

CALIFORNIA WATER SERVICE COMPANY
1720 North First Street, San Jose, CA 95112
(408) 367-8200

Revised Cal. P.U.C. Sheet No. 1485-W

Canceling Revised Cal. P.U.C. Sheet No. 249-W

Rule No. 2

DESCRIPTION OF SERVICE

A. Quantities

The utility will endeavor to supply water dependably and safely in adequate quantities (T)
to meet the reasonable needs and requirements of customers. (T)

B. Pressures

1. Generally.

The utility will endeavor to maintain normal operating pressures of not less than 40 (N)
pounds per square inch nor more than 125 pounds per square inch at the service connection, |
except that during periods of hourly maximum demand the pressure at the time of peak seasonal |
loads may not be less than 30 pounds per square inch and that during periods of hourly minimum |
demand the pressure may not be more than 150 pounds per square inch. Variations in pressure under |
normal operation will not exceed 50% of the average operating pressure. (The average operating |
pressure will be determined by computing the arithmetical average of at least 24 consecutive hourly |
pressure readings.) |

2. Designated Pressure Area.

Within designated areas as shown or described on utility's service area map the utility will |
endeavor to maintain normal minimum operating pressure between 25 p.s.i.g. and 40 p.s.i.g. with |
peak load pressures above 20 p.s.i.g. Prior to June 5, 1976 inquiry should be made to the utility |
for location of such designated areas. (N)

C. Quality

Whenever furnished for human consumption or for domestic uses, the utility will (T)
endeavor to provide water that is wholesome, potable, in no way harmful or dangerous to |
health and, insofar as practicable, free from objectionable odors, taste, color and turbidity. (T)
(D)

(To be inserted by utility)

Issued by

(To be inserted by Cal. P.U.C.)

Advice Letter No. 458 ED F. CATEY
NAME

Date Filed JUL 29 1975

Decision No. 84334 Vice President
TITLE

Effective AUG 3 1975

Resolution No. _____