

## **Appendix M**

- Water Balance Worksheet



# AWWA Free Water Audit Software: Water Balance

WAS v5.0

American Water Works Association.  
Copyright © 2014, All Rights Reserved.

Water Audit Report for:	<b>California Water Service -PV</b>	
Reporting Year:	<b>2014</b>	<b>1/2014 - 12/2014</b>
Data Validity Score:	<b>74</b>	

	Water Exported <i>0.000</i>	Billed Water Exported				
<b>Own Sources</b> (Adjusted for known errors)  <i>0.000</i>	<b>Water Supplied</b>  <i>21,138.000</i>	<b>Authorized Consumption</b>  <i>20,197.450</i>	<b>Billed Authorized Consumption</b>  <i>19,933.225</i>	<b>Billed Metered Consumption (water exported is removed)</b>  <i>19,933.225</i>	<b>Revenue Water</b>  <i>19,933.225</i>	
				<b>Billed Unmetered Consumption</b>  <i>0.000</i>		
		<b>Water Losses</b>  <i>940.550</i>	<b>Unbilled Authorized Consumption</b>  <i>264.225</i>	<b>Unbilled Metered Consumption</b>  <i>0.000</i>	<b>Non-Revenue Water (NRW)</b>  <i>1,204.775</i>	
			<b>Apparent Losses</b>  <i>509.479</i>	<b>Unbilled Unmetered Consumption</b>  <i>264.225</i>		
	<b>Unauthorized Consumption</b>  <i>52.845</i>					
<b>Water Imported</b>  <i>21,138.000</i>		<b>Real Losses</b>  <i>431.071</i>	<b>Customer Metering Inaccuracies</b>  <i>406.801</i>	<b>Systematic Data Handling Errors</b>  <i>49.833</i>		
			<b>Leakage on Transmission and/or Distribution Mains</b> <i>Not broken down</i>	<b>Leakage and Overflows at Utility's Storage Tanks</b> <i>Not broken down</i>		
			<b>Leakage on Service Connections</b> <i>Not broken down</i>			