




# 2025 Urban Water Management Plan

**Dixon District**  
June 2026





## Table of Contents

Table of Contents.....	1
List of Tables .....	5
List of Figures .....	7
List of Acronyms.....	8
Chapter 1 Introduction and Overview.....	11
1.1 Background and Purpose.....	11
1.2 Urban Water Management Planning and the California Water Code .....	12
1.3 Relationship to Other Planning Efforts .....	13
1.4 Plan Organization .....	13
1.5 Demonstration of Consistency with the Delta Plan for Participants in Covered Actions .....	14
1.6 Lay Description.....	15
Chapter 2 Plan Preparation.....	19
2.1 Public Water Systems.....	19
2.2 Regional Planning.....	20
2.3 Individual or Regional Planning and Compliance (Regional Alliance) .....	20
2.4 Plan Preparation, Standard Units, and Basis for Reporting .....	22
2.5 Coordination and Outreach.....	23
2.5.1 Wholesale and Retail Coordination.....	24
2.5.2 Coordination with and Notice to Other Agencies and the Community.....	25
2.5.3 Coordination with Land Use Authorities .....	26
Chapter 3 System Description.....	27
3.1 General Description.....	27
3.2 Service Area Boundary Map .....	28
3.3 Service Area Climate .....	29
3.4 Service Area Population and Demographics.....	30
3.5 Land Uses within Service Area.....	32
Chapter 4 Water Use Characterization .....	35
4.1 Non-Potable Versus Potable Water Use.....	35

4.2 Past, Current, and Projected Water Uses by Sector ..... 36

    4.2.1 Past and Current Water Use ..... 37

    4.2.2 Projected Water Use ..... 40

    4.2.3 Adjustments to Projected Water Uses ..... 42

4.3 Distribution System Water Loss ..... 47

    4.3.1 Previous Five Years Distribution System Losses ..... 47

    4.3.2 Progress Toward Meeting the Water Loss Performance Standard ..... 47

4.4 Climate Change Considerations ..... 50

    4.4.1 Characteristic Five-Year Water Use ..... 51

4.5 Coordinating Water Use Projections ..... 52

Chapter 5 SB X7-7 Baseline, 2020 Target and 2025 Reporting ..... 53

    5.1 Demonstration of Compliance with the 2020 Target in 2020 ..... 53

    5.2 Nexus to State Water Board Urban Water Use Objectives ..... 55

Chapter 6 Water Supply Characterization ..... 59

    6.1 Purchased Water ..... 60

    6.2 Groundwater ..... 60

        6.2.1 Basin Description and Status ..... 61

        6.2.2 Non-SGMA Groundwater Management ..... 63

        6.2.3 SGMA Groundwater Management ..... 64

        6.2.4 Cal Water Coordination with Groundwater Sustainability Agencies ..... 66

        6.2.5 Historical Pumping and Supply Sufficiency ..... 67

    6.3 Surface Water ..... 70

    6.4 Stormwater ..... 70

    6.5 Wastewater and Recycled Water ..... 70

        6.5.1 Recycled Water Coordination ..... 70

        6.5.2 Wastewater Collection, Treatment, and Disposal ..... 70

        6.5.3 Recycled Water System and Recycled Water Beneficial Uses ..... 74

        6.5.4 Actions to Encourage and Optimize Future Recycled Water Use ..... 76

    6.6 Desalinated Water Opportunities ..... 77

    6.7 Water Exchanges and Transfers ..... 77

        6.7.1 Exchanges ..... 77

6.7.2	Transfers .....	77
6.7.3	Emergency Interties .....	77
6.8	Future Water Projects .....	78
6.9	Summary of Existing and Planned Sources of Water .....	80
6.10	Special Conditions .....	83
6.10.1	Climate Change Effects .....	83
6.10.2	Regulatory Conditions and Project Development .....	83
6.10.3	Other Locally Applicable Criteria.....	84
6.11	Energy Intensity.....	84
Chapter 7 Water Supply Reliability Assessment.....		87
7.1	Constraints on Water Sources .....	87
7.1.1	Supply Availability .....	88
7.1.2	Water Quality.....	89
7.1.3	Climate Change .....	90
7.2	Reliability by Type of Year .....	91
7.3	Supply and Demand Assessment.....	94
7.4	Water Supply Management Tools and Options.....	96
7.5	Drought Risk Assessment .....	97
7.5.1	Data, Methods, and Basis for Water Shortage Condition.....	97
7.5.2	Drought Risk Assessment Water Source Reliability.....	97
Chapter 8 Water Shortage Contingency Planning .....		101
Chapter 9 Demand Management Measures .....		109
9.1	Water Waste Prevention Ordinances.....	110
9.2	Metering.....	112
9.3	Conservation Pricing.....	112
9.4	Customer Conservation Programs.....	112
9.4.1	Current Customer Conservation Programs .....	113
9.4.2	Future Customer Conservation Programs .....	114
9.4.3	CII Performance Measures .....	117
9.5	Water Loss Management .....	120
9.6	Water Conservation Program Staffing.....	120

9.7	Summary and Implementation Considerations .....	121
Chapter 10 Plan Adoption, Submittal, and Implementation .....		123
10.1	Inclusion of All 2025 Data .....	123
10.2	Notice of Public Hearing .....	124
10.2.1	Notice to Cities and Counties .....	124
10.2.2	Notice to the Public .....	125
10.3	Public Hearing and Adoption .....	125
10.4	Plan Submittal .....	126
10.5	Public Availability .....	126
10.6	Notification of Public Utilities Commission .....	127
10.7	Amending an Adopted UWMP or Water Shortage Contingency Plan .....	127
Appendix A: UWMP Act Checklist .....		A-1
Appendix B: Correspondence .....		B-1
Appendix C: Public Meeting Notice .....		C-1
Appendix D: City of Dixon Land Use Map .....		D-1
Appendix E: Historical and Projected Service Area Population, Services, Sales, and Production .....		E-1
Appendix F: Climate Change Studies – Executive Summaries .....		F-1
Appendix G: Water Shortage Contingency Plan .....		G-1
Appendix H: Conservation Master Plan .....		H-1
Appendix I: Resolution to Adopt .....		I-1

## List of Tables

Table 2-1. Public Water Systems (DWR Table 2-1) .....	20
Table 2-2. Plan Identification (DWR Table 2-2) .....	21
Table 2-3. Supplier Identification (DWR Table 2-3) .....	23
Table 2-4. Water Supplier Information Exchange (DWR Table 2-4).....	24
Table 3-1. Population – Current and Projected (DWR Table 3-1) .....	31
Table 3-2. Demographic and Housing Characteristics .....	32
Table 4-1. Uses for Potable and Non-Potable Water – Actual (DWR Table 4-1).....	38
Table 4-2. Use for Potable and Non-Potable Water – Projected (DWR Table 4-2) .....	41
Table 4-3. Inclusion in Water Use Projections (DWR Table 4-3).....	43
Table 4-4. Projected Baseline and Adjusted Potable Water Demand.....	46
Table 4-5. Water Loss Audit Reporting (DWR Table 4-5).....	47
Table 4-6. Progress Towards 2028 Water Loss Standards (DWR Table 4-6) .....	49
Table 4-7. Characteristic Five-Year Water Use for Normal and Multi-Year Dry Scenarios.....	52
Table 5-1. SB X7-7 2020 Target Progress (DWR Table 5-1).....	54
Table 6-1. Groundwater Volume Pumped (DWR Table 6-1).....	69
Table 6-2. Wastewater Collected Within Service Area in 2025 (DWR Table 6-2) .....	72
Table 6-3. Wastewater Treatment and Outcomes Within UWMP Service Area in 2025 (DWR Table 6-3).....	73
Table 6-4. Recycled Water Direct Beneficial Uses Within Service Area (DWR Table 6-4).....	75
Table 6-5. 2020 UWMP Recycled Water Use Projection Compared to 2025 Actual (DWR Table 6-5).....	76
Table 6-6. Methods to Expand Future Recycled Water Use (DWR Table 6-6) .....	76

---

Table 6-7. Expected Future Water Supply Projects or Programs (DWR Table 6-7).....	79
Table 6-8. Water Supplies – Actual (DWR Table 6-8) .....	81
Table 6-9. Water Supplies – Projected (DWR Table 6-9) .....	82
Table 6-10. Recommended Energy Intensity – Total Utility Approach (DWR Table O-1B) .....	85
Table 7-1. Basis of Water Year Data (Reliability Assessment) (DWR Table 7-1) .....	93
Table 7-2. Normal Year Supply and Use Comparison (DWR Table 7-2) .....	94
Table 7-3. Single Dry Year Supply and Use Comparison (DWR Table 7-3) .....	95
Table 7-4. Multiple Dry Years Supply and Use Comparison (DWR Table 7-4).....	95
Table 7-5. Five-Year Drought Risk Assessment Tables (DWR Table 7-5).....	99
Table 8-1. Water Shortage Contingency Plan Levels (DWR Table 8-1) .....	102
Table 8-2. Supply Augmentation and Other Actions (DWR Table 8-2) .....	102
Table 8-3. Demand Reduction Actions (DWR Table 8-3) .....	103
Table 9-1. Barriers and Customer Requirements of Landscape Transformation Programs.....	115
Table 9-2. Representative Conservation Measures with Significant Savings Potential .....	116
Table 9-3. Proposed New Conservation Staff Positions.....	121
Table 10-1. Notification to Cities and Counties (DWR Table 10-1) .....	125

## List of Figures

Figure 3-1. District Location and Service Boundaries .....	29
Figure 3-2. 30-Year Normals, Precipitation and Maximum Daily Air Temperature .....	30
Figure 4-1. Annual Total Water Demand by Sector .....	39
Figure 4-2. Annual Per Capita Water Use .....	39
Figure 4-3. Projected Annual Water Demand by Sector.....	41
Figure 4-4. Projected Per Capita Water Use.....	42
Figure 4-5. Projected Potable Water Demand and Conservation.....	46
Figure 6-1. Groundwater Basin Underlying the Dixon District .....	62
Figure 6-2. Dixon District Historical Pumping (1980–2025).....	68
Figure 7-1. Deviation of Annual Rainfall from Long-Term Average .....	92

## List of Acronyms

AB	Assembly Bill
ABAG	Association of Bay Area Governments
AF	acre-feet
AFY	acre-feet per year
AMI	Advanced Metering Infrastructure
AMR	Automatic meter reading
AWE	Alliance for Water Efficiency
AWWA	American Water Works Association
BMO	Basin Management Objectives
BMP	Best Management Practices
CAP	Customer Assistance Program
CCF	hundred cubic feet
CCR	California Code of Regulations
CII	Commercial, Industrial, and Institutional
CPUC	California Public Utilities Commission
CUWCC	California Urban Water Conservation Council
CWC	California Water Code
DDW	Division of Drinking Water
DIMs	Dedicated irrigation meters
DMM	Demand Management Measure
DPR	Direct Potable Reuse
DWR	California Department of Water Resources
EO	Executive Order
EPA	Environmental Protection Agency
FTE	Full-time equivalent
GHG	Green House Gas
GMP	Groundwater Management Plan
GPCD	gallons per capita per day
GPF	gallons per flush
GPSCD	gallons per service connection per day
GRC	General Rate Case
GSA	Groundwater Sustainability Agency
GSP	Groundwater Sustainability Plan
IPCC	Intergovernmental Panel on Climate Change
IPR	Indirect Potable Reuse
IRWMP	Integrated Regional Water Management Plan
kWh	kilowatt-hour

---

kWh/AF	kilowatt-hours per acre-foot
kWh/vol	kilowatt-hours per volume
M&I	Municipal and Industrial
MAWA	Maximum Applied Water Allowance
MCCWL	Making Conservation a California Way of Life
MCL	Maximum Contaminant Levels
MG	million gallons
MGD	million gallons per day
MUMs	Mixed-use meters
MWELO	Model Water Efficient Landscape Ordinance
NPR	Non Potable Reuse
P/MAs	Projects and Management Actions
PWS	Public Water System
RCP	Representative Concentration Pathways
RUWMP	Regional Urban Water Management Plan
SB	Senate Bill
SGMA	Sustainable Groundwater Management Act
SID	Solano Irrigation District
SWRCB	State Water Resources Control Board
TAZ	Traffic Analysis Zones
TCFD	Task Force on Climate-related Financial Disclosures
U.S.	United States
UWMP	Urban Water Management Plan
UWUO	Urban Water Use Objective
WSCP	Water Shortage Contingency Plan
WWTF	Wastewater Treatment Facility
WWTP	Wastewater Treatment Plant
WY	Water Year



## Chapter 1

### Introduction and Overview

This chapter discusses the importance and uses of this 2025 Urban Water Management Plan (UWMP or Plan), the relationship of this Plan to the California Water Code (CWC), the relationship of this Plan to other local and regional planning efforts, and how this Plan is organized and developed in general accordance with the California Department of Water Resources' (DWR's) 2025 UWMP Guidebook.<sup>1</sup> Specifically, this chapter contains the following sections:

1.1 Background and Purpose

1.2 Urban Water Management Planning and the California Water Code

1.3 Relationship to Other Planning Efforts

1.4 Plan Organization

1.5 Demonstration of Consistency with the Delta Plan for Participants in Covered Actions

1.6 Lay Description

#### 1.1 Background and Purpose

California Water Service (Cal Water) is a public utility regulated by the California Public Utilities Commission (CPUC) that supplies water service to more than 2 million Californians through about 500,000 connections. Cal Water's 24 districts serve over 100 communities, spanning from the Chico District in the north to the Palos Verdes Peninsula in the south. California Water Service Group, Cal Water's parent company, also provides utility service to communities in Washington, New Mexico, Hawaii, and Texas. While water rates are set separately for each of Cal Water's 24 districts, oversight of the water rate setting process and district operations is provided by the CPUC.

This UWMP is a foundational document and source of information about the Dixon District's (also referred to herein as the "District") historical and projected water demands, water supplies, supply reliability and potential vulnerabilities, water shortage contingency planning, and demand management programs. Among other things, it is used as:

- A long-range planning document by Cal Water for water supply and system planning; and

---

<sup>1</sup> The 2025 UWMP Guidebook is available at: <https://water.ca.gov/Programs/Water-Use-And-Efficiency/Urban-Water-Use-Efficiency/Urban-Water-Management-Plans>.

- A source for data on population, housing, water demands, water supplies, and capital improvement projects used in:
  - Regional water resource management plans prepared by wholesale water suppliers and other regional planning authorities (as applicable);
  - General Plans prepared by cities and counties; and,
  - Statewide and broad regional water resource plans prepared by DWR, the State Water Resources Control Board (SWRCB), or other state agencies.

The District’s last UWMP was completed in 2021, referred to herein as the “2020 UWMP.” This Plan is an update to the 2020 UWMP and carries forward information from that plan that remains current and relevant, and provides additional information as required by subsequent amendments to the UWMP Act (CWC §10610 – 10657). Although this Plan is an update to the 2020 UWMP, it was developed to be a self-contained, stand-alone document and does not require readers to reference information contained in previous UWMP updates.

## 1.2 Urban Water Management Planning and the California Water Code

The UWMP Act requires urban water suppliers to prepare a UWMP every five years and to submit this Plan to DWR, the California State Library, and any city or county within which the supplier provides water supplies. All urban water suppliers, either publicly or privately owned, providing water for municipal purposes either directly or indirectly to more than 3,000 customers or supplying more than 3,000 acre-feet annually are required to prepare a UWMP (CWC §10617). For the purposes of the Plan, the terms “customer” and “connections” are used interchangeably.

The UWMP Act was enacted in 1983. Over the years it has been amended in response to water resource challenges and planning imperatives confronting California. A significant amendment was made in 2009 as a result of the governor’s call for a statewide 20 percent reduction in urban water use by 2020, referred to as “20x2020,” the Water Conservation Act of 2009, and “Senate Bill (SB) X7-7.” This amendment required urban retail water suppliers to establish water use targets for 2015 and 2020 that would result in statewide water savings of 20 percent by 2020. Beginning in 2016, urban retail water suppliers were required to comply with the water conservation requirements in SB X7-7 in order to be eligible for state water grants or loans. Chapter 5 of this Plan contains the data and calculations used to determine compliance with these requirements.

In 2016, Governor Brown signed Executive Order (EO) B-37-16 Making Conservation a California Way of Life (MCCWL) regulation and subsequently SB 606 and Assembly Bill (AB) 1668 were passed in 2018. A substantial revision to the UWMP Act was made through SB 606 and AB 1668. These changes include, among other things: (1) additional requirements for Water Shortage Contingency Plans (WSCPs) (CWC §10640), (2) requirements for urban water suppliers to conduct

a drought risk assessment as part of their future UWMPs to assess water supply reliability for a period of drought lasting five consecutive water years (WYs; CWC §10635(b)), and (3) conduct annual water supply and demand assessments to determine its water supply reliability for the current year and one dry year (CWC §10632(a)). These elements are included in Chapter 7 and Chapter 8 (and the WSCP included as **Appendix G**) of this Plan. Additionally, SB 606 and AB 1668 set new requirements for urban water agencies to continue to increase water efficiency beyond SB X7-7. Beginning in 2024, agencies were required to report an annual Urban Water Use Objective (UWUO) to DWR as part of their Annual Water Use Reports.

The UWMP Act contains numerous other requirements that a UWMP must satisfy. **Appendix A** to this Plan lists each of these requirements and where in the Plan they are addressed.

### 1.3 Relationship to Other Planning Efforts

This Plan provides information specific to water management and planning by the Dixon District. However, water management does not happen in isolation; there are other planning processes that integrate with the UWMP to accomplish urban planning. Some of these relevant planning documents include relevant city and county General Plans, Water Master Plans, Recycled Water Master Plans, Integrated Resource Plans, Integrated Regional Water Management Plans, Groundwater Management Plans, Groundwater Sustainability Plans (GSPs), and others.

This Plan is informed by and helps to inform these other planning efforts. In particular, this Plan utilizes information contained in city and county General Plans and local and regional water resource plans to the extent data from these plans are applicable and available.

### 1.4 Plan Organization

The organization of this Plan follows the same sequence as outlined in the 2025 UWMP Guidebook.<sup>2</sup>

Chapter 1 - Introduction and Overview

Chapter 2 - Plan Preparation

Chapter 3 - System Description

Chapter 4 - Water Use Characterization

Chapter 5 - SB X7-7 Baseline, 2020 Target and 2025 Reporting

---

<sup>2</sup>ibid

Chapter 6 - Water Supply Characterization

Chapter 7 - Water Supply Reliability Assessment

Chapter 8 - Water Shortage Contingency Planning

Chapter 9 - Demand Management Measures

Chapter 10 - Plan Adoption, Submittal, and Implementation

In addition to these ten chapters, this Plan includes a number of appendices providing supporting documentation and supplemental information. Pursuant to CWC §10644(a)(2), this Plan utilizes the standardized forms, tables, and displays developed by DWR for the reporting of water use and supply information required by the UWMP Act. This Plan also includes additional tables, figures, and maps to augment the set developed by DWR, as appropriate. The table headers indicate if the table is part of DWR’s standardized set of submittal tables.

## 1.5 Demonstration of Consistency with the Delta Plan for Participants in Covered Actions

Although not required by the UWMP Act, in the 2025 UWMP Guidebook,<sup>3</sup> DWR recommends that all suppliers that are participating in, or may participate in, receiving water from a proposed project that is considered a “covered action” under the Delta Plan—such as a (1) multiyear water transfer; (2) conveyance facility; or (3) new diversion that involves transferring water through, exporting water from, or using water in the Sacramento-San Joaquin Delta (Delta)—provide information in their UWMP to demonstrate consistency with the Delta Plan policy WR P1, Reduce Reliance on the Delta Through Improved Regional Water Self-Reliance (California Code of Regulations, Title 23, Section 5003).

The Dixon District’s sole source of water supply is groundwater, and therefore the District does not receive water or plan to receive water from a “covered action” under the Delta Plan. As such, this requirement is not applicable.

---

<sup>3</sup>ibid

## 1.6 Lay Description

### **CWC § 10630.5**

*Each plan shall include a simple lay description of how much water the agency has on a reliable basis, how much it needs for the foreseeable future, what the agency's strategy is for meeting its water needs, the challenges facing the agency, and any other information necessary to provide a general understanding of the agency's plan.*

This 2025 UWMP is prepared for the Cal Water Dixon District, which serves drinking water to a population of approximately 9,394. The District meets the definition of an urban water supplier. Therefore, in accordance with CWC §10621(f), the District is obligated to develop and submit a UWMP to DWR.

This UWMP serves as a foundational planning document and includes descriptions of historical and projected water demands, and water supplies, and the resulting reliability during a set of defined water supply conditions over a 20-year planning horizon. This document also describes the actions the District is taking to promote water conservation, both by the District itself and by its customers (referred to as “demand management measures”), and includes a plan to address potential water supply shortages such as drought or other impacts to supply availability (the “Water Shortage Contingency Plan”, included as **Appendix G**). This UWMP is updated every five years in accordance with state requirements under the UWMP Act and amendments (Division 6 Part 2.6 of the CWC §10610 – 10657). Past plans developed for the District are available on the DWR Water Use Efficiency Data Portal website: <https://wuedata.water.ca.gov/>.

This document includes 10 chapters, which are summarized below pursuant to the requirements of the CWC §10630.5.

### **Chapter 1- Introduction and Overview**

This chapter presents the background and purpose of the UWMP, identifies the Plan organization, and provides this lay description overview of the document. For agencies that rely on water from the Delta, this section also discusses and demonstrates consistency with the Delta Plan by the Delta Stewardship Council.

### **Chapter 2 - Plan Preparation**

This chapter discusses key structural aspects related to the preparation of the UWMP, and describes the coordination and outreach conducted as part of the preparation of the Plan, including coordination with local agencies and other community organizations (i.e., City of Dixon and Solano County), relevant Groundwater Sustainability Agency (GSAs), and the public.

***Chapter 3 - System Description***

This chapter provides a description of the Dixon District’s water system and the service area, including information related to the climate, population, and demographics. The District is located in Solano County. The District serves a population of approximately 9,394 and has a climate characterized by hot dry summers and cool wet winters. The majority of the 20.3 inches of average annual precipitation falls between October and May. The service area includes a mixture of low, medium, and high density residential, mixed use, commercial, industrial, and public facilities, and parks/open space. All water customers are considered urban (i.e., non-agricultural water users).

***Chapter 4 - Water Use Characterization***

This chapter provides a description and quantifies the Dixon District’s current and projected demands through the year 2050. The District provides drinking water (also referred to as “potable water”) to customers. Water demands refer not only to the water used by customers, but also includes the water used as part of the system’s maintenance and operation, as well as unavoidable losses inherent in the operation of a water distribution system. Water demand within the District was 1,238 acre-feet per year (AFY) in 2025. Although population is expected to increase, taking into account historical water use and other growth, climatic variability, and other assumptions, water demand within the District is projected to decrease to 993 AFY in 2050, a change of 22 percent compared to 2025. In dry year periods, water demands are expected to be somewhat higher, potentially up to 1,059 AFY by 2050 during an extended five-year drought.

***Chapter 5 - SB X7-7 Baseline, 2020 Target and 2025 Reporting***

In this chapter, the Dixon District demonstrates compliance with its per capita water use target for the year 2020. The Water Conservation Act of 2009 (Senate Bill X7-7) was enacted in November 2009 and requires the state of California to achieve a 20 percent reduction in urban per capita water use by December 31, 2020. In order to achieve this, each urban retail water supplier was required to establish water use targets for 2015 and 2020 using methodologies established by DWR. The District was in compliance with its 2020 water use target of 161 gallons per capita per day (GPCD), having reduced its water use in 2020 to 119 GPCD. The District continues to meet its 2020 Target in 2025.

***Chapter 6 - Water Supply Characterization***

This chapter presents an analysis of the Dixon District’s water supplies, as well as an estimate of water-related energy-consumption. The intent of this chapter is to present a comprehensive overview of the District’s water supplies, estimate the volume of available supplies over the

UWMP planning horizon, and assess the sufficiency of the District's supplies to meet projected demands under "normal" hydrologic conditions.

The sole source of water supply for the District is groundwater, and there are no new sources of supply currently planned. The District pumps groundwater from the Solano Subbasin (DWR Basin No. 5-021.66) of the Sacramento Valley Basin.

The Solano Subbasin is not adjudicated and is not considered by DWR to be critically overdrafted. The Solano Subbasin has been prioritized by DWR as "medium priority." Following the passage of the Sustainable Groundwater Management Act (SGMA), five GSAs were formed in the Solano Subbasin – the Solano GSA, City of Vacaville GSA, Sacramento County GSA, SID GSA, and the Northern Delta GSA. Collectively the five GSAs formed the Solano Collaborative to develop a single GSP for the Solano Subbasin. The Solano Collaborative submitted the GSP to DWR in January 2022 which was approved by DWR in January 2024. The District falls within the jurisdiction of the Solano Subbasin GSA. Based on available information, including that which has been developed by the GSAs to date, the groundwater supply is expected to be sufficient to support the District's projected water demand through 2050.

Calculating and reporting of water system energy intensity is also required for the 2025 UWMPs. Energy intensity is defined as the net energy used for water treatment, pumping, conveyance, and distribution for all water entering the distribution system, and does not include the energy used to treat wastewater. The energy intensity for the District is estimated to be 563 kilowatt hours per acre-foot of water (kWh/AF).

### ***Chapter 7 - Water Supply Reliability Assessment***

This chapter assesses the reliability of the Dixon District's water supplies, with a specific focus on potential constraints such as groundwater supply availability, water quality, and climate change. The intent of this chapter is to identify any potential constraints that could affect the reliability of the District's supply (such as drought conditions) to support the District's planning efforts to ensure that its customers are well served. Water service reliability is assessed during normal, single dry-year, and multiple dry-year hydrologic conditions. Based on this analysis, the District expects the available supplies to be sufficient to meet projected demands in all hydrologic conditions, including a five-year drought period, and considering the impacts of climate change.

Further, potential water quality issues are not expected to affect the quality of water served to the District's customers, as water quality is routinely monitored and the District is able to make all appropriate adjustments to its treatment and distribution system to ensure only high-quality drinking water is served.

***Chapter 8 - Water Shortage Contingency Planning***

This chapter describes the WSCP for the Dixon District. The WSCP serves as a standalone document to be engaged in the case of a water shortage event, such as a drought or supply interruption, and defines specific policies and actions that will be implemented at various shortage level scenarios (e.g., implementing customer water budgets and surcharges, or restricting landscape irrigation to specific days and/or times). Consistent with DWR requirements, the WSCP includes six Shortage Levels to address shortage conditions ranging from up to 10 percent to greater than 50 percent shortage.

***Chapter 9 - Demand Management Measures***

This chapter includes descriptions of past and planned conservation programs that Cal Water operates within each demand management measure (DMM) category outlined in the UWMP Act, specifically: (1) water waste prevention ordinances, (2) metering, (3) conservation pricing, (4) public education and outreach, (5) distribution system water loss management, (6) water conservation program coordination and staffing support, and (7) “other” DMMs. Cal Water has developed a suite of conservation programs and policies, which address each DMM category.

***Chapter 10 - Plan Adoption, Submittal, and Implementation***

This chapter provides information on a public hearing, the adoption process for the UWMP and WSCP, the adopted UWMP and WSCP submittal process, Plan implementation, and the process for amending the adopted UWMP and WSCP. Prior to adopting the Plan, Cal Water held a formal public hearing to present information on its Dixon District UWMP and WSCP on May 20, 2026, 6:30 PM. This UWMP and the corresponding WSCP were submitted to DWR within 30 days of adoption and by the July 1, 2026 deadline.

## Chapter 2

### Plan Preparation

This chapter discusses the type of Urban Water Management Plan (UWMP or Plan) the California Water Service (Cal Water) Dixon District (also referred to herein as “District”) has prepared and includes information that will apply throughout the Plan. Coordination and outreach during the development of the Plan is also discussed. Specifically, this chapter includes the following sections:

- 2.1 Public Water Systems
- 2.2 Regional Planning
- 2.3 Individual or Regional Planning and Compliance (Regional Alliance)
- 2.4 Plan Preparation, Standard Units, and Basis for Reporting
- 2.5 Coordination and Outreach

#### 2.1 Public Water Systems

The District operates the Public Water System (PWS) listed in **Table 2-1**. Public Water Systems are the systems that provide drinking water for human consumption and are regulated by the California State Water Resources Control Board (SWRCB), Division of Drinking Water. The SWRCB requires that water agencies report water usage and other relevant PWS information via the electronic Annual Reports to the Drinking Water Program (eARDWP). These data are used by the state to determine, among other things, whether an urban retail water supplier has reached the threshold (3,000 or more connections or 3,000 acre-feet [AF] of water supplied) for submitting a UWMP. For the purposes of the Plan, the terms “customer” and “connections” are used interchangeably. In 2025, the District provided water through 3,063 connections and served 1,348 AF of water (**Table 2-1**). The District is therefore subject to the requirements of the UWMP Act.

**Table 2-1. Public Water Systems (DWR Table 2-1)**

Has there been a change in the number of affiliated Public Water Systems since the 2020 UWMP? (OPTIONAL)			No
Public Water System Number	Public Water System Name	Number of Municipal Connections 2025	Volume of Water Supplied 2025
			(AF)
CA4810002	California Water Service Co. - Dixon	3,063	1,348
<b>Total</b>		3,063	1,348
<b>Notes:</b>			

## 2.2 Regional Planning

Regional planning can deliver mutually beneficial solutions to all agencies involved by reducing costs for the individual agency, assessing water resources at the appropriate geographic scale, and allowing for solutions that cross jurisdictional boundaries. Cal Water participates in regional water resources planning initiatives throughout California in the regions in which its 24 water districts are located. Cal Water monitors and supports the goals of the Westside Sacramento Integrated Regional Water Management Plan (IRWMP). Cal Water also participates in the implementation of the Groundwater Sustainability Plan (GSP) for Solano Subbasin. The District falls within the jurisdiction of the Solano Subbasin Groundwater Sustainability Agency (GSA). The District has a Cal Water representative that serves on the Solano GSA Board of Directors, as well as a representative that serves on the Solano GSA Technical Advisory Committee.

## 2.3 Individual or Regional Planning and Compliance (Regional Alliance)

Urban water suppliers may elect to prepare individual or regional UWMPs. The Dixon District has elected to prepare an individual UWMP (see **Table 2-2**).

This Plan has been prepared in general accordance with the format suggested in the California Department of Water Resources’ (DWR’s) 2025 UWMP Guidebook. Text from the UWMP Act has been included in text boxes at the beginning of relevant Chapters of this UWMP. The information presented in the respective UWMP chapters, and the associated text, figures, and charts are collectively intended to fulfill the requirements of that sub-section of the UWMP Act. To the extent practicable, supporting documentation has also been provided in **Appendix A** through **Appendix I**. Other sources for the information contained herein are provided in the references section of the Plan.

Urban retail water suppliers may report on the requirements of the Water Conservation Act of 2009 (Senate Bill [SB] X7-7) individually or as a member of a “Regional Alliance.” Although the District is a member of a Regional Alliance, this UWMP provides information on the District’s compliance with its SB X7-7 water conservation targets as an individual urban retail water supplier.

**Table 2-2. Plan Identification (DWR Table 2-2)**

Select One or Both	Type of Plan		Name of Regional Alliance or RUWMP
<input checked="" type="checkbox"/>	<b>Individual UWMP</b>		
	<input checked="" type="checkbox"/>	Water Supplier is also a member of a SB X7-7 Regional Alliance	California Water Service – Sacramento River Alliance
<input type="checkbox"/>	<b>Regional Urban Water Management Plan (RUWMP)</b>		
<p><b>Notes:</b></p> <p>(a) The Dixon District is a member of a Regional Alliance; however, Chapter 5 provides information on the District’s progress towards meeting its water conservation targets under SB X7-7 as an individual urban retail water supplier.</p>			

## 2.4 Plan Preparation, Standard Units, and Basis for Reporting

**CWC § 10608.12 (t)**

*“Urban retail water supplier” means a water supplier, either publicly or privately owned, that directly provides potable municipal water to more than 3,000 end users or that supplies more than 3,000 acre-feet of potable water annually at retail for municipal purposes.*

**CWC § 10617**

*“Urban water supplier” means a supplier, either publicly or privately owned, providing water for municipal purposes either directly or indirectly to more than 3,000 customers or supplying more than 3,000 acre-feet of water annually. An urban water supplier includes a supplier or contractor for water, regardless of the basis of right, which distributes or sells for ultimate resale to customers. This part applies only to water supplied from public water systems subject to Chapter 4 (commencing with Section 116275) of Part 12 of Division 104 of the Health and Safety Code.*

**CWC § 10621 (a)**

*Each urban water supplier shall update its plan at least once every five years on or before July 1, in years ending in six and one, incorporating updated and new information from the five years preceding each update.*

**CWC § 10621 (f)**

*Each urban water supplier shall update and submit its 2020 plan to the department by July 1, 2021.*

Per California Water Code (CWC) §10617, the Dixon District is an urban water supplier providing water for municipal purposes to more than 3,000 connections or supplying more than 3,000 AF of water annually. The Dixon District is therefore obligated under CWC §10621(f) to develop and submit a UWMP to DWR by July 1, 2026. The District is an urban retail water supplier, as defined by CWC §10608.12 (t) and §10617, and as identified in **Table 2-3**. The District is not a wholesale water supplier.

Annual volumes of water reported in this UWMP are measured in AF and are reported on a calendar year basis (**Table 2-3**). Water use and planning data reported in this UWMP use calendar year 2025 as the selected twelve-month reporting period, consistent with the reporting period options provided in the 2025 UWMP Guidebook.

Further, consistent with the 2025 UWMP Guidebook, the terms “water use”, “water consumption”, and “water demand” are used interchangeably in this UWMP.

**Table 2-3. Supplier Identification (DWR Table 2-3)**

Type of Supplier (select one or both)	
<input type="checkbox"/>	Supplier is a wholesale supplier
<input checked="" type="checkbox"/>	Supplier is a retail supplier
Fiscal or Calendar Year (select one)	
<input checked="" type="checkbox"/>	UWMP Tables are in calendar years
<input type="checkbox"/>	UWMP Tables are in fiscal years
<b>If using fiscal years provide month and date that the fiscal year begins (mm/dd)</b>	
Units of measure used in UWMP (Select from the drop down list).	
<b>Unit</b>	AF
<b>Notes:</b>	

## 2.5 Coordination and Outreach

**CWC § 10620 (d) (3)**

*Each urban water supplier shall coordinate the preparation of its plan with other appropriate agencies in the area, including other water suppliers that share a common source, water management agencies, and relevant public agencies, to the extent practicable.*

**CWC § 10631 (a)** A plan shall be adopted in accordance with this chapter that shall do all of the following:

*Urban water suppliers shall coordinate with local or regional land use authorities to determine the most appropriate land use information, including, where appropriate, land use information obtained from local or regional land use authorities, as developed pursuant to Article 5 (commencing with Section 65300) of Chapter 3 of Division 1 of Title 7 of the Government Code.*

**CWC § 10642**

*Each urban water supplier shall encourage the active involvement of diverse social, cultural, and economic elements of the population within the service area prior to and during the preparation of both the plan and the water shortage contingency plan. Prior to adopting either, the urban water supplier shall make both the plan and the water shortage contingency plan available for public inspection and shall hold a public hearing or hearings thereon. ...*

Coordination with other water suppliers, cities, counties, and other community organizations in the region is an important part of preparing a UWMP and a Water Shortage Contingency Plan

(WSCP). This section identifies the agencies and organizations the Dixon District sought to coordinate with during preparation of this Plan.

2.5.1 Wholesale and Retail Coordination

**CWC § 10631 (h)**

*An urban water supplier that relies upon a wholesale agency for a source of water shall provide the wholesale agency with water use projections from that agency for that source of water in five-year increments to 20 years or as far as data is available. The wholesale agency shall provide information to the urban water supplier for inclusion in the urban water supplier’s plan that identifies and quantifies, to the extent practicable, the existing and planned sources of water as required by subdivision (b), available from the wholesale agency to the urban water supplier over the same five-year increments, and during various water-year types in accordance with subdivision (f). An urban water supplier may rely upon water supply information provided by the wholesale agency in fulfilling the plan informational requirements of subdivisions (b) and (f).*

Urban retail water suppliers relying on one or more wholesalers for water supply are required to provide these wholesalers with information regarding projected water supply and demand. As shown in **Table 2-4**, the District does not derive any of its water supply from a wholesale water supplier.

**Table 2-4. Water Supplier Information Exchange (DWR Table 2-4)**

Wholesale Water Supplier Name
<b>Not Applicable (see note a)</b>
<p><b>Notes:</b></p> <p>(a) The District does not derive any of its water supply from a wholesale water supplier.</p>

## 2.5.2 Coordination with and Notice to Other Agencies and the Community

### **CWC § 10620 (d) (3)**

*Each urban water supplier shall coordinate the preparation of its plan with other appropriate agencies in the area, including other water suppliers that share a common source, water management agencies, and relevant public agencies, to the extent practicable.*

### **CWC § 10642**

*Each urban water supplier shall encourage the active involvement of diverse social, cultural, and economic elements of the population within the service area prior to and during the preparation of both the plan and the water shortage contingency plan. Prior to adopting either, the urban water supplier shall make both the plan and the water shortage contingency plan available for public inspection and shall hold a public hearing or hearings thereon. Prior to any of these hearings, notice of the time and place of the hearing shall be published within the jurisdiction of the publicly owned water supplier pursuant to Section 6066 of the Government Code. The urban water supplier shall provide notice of the time and place of a hearing to any city or county within which the supplier provides water supplies. Notices by a local public agency pursuant to this section shall be provided pursuant to Chapter 17.5 (commencing with Section 7290) of Division 7 of Title 1 of the Government Code. A privately owned water supplier shall provide an equivalent notice within its service area. After the hearing or hearings, the plan or water shortage contingency plan shall be adopted as prepared or as modified after the hearing or hearings.*

The Dixon District coordinated with cities, counties, and other community organizations during preparation of this UWMP. Cal Water provided notice to these entities and the communities it serves 60 days prior to the public hearing it held on May 20, 2026, to present the draft of the UWMP, address questions, and receive comments. Cities and counties receiving the public hearing notification from the District as required per CWC §10621 (b) are listed in **Table 10-1** in Chapter 10 of this Plan.

Copies of correspondence with other agencies and public notices are provided in **Appendix B** and **Appendix C**, respectively.

Water suppliers are required by the UWMP Act to encourage active involvement of the community within the service area prior to and during the preparation of its UWMP. The UWMP Act also requires water suppliers to make a draft of the UWMP available for public review and to hold a public hearing regarding the findings of the UWMP prior to its adoption. In addition to sending notices to the various agencies listed in **Table 2-4**, the District also notified the public of its intent to adopt its UWMP. The Public Review Draft of the 2025 UWMP was made available on Cal Water's website on April 20, 2026. Additional information on public participation, including information on noticing, is provided in Chapter 10.

### 2.5.3 Coordination with Land Use Authorities

**CWC § 10631 (a)** *A plan shall be adopted in accordance with this chapter that shall do all of the following:*

*Urban water suppliers shall coordinate with local or regional land use authorities to determine the most appropriate land use information, including, where appropriate, land use information obtained from local or regional land use authorities, as developed pursuant to Article 5 (commencing with Section 65300) of Chapter 3 of Division 1 of Title 7 of the Government Code.*

Cal Water coordinated with the City of Dixon and Solano County staff to review and confirm that appropriate land use assumptions were used to develop the UWMP demand projections. Correspondence with land use authorities is included in **Appendix B**.

## Chapter 3

### System Description

#### **CWC § 10631 (a)**

*A plan shall be adopted in accordance with this chapter that shall do all of the following:*

*Describe the service area of the supplier, including current and projected population, climate, and other social, economic, and demographic factors affecting the supplier's water management planning. The projected population estimates shall be based upon data from the state, regional, or local service agency population projections within the service area of the urban water supplier and shall be in five-year increments to 20 years or as far as data is available. The description shall include the current and projected land uses within the existing or anticipated service area affecting the supplier's water management planning. Urban water suppliers shall coordinate with local or regional land use authorities to determine the most appropriate land use information, including, where appropriate, land use information obtained from local or regional land use authorities, as developed pursuant to Article 5 (commencing with Section 65300) of Chapter 3 of Division 1 of Title 7 of the Government Code.*

This chapter provides a description of the California Water Service (Cal Water) Dixon District (also referred to herein as the "District") water system and service area, including climate, population, demographics, and land uses to help in understanding various elements of water supply and demand. This chapter includes the following sections:

- 3.1 General Description
- 3.2 Service Area Boundary Map
- 3.3 Service Area Climate
- 3.4 Service Area Population and Demographics
- 3.5 Land Uses within Service Area

### 3.1 General Description

The District was formed in 1927 when Cal Water, a public water utility regulated by the California Public Utilities Commission (CPUC), purchased the Dixon Public Water System from the Pacific Gas and Electric Company. The District serves a portion of the City of Dixon in Solano County. The City of Dixon provides water service to the parts of Dixon not served by the District. In total, the District currently has nine wells, two storage tanks, three booster pumps, and over 35 miles of pipeline delivering approximately 1.2 million gallons of water daily. The District delivers water to residential, commercial, and governmental customers. Residential customers account for most of the District's service connections and 64 percent of its water uses. Non-residential water uses

account for eight percent of total demand, while system water losses account for the remaining amount.

### 3.2 Service Area Boundary Map


**Figure 3-1** shows the location of the Dixon District and its current service area boundaries. Interstate Highway 80 lies to the northwest of the District. State Highway 113 runs through the eastern side of the District. The Sacramento River, the principal drain for the region, flows to the east of the District. The Sacramento-San Joaquin River Delta lies to the south of the District.

Topographically, the District is on level terrain and approximately 64 feet above sea level. Like much of California, the District is in a seismically active region. While the District does not overlie any known active faults, there are faults nearby that could subject the District to ground shaking and seismic hazards, including liquefaction of soils, which has the potential to disrupt water service.<sup>4</sup>

---

<sup>4</sup> Dixon General Plan 2040, Natural Environment. Accessed from:  
<https://www.cityofdixonca.gov/departments/CommunityDevelopment/GeneralPlan>

**Figure 3-1. District Location and Service Boundaries**




### 3.3 Service Area Climate

The Dixon District’s climate is characterized by hot dry summers and cool wet winters (see **Figure 3-2**).<sup>5</sup> Most rainfall occurs between October and May. Precipitation totals in the summer months

<sup>5</sup> Precipitation and temperature data downloaded from: <https://prism.oregonstate.edu/explorer/>. These data represent a 30-year period from 1991 through 2020. The x-axis reflects the end of the 30-year time series.

are negligible. On average, the District receives 20.3 inches of rainfall annually. Maximum daily air temperature averages 91 degrees Fahrenheit during the summer months. In the winter, it averages 57 degrees Fahrenheit.

**Figure 3-2. 30-Year Normals, Precipitation and Maximum Daily Air Temperature**



Based on data from the Oregon State PRISM dataset for 1895–2024, annual rainfall varies considerably from year to year, as is typical across much of California. The standard deviation of annual rainfall is 6.5 inches—about 34 percent of the long-term average. Multi-year periods of below-average rainfall are common: since 1895, there have been ten episodes lasting three or more consecutive years and two episodes lasting five or more years. The last five year dry spell started in 1987 and ended in 1991. Despite the high variability, there is no statistically significant long-term trend in average annual rainfall, and the variance of annual rainfall has remained stable.

In contrast, temperatures in the District have been steadily warming. Since 1895, the average daily temperature has increased at a rate of approximately 0.002 degrees Fahrenheit per year. Mean annual temperature for the 2015–2024 period was 2.1 degrees Fahrenheit higher than for the corresponding 10-year period a century earlier. Although temperatures have risen, the variance in annual temperatures has remained stable over time.<sup>6</sup>

### 3.4 Service Area Population and Demographics

The Dixon District estimates that its service area population was 9,394 in 2025.

<sup>6</sup> Because annual temperature exhibits a statistically significant upward trend, it is necessary to apply variance stability tests to the detrended temperature series. This ensures that the test evaluates stability in the variance around the trend, rather than confounding shifts in the mean with changes in variability.

Population estimates are developed using U.S. Census Block population counts from the decennial Census. These counts are converted to average population per single-family and multi-family service, which are then applied to annual service counts for the years between decennial censuses. This approach is similar to the method used in the California Department of Water Resources (DWR) Population Tool, and comparisons between the two methods show that resulting population estimates typically differ by less than one percent.<sup>7</sup>

Current and projected service area populations are shown in **Table 3-1**. Projected population is based on historical growth of residential services over the previous five years. Although new development is occurring within the City of Dixon, this development is taking place outside of the District's service area. Minimal growth is projected within the District's service boundary, as this part of the City of Dixon is already largely built out. Between 2025 and 2050, the District service area population is projected to grow at an average rate of approximately 0.2 percent per year.

**Table 3-1. Population – Current and Projected (DWR Table 3-1)**

Population Served	2025	2030	2035	2040	2045	2050
	9,394	9,489	9,584	9,680	9,777	9,876

Demographics for the City of Dixon are summarized in **Table 3-2**. These data are from the U.S. Census American Community Survey 2023 5-Year Estimates. Relative to the rest of California, the City of Dixon's population is younger and more racially homogenous. Educational attainment in the City of Dixon is lower than for California overall, while median household income is slightly higher.

The City of Dixon's stock of housing is significantly newer than for California as a whole. Approximately 57 percent of homes in the City of Dixon were built before 1990 compared to 72 percent for all of California. Homes built after 1990 are more likely to have plumbing fixtures that are compliant with state and federal water and energy efficiency standards.

<sup>7</sup> California Water Service, 2016. 2015 Urban Water Management Plan: Dixon District, dated June 2016.

**Table 3-2. Demographic and Housing Characteristics**

<b>Demographics</b>	<b>City of Dixon</b>	<b>California</b>
Median Age (years)	34.2	37.6
Racial Makeup (%)		
White	62.8	38.1
Black or African American	1.5	5.4
American Indian and Alaska Native	0.2	1.4
Asian	3.5	16.1
Native Hawaiian	0.1	0.4
Some other race	17.1	18.9
More than two races	14.9	19.8
Hispanic or Latino (of any race) (%)	43.6	40.8
Educational Attainment (%)		
Bachelor's Degree or Higher	24.3	36.5
Primary Language Spoken at Home (%)		
English Only	84.9	82.7
Limited English-Speaking Households	15.1	17.3
Median Household Income (\$)	98,798	96,334
Population below Federal Poverty Level (%)	8.4	12.0
<b>Housing</b>	<b>City of Dixon</b>	<b>California</b>
Median Year Built	1985	1976
Year Housing Built (%)		
2010 or Later	7.3	6.9
2000 to 2009	15.1	11.1
1990 to 1999	20.8	10.3
Before 1990	56.8	71.6

### 3.5 Land Uses within Service Area

Current land uses within the Dixon District are a mixture of low, medium, and high density residential, mixed use, commercial, public facilities, and parks/open space. Maps showing

General Plan land use designations for communities served by the District are provided in **Appendix D**.

The District's population and service growth projections are tied to historical growth of residential services over the previous five years. Although new development is occurring within the City of Dixon, this development is taking place outside of the District's service area. Within the District's service boundary, the City of Dixon is largely built out, and future growth is expected to be minimal. For the purposes of this plan, population and new single-family services are projected to increase at two-thirds the rate of increase occurring from 2020 to 2025. Growth in services for other classes of service is not expected.



## Chapter 4

### Water Use Characterization

This chapter provides a description and quantifies the California Water Service (Cal Water) Dixon District's (also referred to herein as the "District") past, current, and projected water uses through 2050. For the purposes of the Urban Water Management Plan (UWMP or Plan), the terms "water use" and "water demand" are used interchangeably. This chapter is divided into the following subsections:

- 4.1 Non-Potable Versus Potable Water Use
- 4.2 Past, Current, and Projected Water Uses by Sector
- 4.3 Distribution System Water Loss
- 4.4 Climate Change Considerations
- 4.5 Coordinating Water Use Projections

**Appendix E** provides additional information and data related to the development of the water demand projections presented in this chapter.

#### 4.1 Non-Potable Versus Potable Water Use

Potable and non-potable water uses are accounted for separately herein. Potable uses are served by the District's potable water delivery system. Potable water deliveries comply with Title 22 Drinking Water Standards. Non-potable water uses include recycled and untreated raw water deliveries, such as tertiary treated recycled water or surface or groundwater supplies that do not meet potable drinking water standards. Uses of potable versus non-potable water are clearly distinguished in the tables included in this chapter.

## 4.2 Past, Current, and Projected Water Uses by Sector

**CWC § 10631 (d) (1)** A plan shall be adopted in accordance with this chapter that shall do all of the following:

*(d)(1) For an urban retail water supplier, quantify, to the extent records are available, past and current water use, over the same five-year increments described in subdivision (a), and projected water use, based upon information developed pursuant to subdivision (a), identifying the uses among water use sectors, including, but not necessarily limited to, all of the following:*

*(A) Single-family residential.*

*(B) Multifamily.*

*(C) Commercial.*

*(D) Industrial.*

*(E) Institutional and governmental.*

*(F) Landscape.*

*(G) Sales to other agencies.*

*(H) Saline water intrusion barriers, groundwater recharge, or conjunctive use, or any combination thereof.*

*(I) Agricultural.*

*(J) Distribution system water loss (d)(2) The water use projections shall be in the same five-year increments described in subdivision (a).*

*(d)(4)(A) Water use projections, where available, shall display and account for the water savings estimated to result from adopted codes, standards, ordinances, or transportation and land use plans identified by the urban water supplier, as applicable to the service area.*

*(d)(4)(B) To the extent that an urban water supplier reports the information described in subparagraph (A), an urban water supplier shall do both of the following: (i) Provide citations of the various codes, standards, ordinances, or transportation and land use plans utilized in making the projections. (ii) Indicate the extent that the water use projections consider savings from codes, standards, ordinances, or transportation and land use plans. Water use projections that do not account for these water savings shall be noted of that fact.*

Demand within the District's water service area is measured using water meters that are installed at each customer service connection. Demand within the water service area is tracked and reported for the following sectors:

- **Single Family Residential:** Attached or detached dwelling units that are individually metered.

- **Multi-Family Residential:** Three or more dwelling units served by a common water meter.
- **Commercial:** Private enterprise customers other than large industrial customers.
- **Institutional/Governmental:** Institutional and governmental entities such as schools, administrative buildings, and publicly owned parks and landscaping.
- **Industrial:** Large industrial sites and water use.
- **Landscape:** Water meters classified exclusively for outdoor landscape irrigation.
- **Other:** Includes temporary meters, and miscellaneous customers not listed elsewhere.
- **Fire Service:** Water meters used for fire suppression or system maintenance. These meters typically do not have billed consumption.

Water use categories described in CWC §10631(d)(1)(G) through (I)—listed below—were not included in the District’s water demand calculations because they do not apply to the system:

- Sales to other agencies;
- Sales for agricultural irrigation; and,
- Saline water intrusion barriers, groundwater recharge, or conjunctive use, or any combination thereof.

#### 4.2.1 Past and Current Water Use

##### **CWC §10631**

*(d)(1) For an urban retail water supplier, quantify, to the extent records are available, past and current water use... based upon information developed pursuant to subdivision (a), identifying the uses among water use sectors...*

**Table 4-1** and **Figure 4-1** show the District’s water uses from 2021 through 2025 in acre-feet (AF). Total demand in 2025 was 1,238 AF. Residential customers constitute the majority of the District’s service connections but only account for 64 percent of total water use. Non-residential demands represent about 8.0 percent, while distribution system losses account for the remaining amount. The District does not currently serve recycled water. Discussion of potential future use of recycled water is provided in Section 6.5.

Per capita water use in the District has declined steadily since the mid-2000s. Between 2000 and 2025, per capita water use per person decreased by 26 percent (**Figure 4-2**), falling from 159 gallons per capita per day (GPCD) to 118 GPCD. During this period, total demand dropped by approximately 400 AF—going from 1,669 AF in 2000 to 1,238 AF today.


Several factors have contributed to this long-term reduction in per capita water use. Tiered residential pricing was adopted in 2009, strengthening incentives for efficient household water use. Additionally, beginning in 2012, Cal Water tripled conservation program expenditures, expanding customer access to tools and resources that support water-use efficiency. Lastly, state and federal efficiency standards have significantly reduced water use from toilets, showers, clothes washers, and other plumbing fixtures.

Collectively, these actions have resulted in a sustained reduction in water use across the service area. These trends are expected to continue and are incorporated into the demand projections presented in the next section.


**Table 4-1. Uses for Potable and Non-Potable Water – Actual (DWR Table 4-1)**

Use Type	Additional Description (as needed)	Level of Treatment When Delivered (OPTIONAL)	Historical Water Use				
			2021	2022	2023	2024	2025
			(AF)	(AF)	(AF)	(AF)	(AF)
Single Family		Potable	850	763	715	744	713
Multi-Family		Potable	89	97	83	85	74
Commercial		Potable	80	71	70	72	65
Institutional		Potable	24	27	24	34	31
Industrial		Potable	0	0	0	0	0
Landscape		Potable	1	1	1	0	1
Other		Potable	0	0	0	0	0
Losses	(a)	Potable	266	279	383	402	354
Subtotal Potable			1,311	1,238	1,276	1,337	1,238
Subtotal Non-Potable			0	0	0	0	0
<b>Total</b>			1,311	1,238	1,276	1,337	1,238
<b>Notes:</b>							
(a) Sum of potable real and apparent losses and authorized unbilled consumption from water loss reports.							
(b) The total demand in DWR Table 4-1, volume supplied in DWR Table 2-1, total groundwater pumped in DWR Table 6-1, and total supply in DWR Table 6-8 may not be equal due to estimations of water loss based on historical state-reported water loss values.							

**Figure 4-1. Annual Total Water Demand by Sector**



**Figure 4-2. Annual Per Capita Water Use**



#### 4.2.2 Projected Water Use

**Table 4-2** and **Figure 4-3** show projected water uses in five-year increments through 2050. Future water uses are projected by combining forecasts of future water services with forecasts of expected water use per service. The forecasts of future services are aligned with the population, housing, and employment forecasts described in Section 3.4. Separate growth rates were developed for residential and non-residential services based on these regional projections. Between 2025 and 2050, the total number of services is expected to increase from approximately 3,100 to more than 3,200, a rate of growth generally consistent with the projected increase in service area population.

Baseline forecasts of expected use per service are calibrated to average usage for the previous three years. The baseline forecasts are then adjusted over the forecast period for expected changes in usage associated with:

1. **Passive water savings** that are primarily driven by plumbing codes and appliance standards that affect both the turnover of existing appliances and fixtures and the installation of new ones.
2. **Active water savings** that are driven by the continued implementation of District conservation programs.
3. **Behavioral responses to higher water service costs** that are driven by customer responsiveness to changes in marginal water prices and projected increases in water service costs over the forecast period.
4. **Water loss standards compliance** that is translated into a reduction in expected loss per service connection (see **Table 4-6**).

These adjustments are described in greater detail in the next section.

Despite projected population growth, total demand is projected to remain essentially unchanged or decline over the forecast period, primarily due to projected reductions in distribution system water loss. As shown in **Table 4-2**, per capita demand is projected to continue declining, though at a more gradual pace than in previous decades, as many of the most accessible conservation opportunities—such as metering—have already been realized.


**Table 4-2. Use for Potable and Non-Potable Water – Projected (DWR Table 4-2)**

Use Type	Additional Description (as needed)	Level of Treatment When Delivered (OPTIONAL)	Projected Water Use				
			2030	2035	2040	2045	2050
			(AF)	(AF)	(AF)	(AF)	(AF)
Single Family		Potable	686	659	642	630	618
Multi-Family		Potable	76	73	70	69	67
Commercial		Potable	63	59	55	52	49
Institutional		Potable	28	26	24	23	21
Industrial		Potable	0	0	0	0	0
Landscape		Potable	1	1	1	1	1
Other		Potable	0	0	0	0	0
Losses	(a)	Potable	228	230	233	235	237
Subtotal Potable			1,082	1,048	1,025	1,008	993
Subtotal Non-Potable			0	0	0	0	0
<b>Total</b>			<b>1,082</b>	<b>1,048</b>	<b>1,025</b>	<b>1,008</b>	<b>993</b>


**Notes:**

(a) Sum of potable real and apparent losses and authorized unbilled consumption. Assumes compliance with state water loss standards by 2028.

**Figure 4-3. Projected Annual Water Demand by Sector**



**Figure 4-4. Projected Per Capita Water Use**



4.2.3 Adjustments to Projected Water Uses

As noted in the previous section, four adjustments were made to projected water usage:

1. **Passive water savings** from plumbing codes and appliance standards.
2. **Active water savings** from implementation of the District’s conservation programs.
3. **Behavioral responses to higher water service cost.**
4. **Water loss standards compliance.**

This section describes the data and methods underlying these adjustments as well as their relative magnitudes.

**Table 4-3. Inclusion in Water Use Projections (DWR Table 4-3)**

<b>Are Future Water Savings Included in Projections?</b>	Yes
If "Yes" to above: State the section or page number, in the cell to the right, where citations of the codes, ordinances, or otherwise are utilized in demand projections are found.	Section 4.2.3
<b>Are Lower Income Residential Demands Included in Projections?</b>	Yes
<b>OPTIONAL</b> If the method for accounting Lower Income Residential Demands has been included, provide page number where this accounting can be found.	See notes
<p><b>Notes:</b></p> <p>(a) All District residential customers, regardless of income level, are metered and thus the demands of residential customers with lower incomes are fully included in the single- and multi-family water uses shown in DWR Table 4-2.</p>	

(1) Passive Water Savings Adjustment

**CWC §10631(d)(4)**

*(A) Water use projections, where available, shall display and account for the water savings estimated to result from adopted codes, standards, ordinances, or transportation and land use plans identified by the urban water supplier, as applicable to the service area.*

*(B) To the extent that an urban water supplier reports the information described in subparagraph (A), an urban water supplier shall do both of the following:*

*(i) Provide citations of the various codes, standards, ordinances, or transportation and land use plans utilized in making the projections.*

*(ii) Indicate the extent that the water use projections consider savings from codes, standards, ordinances, or transportation and land use plans. Water use projections that do not account for these water savings shall be noted of that fact.*

The passive water savings adjustments reflect the effects of the following codes and regulations:

- **Assembly Bill (AB) 715 (2007)** requires that any toilet or urinal sold or installed in California on or after January 1, 2014, must not exceed flush ratings of 1.28 gallons per flush (gpf) for toilets and 0.5 gpf for urinals. These standards superseded the earlier 1991 limits of 1.6 and 1.0 gpf, respectively. In response to the Governor’s Emergency Drought Response Executive Order B-29-15, the California Energy Commission adopted new urinal standards in April 2015, reducing allowable use to 0.125 gpf—75 percent lower than the AB 715 standard.
- **California Appliance Efficiency Regulations (California Code of Regulations [CCR], Title 20, Sections 1601-1609)** set a two-tier standard for showerheads: a maximum flow rate

of 2.0 gallons per minute (gpm) for models manufactured on or after July 1, 2016, and a maximum flow rate of 1.8 gpm for models manufactured on or after July 1, 2018.

- **Federal appliance water efficiency standards** for residential and commercial clothes washers and dishwashers are established by the U.S. Department of Energy under the Energy Policy and Conservation Act.
- **CALGreen Building Code** requirements apply to new construction and renovations in California. CALGreen includes prescriptive indoor standards limiting water consumption of plumbing fixtures and fittings, as well as an optional performance path requiring a 20 percent reduction in indoor water use relative to a calculated baseline using CALGreen worksheets.
- **Senate Bill (SB) 407 (2009)** mandates that all buildings constructed on or before January 1, 1994, retrofit noncompliant plumbing fixtures to meet current state efficiency standards. The law also requires sellers of single-family homes, effective January 1, 2017, to disclose in writing whether required plumbing fixture replacements have been completed. Similar disclosure requirements for multi-family and commercial properties took effect January 1, 2019. **SB 837 (2011)** reinforced these requirements by adding corresponding disclosure elements to the statutory property transfer disclosure statement.
- **Model Water Efficient Landscape Ordinance (MWELO)** was updated by the California Water Commission in 2015. MWELO (or a locally adopted equivalent) limits water use for new and rehabilitated landscapes. Under MWELO, the maximum applied water allowance (MAWA) is set at 55 percent of reference evapotranspiration for residential landscapes and 45 percent for commercial landscapes, with exceptions for special uses such as sports fields, parks, or landscapes irrigated with recycled water.

Passive water savings adjustments were estimated using the Alliance for Water Efficiency's *Water Conservation Tracking Tool* (AWE Tracking Tool), a quantitative model widely used by water utilities to assess both active and passive water savings.

## (2) Active Savings Adjustment

Active savings refer to water savings resulting from the District's implementation of water conservation programs, customer education efforts, and the provision of financial incentives (e.g., rebates). The active savings adjustment assumes continuation of the District's current conservation programs at implementation levels consistent with conservation program funding authorized by the California Public Utilities Commission (CPUC) in Cal Water's most recent General Rate Case.

A description of the District's existing and planned conservation programs, also referred to as Demand Management Measures (DMMs), is provided in Chapter 9. Projected compliance with state urban water conservation regulations is addressed in Chapter 5.

As with passive savings, the cumulative effects of these programs on future water demand were estimated using the AWE Tracking Tool.

### (3) Customer Price Response Adjustment

The AWE Tracking Tool was also used to calculate customer price response adjustments. The adjustment assumes a sustained 1.0 percent annual rate of increase above general price inflation in the marginal cost of water service.

The AWE Tracking Tool's default demand elasticities were used to adjust baseline demands over the forecast period in response to the real increases in marginal water service costs. The demand elasticities estimate the expected percentage change in water use given a 1.0 percent inflation-adjusted increase in marginal water cost. For example, an elasticity of -0.1 implies that demand will decrease, on average, by 0.1 percent given a 1.0 percent increase in marginal water cost.

The default elasticities used by the tracking tool are as follows:

- Single-Family: -0.15
- Multi-Family: -0.075
- CII: -0.15
- Irrigation: -0.25

Because higher water service cost encourages conservation program participation, the AWE Tracking Tool's default elasticities are purposely conservative (i.e., small in magnitude) in order to reduce the likelihood of double counting water savings.

### (4) Water Loss Standards Compliance

The water loss standards compliance adjustment is based on the difference between average real and apparent water loss, as reported in the District's most recent three water loss reports (see **Table 4-5**), and the corresponding standards. Real and apparent water use per service is reduced by these differences in 2028, the deadline for compliance with the standards, if the average loss rates exceed their standards.

### (5) Summary of Demand Adjustments

**Table 4-4** and **Figure 4-5** show the impact of the demand adjustments on projected water use. In total, the adjustments reduce projected 2050 water use by 24 percent relative to the baseline forecast. Most of the reduction is associated with reductions in distribution system water loss


(42 percent), followed by passive water savings (30 percent), active water savings (21 percent), then water service cost (8 percent).

**Table 4-4. Projected Baseline and Adjusted Potable Water Demand**

Water Conservation Type	Projected Potable Water Demand				
	2030	2035	2040	2045	2050
	(AF)	(AF)	(AF)	(AF)	(AF)
Baseline Potable Water Demand	1,265	1,276	1,286	1,297	1,308
<b>Demand Adjustments</b>					
Passive Conservation	28	49	66	80	94
Active Conservation	23	40	51	58	65
Water Service Cost (a)	6	11	16	21	25
Water Loss Standards Compliance (b)	126	127	128	130	131
Subtotal Adjustments	183	227	261	289	315
Projected Potable Demand	1,082	1,048	1,025	1,008	993

**Notes:**  
 (a) Water cost adjustments incorporate adjustments for increases in both income and price. Negative water service cost adjustments indicate the increase in demand because of increased income is greater than the reduction in demand because of increased price of water.  
 (b) Compliance with loss standards by 2028 is assumed. No reported adjustment indicates current losses per connection are below the District's standards for real and apparent water loss.

**Figure 4-5. Projected Potable Water Demand and Conservation**



### 4.3 Distribution System Water Loss

**CWC § 10631 (3)**

(A) The distribution system water loss shall be quantified for each of the five years preceding the plan update, in accordance with rules adopted pursuant to Section 10608.34.

(B) The distribution system water loss quantification shall be reported in accordance with a worksheet approved or developed by the department through a public process. The water loss quantification worksheet shall be based on the water system balance methodology developed by the American Water Works Association.

(C) In the plan due July 1, 2021, and in each update thereafter, data shall be included to show whether the urban retail water supplier met the distribution loss standards enacted by the board pursuant to Section 10608.34.

#### 4.3.1 Previous Five Years Distribution System Losses

Since 2016, urban retail water suppliers have been required under California Water Code (CWC) §10608.34 and CCR §638.1 et seq to quantify distribution system water losses using the American Water Works Association (AWWA) Free Water Audit Software (referred to as “water loss audit reports”). **Table 4-5** summarizes the water loss audit reports submitted to DWR since 2021.

**Table 4-5. Water Loss Audit Reporting (DWR Table 4-5)**

Public Water System ID # Reported in Table 2-1 R	Reporting Period	Submitted to DWR Water Loss Audit Program (yes/no)
CA4810002	2021	Yes
	2022	Yes
	2023	Yes
	2024	Yes
	2025	(see notes)
<b>Notes:</b>		
(a) Submitted water loss reports are available at: <a href="https://wuedata.water.ca.gov/">https://wuedata.water.ca.gov/</a>		
(b) 2025 water loss audit reports are not due until January 1, 2027, after the July 2026 UWMP filing deadline.		

#### 4.3.2 Progress Toward Meeting the Water Loss Performance Standard

In 2022, the State Water Resources Control Board (SWRCB) adopted new performance standards for urban retail water suppliers that would reduce water loss by nearly 35 percent. Effective starting in 2023, the SWRCB provided a volumetric standard to each urban retail water supplier that sets cost-effective levels of achievable water loss given each water system’s characteristics and budgets. Suppliers will be required to start meeting individual volumetric loss standards over

a three-year period beginning January 2028. This water loss standard is one component of the Making Conservation a California Way of Life (MCCWL) regulation.<sup>8</sup>

CWC §10631 (3)(c) requires that this UWMP demonstrate whether the distribution loss standards enacted by the SWRCB pursuant to CWC §10608.34 have been met. **Table 4-6** shows that the current real water loss rate for PWS CA4810002 (Dixon) exceeds the real loss standard established by the SWRCB while its current apparent loss rate is below the corresponding standard. Additionally, the three-year average (2022-2024) real loss rate also currently exceeds the standard. The District is implementing water loss management programs and aims to reach compliance by the 2028 deadline.

---

<sup>8</sup> SWRCB, 2025. Making Conservation a California Way of Life, dated January 2025. Accessed From: [https://www.waterboards.ca.gov/conservation/regs/water\\_efficiency\\_legislation.html](https://www.waterboards.ca.gov/conservation/regs/water_efficiency_legislation.html).

**Table 4-6. Progress Towards 2028 Water Loss Standards (DWR Table 4-6)**

Public Water System ID #	Did the Water Board Calculate a Water Loss Standard for this Public Water System? (y/n) If no, Supplier will not complete this row.	Real Water Loss					Apparent Water Loss				
		State Water Board Standard		Most Recent AWWA Water Loss Audit			State Water Board Standard		Most Recent AWWA Water Loss Audit		
		2028 Real Water Loss Standard (a)	Units for Real Water Loss (b)	Number of Services	Volume of Real Loss (c)	Real Water Loss Per Unit per Day	2028 Apparent Water Loss Standard (a)	Units for Apparent Water Loss (b)	Number of Services	Volume of Apparent Loss (c)	Apparent Water Loss Per Unit per Day
CA4810002	Yes	45.4	GPSCD	3,149	332	94.0	7.7	GPSCD	3,149	24	6.7

**Notes:**  
 (a) Provided by State Water Resources Control Board (SWRCB).  
 (b) GPSCD = Gallons per service connection per day.  
 (c) Result from most recent validated AWWA water loss report.

## 4.4 Climate Change Considerations

*It is the intention of the Legislature, in enacting this part, to permit levels of water management planning commensurate with the numbers of customers served and the volume of water supplied, while accounting for impacts from climate change.*

**CWC §10635(b)**

*(b) Every urban water supplier shall include, as part of its urban water management plan, a drought risk assessment ...(and) shall include each of the following ...*

*(4) Considerations of the historical drought hydrology, plausible changes on projected supplies and demands under climate change conditions, anticipated regulatory changes, and other locally applicable criteria.*

As discussed in Section 3.3, the District's climate has been warming. Changing climate can affect water demands, as extreme and higher temperatures can lead to increases in water use. At the same time, adaptive behavior by water users, such as replacing existing landscape with more drought-tolerant landscape material, may partially offset these effects. Pursuant to the CWC requirements and the 2025 UWMP Guidebook, this Plan incorporates climate change considerations into the water demand projections provided in this section.

For many years, Cal Water has focused on identifying and assessing climate-related risks and opportunities. Cal Water's initial evaluations in 2016 and 2020 formed the foundation for the Climate Change Risk Assessment and Adaptation Framework (Climate Assessment) which was completed in 2021. This Climate Assessment considered climate-related risks and opportunities over three distinct time horizons:

- The early-century horizon (2020-2049) includes near-term vulnerabilities and adaptation measures to consider for implementation.
- The mid-century horizon (2035-2064) covers longer-term investments, such as new facilities constructed after the lifespan of the current infrastructure.
- The late-century horizon (2070-2099) evaluates long-term adaptation pathways.

Climate projections for each time horizon were averaged to account for natural climate variability across shorter periods. Cal Water also followed guidance from the Task Force on Climate-related Financial Disclosures (TCFD) and the Intergovernmental Panel on Climate Change (IPCC) to leverage Representative Concentration Pathways (RCPs) for a range of possible climate futures. RCPs show trajectories of atmospheric Green House Gas (GHG) concentrations for different timeframes and emission levels. Based on the findings from our foundational work and the associated literature review, the following RCPs were selected for risk analysis:

RCP 4.5 is an intermediate scenario that assumes an estimated global temperature rise between 2.0 degrees Celsius and 3.0 degrees Celsius from pre-industrial levels by 2100, with anthropogenic GHG emissions peaking in 2040.

RCP 8.5 is a high-emissions scenario that assumes temperature increases of at least 4.0 degrees Celsius from pre-industrial levels by 2100, with anthropogenic GHG emissions continuing to rise over the next century.

Although RCP 2.6 is the lower bound of the RCP scenarios adopted by the IPCC, Cal Water selected RCP 4.5, since Cal Water believes it to be a more realistic potential lower bound, because achieving RCP 2.6 requires significant actions at a global scale. The California Fourth Climate Assessment also identified RCP 4.5 and RCP 8.5, which are consistent with planning models that Shortage Level agencies use.

The Climate Assessment also identifies and prioritizes climate-driven risks to future water supply availability and critical operations and assets, projects and assesses supply of and demand for water, and identifies primary risks to Cal Water's operations.

The Climate Assessment provides actionable insights and a reliable framework for future planning. Using this framework, Cal Water intends to continue implementing programs that capitalize on these adaptation strategies.

The Executive Summaries from the 2016 and 2020 foundational work, and the Climate Assessment, can be found in **Appendix F**.

#### 4.4.1 Characteristic Five-Year Water Use

##### **CWC § 10635(b)(3)**

*(b) Every urban water supplier shall include, as part of its urban water management plan, a drought risk assessment for its water service to its customers as part of information considered in developing the demand management measures and water supply projects and programs to be included in the urban water management plan. The urban water supplier may conduct an interim update or updates to this drought risk assessment within the five-year cycle of its urban water management plan update. The drought risk assessment shall include each of the following...*

*(3) A comparison of the total water supply sources available to the water supplier with **the total projected water use for the drought period**. (Emphasis added).*

In accordance with CWC §10635(b)(3), UWMPs must provide a five-year Drought Risk Assessment (see Section 7.5). As a first step, DWR suggests that water suppliers estimate their unconstrained water demand for the next five years (2026-2030). Unconstrained water demand is water use in the absence of drought water use restrictions. These numbers can then be

adjusted to estimate the five-years' cumulative drought effects. The Drought Risk Assessment presented in Section 7.5 incorporates adjustments to unconstrained water demand in accordance with the District's Water Shortage Contingency Plan (WSCP).

As part of the sales forecasting process for General Rate Cases before the California Public Utilities Commission (CPUC), Cal Water conducts econometric modeling to evaluate the sensitivity of water sales to variations in weather conditions. These models were used to simulate differences in projected water use under normal weather conditions and under multiple dry-year scenarios. For this analysis, historical weather data from the dry periods of 1929–1934, 1987–1991, and 2013–2016 were applied.

The results indicate that the District's annual water use under a multiple dry-year scenario would increase by approximately 7 percent relative to normal conditions. This relatively large increase reflects the sensitivity of District demands to climate variability, particularly in spring and autumn transitional irrigation periods.

Projected unconstrained demands for 2026-2030 for normal and multiple-dry-year scenarios are provided in **Table 4-7**.

**Table 4-7. Characteristic Five-Year Water Use for Normal and Multi-Year Dry Scenarios**

Water Year Type	2026	2027	2028	2029	2030
	(AF)	(AF)	(AF)	(AF)	(AF)
Normal	1,248	1,238	1,100	1,091	1,082
Multi-Year Dry	1,330	1,319	1,172	1,163	1,153

## 4.5 Coordinating Water Use Projections

### CWC §10631

*(h) An urban water supplier that relies upon a wholesale agency for a source of water shall provide the wholesale agency with water use projections from that agency for that source of water in five-year increments to 20 years or as far as data is available. The wholesale agency shall provide information to the urban water supplier for inclusion in the urban water supplier's plan that identifies and quantifies, to the extent practicable, the existing and planned sources of water as required by subdivision (b), available from the wholesale agency to the urban water supplier over the same five-year increments, and during various water-year types in accordance with subdivision.*

As described in Chapter 6, the Dixon District currently does not rely upon a wholesale agency for source water. Consequently, this section of the UWMP Act does not apply to the District.

## Chapter 5

### SB X7-7 Baseline, 2020 Target and 2025 Reporting

Senate Bill (SB) X7-7 mandated a 20 percent reduction in urban per capita water use across California by 2020. To achieve this goal, SB X7-7 required each retail supplier to establish an urban water use target (2020 Target), contributing to the State’s collective efforts. Because the California Water Code (CWC) does not set an end date for reporting progress in meeting the 2020 Target, this section of the Urban Water Management Plan (UWMP or Plan) demonstrates the California Water Service (Cal Water) Dixon District’s (also referred to herein as the “District”) compliance with SB X7-7 in 2020.

This chapter has the following sections:

5.1 Demonstration of Compliance with the 2020 Target in 2020

5.2 Nexus to State Water Board Urban Water Use Objectives

#### 5.1 Demonstration of Compliance with the 2020 Target in 2020

**CWC §10608.40**

*Urban water retail suppliers shall report to the department on their progress in meeting their urban water use targets as part of their urban water management plans submitted pursuant to Section 10631.*

**CWC §10608.12**

*(af) “Urban retail water supplier” means a water supplier, either publicly or privately owned, that directly provides potable municipal water to more than 3,000 end users or that supplies more than 3,000 acre-feet of potable water annually at retail for municipal purposes.*

The Dixon District achieved its 2020 Target in 2020. The data used to calculate the 2020 Target and demonstrate compliance are documented in the District’s 2020 UWMP. **Table 5-1** below summarizes the District’s 2020 Target and actual 2020 gallons per capita per day (GPCD), confirming that it met the SB X7-7 compliance requirements.

**Table 5-1. SB X7-7 2020 Target Progress (DWR Table 5-1)**

<input type="checkbox"/>	Check the box if the Supplier was not an Urban Water Supplier during or before the 2020 UWMP reporting cycle. Proceed to the next table.					
Was Supplier part of a merger or consolidation since 2020?	Regional Alliance Target or Individual Target?	2020 Target	Actual 2020 GPCD	Did Supplier achieve targeted reduction for 2020?	Only for suppliers that did not meet the Target in 2020	
					Actual 2025 GPCD (From SB X7-7 Compliance Form)	Did Supplier meet the 2020 Target in 2025?
No	Individual Target	161	119	Yes		N/A

## 5.2 Nexus to State Water Board Urban Water Use Objectives

### **CWC § 10609.20**

*(a) Each urban retail water supplier shall calculate its urban water use objective no later than January 1, 2024, and by January 1 every year thereafter.*

*(b) The calculation shall be based on the urban retail water supplier's water use conditions for the previous calendar or fiscal year.*

### **CWC § 10609.22**

*(a) An urban retail water supplier shall calculate its actual urban water use no later than January 1, 2024, and by January 1 every year thereafter.*

*(b) The calculation shall be based on the urban retail water supplier's water use for the previous calendar or fiscal year.*

### **CWC § 10609.24**

*(a) An urban retail water supplier shall submit a report to the department no later than January 1, 2024, and by January 1 every year thereafter. The report shall include all of the following:*

*(1) The urban water use objective calculated pursuant to Section 10609.20 along with relevant supporting data.*

*(2) The actual urban water use calculated pursuant to Section 10609.22 along with relevant supporting data.*

*(3) Documentation of the implementation of the performance measures for CII water use.*

*(4) A description of the progress made towards meeting the urban water use objective.*

*(5) The validated water loss audit report conducted pursuant to Section 10608.34.*

*(b) The department shall post the reports and information on its internet website.*

*(c) The board may issue an information order or conservation order to, or impose civil liability on, an entity or individual for failure to submit a report required by this section.*

In July 2024, California adopted the Making Conservation a California Way of Life (MCCWL) regulation, implementing SB 606 and Assembly Bill (AB) 1668 to support long-term water conservation and drought resilience. The regulation establishes annual Urban Water Use Objectives (UWUOs) for urban retail water suppliers and introduces performance measures for commercial, industrial, and institutional (CII) water uses.

The UWUO is a water budget-based framework that is specific to each urban retail water supplier. It consists of the following components: (1) a residential indoor water use standard; (2)

a residential outdoor water budget; (3) a CII landscape outdoor water use standard for landscapes served by dedicated irrigation meters; (4) a water loss standard; (5) allowable variances; and (6) a potable reuse bonus. Beginning in 2027, suppliers must annually assess whether the sum of their regulated water uses—residential indoor and outdoor use, dedicated irrigation meter use, and distribution system water loss—is at or below their UWUO. Additionally, starting in 2028, they must demonstrate that real and apparent distribution system water loss rates are less than their corresponding standards, as discussed in Section 4.3.2. Compliance with the water loss standards is required even if the urban retail water supplier’s total regulated water use is below its UWUO.

The state standards underlying the residential indoor, residential outdoor, and CII outdoor components of the UWUO will become increasingly stringent over time. As a result, compliance is expected to require continued reductions in water use beyond those achieved under the SB X7-7 framework.<sup>9</sup> Urban retail water suppliers are required to report annually to the State Water Resources Control Board on water use relative to their UWUOs. The Dixon District submits UWUO compliance data through the Department of Water Resources’ Water Use Efficiency Data portal.<sup>10</sup>

Although projections of UWUO compliance are not required as part of an Urban Water Management Plan, they provide useful insight into the magnitude and timing of future conservation needs. For this reason, Cal Water has evaluated how projected regulated water use in the Dixon District compares to anticipated UWUO requirements over the planning horizon, with findings expressed as relative changes to baseline demand needed for compliance.

The assessment of future UWUO compliance for the Dixon District is predicated on levels of conservation that are currently authorized by the California Public Utilities Commission (CPUC), together with anticipated passive conservation savings. These passive savings include continued turnover of plumbing fixtures and appliances subject to state and federal efficiency standards and customer behavioral responses to conservation-oriented rate structures. The baseline demand projections described in Chapter 4 reflect these authorized active conservation programs and anticipated passive savings.

Under this baseline demand scenario, total regulated water use in the Dixon District is projected to remain below the applicable UWUO through around 2050. However, as discussed in Section 4.3, current water loss rates in the District exceed the water loss standards assigned by the state and must be reduced to the level of the standards by 2028 in order to comply with the water loss requirements of the MCCWL regulation.

---

<sup>9</sup> Under the MCCWL regulation, the SB X7-7 target serves as a backstop on the UWUO. If a supplier’s UWUO exceeds its SB X7-7 target, its UWUO becomes its SB X7-7 target.

<sup>10</sup> DWR’s Water Use Efficiency Data Portal: [https://wuedata.water.ca.gov/uwuo\\_plans](https://wuedata.water.ca.gov/uwuo_plans)

Based on this evaluation, real water losses will need to be reduced on the order of approximately 45 to 50 percent from current levels in order to achieve compliance with the state water loss standards.

Achieving these reductions in real water loss will depend on Cal Water's ability to implement water loss management programs in the District. For public utilities regulated by the CPUC, expansion of water loss management programs necessary to achieve reductions require CPUC authorization. Accordingly, future compliance with the water loss component of the MCCWL regulations for the District will depend on timely approval of expanded water loss management programs and related measures necessary to meet the state water loss standards.

Cal Water has requested authorization for additional conservation expenditures to support water loss management programs in the District in its 2024 General Rate Case. At the time this UWMP was prepared, a final decision in that proceeding had not yet been issued. As a result, it remains uncertain whether the requested level of funding needed to support compliance with state water loss requirements will be approved.



## Chapter 6

### Water Supply Characterization

**CWC § 10631 (b)** *A plan shall be adopted in accordance with this chapter that shall do all of the following:*

*Identify and quantify, to the extent practicable, the existing and planned sources of water available to the supplier over the same five-year increments described in subdivision (a).*

This chapter provides a description of the California Water Service (Cal Water) Dixon District's (also referred to herein as the "District") current water supplies, including a discussion of the underlying groundwater basin and its management, and potential supply sources, such as surface water, stormwater, and recycled water, as well as an assessment of the energy intensity used to operate the District treatment and distribution system. This chapter includes the following sections:

- 6.1 Purchased Water
- 6.2 Groundwater
- 6.3 Surface Water
- 6.4 Stormwater
- 6.5 Wastewater and Recycled Water
- 6.6 Desalinated Water Opportunities
- 6.7 Water Exchanges and Transfers
- 6.8 Future Water Projects
- 6.9 Summary of Existing and Planned Sources of Water
- 6.10 Special Conditions
- 6.11 Energy Intensity

## 6.1 Purchased Water

**CWC § 10631 (h)** A plan shall be adopted in accordance with this chapter and shall do all of the following:

*An urban water supplier that relies upon a wholesale agency for a source of water shall provide the wholesale agency with water use projections from that agency for that source of water in five-year increments to 20 years or as far as data is available. The wholesale agency shall provide information to the urban water supplier for inclusion in the urban water supplier's plan that identifies and quantifies, to the extent practicable, the existing and planned sources of water as required by subdivision (b), available from the wholesale agency to the urban water supplier over the same five-year increments, and during various water-year types in accordance with subdivision (f). An urban water supplier may rely upon water supply information provided by the wholesale agency in fulfilling the plan informational requirements of subdivisions (b) and (f).*

Cal Water does not currently purchase any imported water to meet demands in its Dixon District.

## 6.2 Groundwater

**CWC § 10631**

*(b) Identify and quantify, to the extent practicable, the existing and planned sources of water available to the supplier over the same five-year increments described in subdivision (a), providing supporting and related information, including all of the following:*

*(4) If groundwater is identified as an existing or planned source of water available to the supplier, all of the following information:*

*(A) The current version of any groundwater sustainability plan or alternative adopted pursuant to Part 2.74 (commencing with Section 10720), any groundwater management plan adopted by the urban water supplier, including plans adopted pursuant to Part 2.75 (commencing with Section 10750), or any other specific authorization for groundwater management for basins underlying the urban water supplier's service area.*

*(B) A description of any groundwater basin or basins from which the urban water supplier pumps groundwater. For basins that a court or the board has adjudicated the rights to pump groundwater, a copy of the order or decree adopted by the court or the board and a description of the amount of groundwater the urban water supplier has the legal right to pump under the order or decree. For a basin that has not been adjudicated, information as to whether the department has identified the basin as a high- or medium-priority basin in the most current official departmental bulletin that characterizes the condition of the groundwater basin, and a detailed description of the efforts being undertaken by the urban water supplier to coordinate with groundwater sustainability agencies or groundwater management agencies listed in subdivision (c) of Section 10723 to maintain or achieve sustainable groundwater conditions in accordance with a groundwater sustainability plan or alternative adopted pursuant to Part 2.74 (commencing with Section 10720).*

*(C) A detailed description and analysis of the location, amount, and sufficiency of groundwater pumped by the urban water supplier for the past five years. The description and analysis shall be based on information that is reasonably available, including, but not limited to, historic use records.*

Groundwater is the sole source of water supply for the Dixon District. This section includes information regarding the basin description, groundwater management, and Cal Water

coordination with the applicable Groundwater Sustainability Agencies (GSAs), followed by a discussion of historical pumping and supply sufficiency, which is further supported by Section 7.1.1.

### 6.2.1 Basin Description and Status

As shown on **Figure 6-1**, the District overlies the Solano Subbasin (also referred to herein as the “Basin”) of the Sacramento Valley Basin (California Department of Water Resources [DWR] Basin No. 5-021.66). The Solano Subbasin is not adjudicated and, in its recent evaluation of California groundwater basins, DWR determined that the Basin is not in a condition of critical overdraft.<sup>11</sup>

The Basin is designated as a medium priority basin under DWR’s 2019 Phase 2 Basin Prioritization.<sup>12</sup> Under this prioritization process, basins are ranked on eight components and if a basin is assigned more than 14 points, it is defined as “medium priority”. In the case of the Solano Subbasin, a total of 20.5 points were assigned, resulting in a designation as “medium priority”. The main factors driving the designation in the Basin include irrigated acreage per square mile (4 out of 5 possible points), population growth (4 out of 5 possible points), and total production well density (3 out of 5 possible points). Additional factors include groundwater reliance (2.5 out of 5 possible points), public supply well density (2 out of 5 possible points), and population density (1 out of 5 possible points).<sup>13</sup>

The Basin covers an area of approximately 354,673 acres (554 square miles) and is bounded on the north by Putah Creek, on the east by the Yolo County line and the Sacramento River, on the southeast by the North Mokelumne River, on the south by the San Joaquin River, on the northwest by the non-water bearing geologic units of the Great Valley Sequence, and on the southwest by the Suisun-Fairfield Valley Basin.<sup>14</sup>

---


<sup>11</sup> DWR, 2019. Sustainable Groundwater Management Act 2018 Basin Prioritization, State of California, dated January 2019.

<sup>12</sup> Ibid.

<sup>13</sup> DWR’s 2019 Phase 2 Basin Prioritization used the basin’s total possible ranking points assigned to each of the eight components to determine the priority. A basin is defined as medium priority if it has more than 14 total ranking points.

<sup>14</sup> Solano Collaborative, 2021. Solano Subbasin Groundwater Sustainability Plan, dated November 2021. Accessed From: <https://sgma.water.ca.gov/portal/gsp/preview/117>.

**Figure 6-1. Groundwater Basin Underlying the Dixon District**



Additional details on the Basin are given in the DWR Groundwater Bulletin 118, as well as in the key documents described below related to groundwater management of the Basin, which are incorporated into this UWMP by reference:

- The Basin’s Groundwater Sustainability Plan (GSP) was adopted by the Basin GSAs, submitted to DWR in January 2022, and approved by DWR in January 2024. The Basin’s GSP includes current groundwater conditions, hydrogeologic conceptual model, water budget, local sustainable management criteria, and the projects and management actions

(P/MAs) for reaching sustainability in the Basin by 2042. The GSP is available on the DWR Sustainable Groundwater Management Act (SGMA) Portal website:

<https://sgma.water.ca.gov/portal/gsp/preview/117>

- The Solano Irrigation District (SID) Groundwater Management Plan (GMP), including descriptions of geology and groundwater resources, historical management, and monitoring protocols is included as Appendix G of the Solano Irrigation District Water Management Plan located at the following web address:

<https://www.usbr.gov/mp/watershare/docs/2010/solano-id-final-plan2010cd.pdf>

- The Westside Sacramento Integrated Regional Water Management Plan (IRWMP), including detailed description of the Solano Subbasin hydrogeology, groundwater conditions, and groundwater monitoring practices, is available on the Westside Sacramento IRWMP website:

<https://westsideirwm.com/irwm-plan/>

## 6.2.2 Non-SGMA Groundwater Management

### Solano Irrigation District GMP

Prior to the passage of SGMA, the Basin was included in the Assembly Bill (AB) 3030 SID GMP. The SID GMP was adopted in 1995 and updated in 2006 in accordance with AB 3030 with the stated goal to “maintain a long term, sustainable, reliable supply of high-quality groundwater which will benefit the water supplies for all parties within the service area.”<sup>15</sup>

The GMP established four specific basin management objectives (BMOs) that describe necessary actions for meeting the goal and objectives set forward by the GMP. The four BMOs identified by the SID and stated in the GMP include: (1) monitor and manage groundwater levels that will result in a net benefit to groundwater users throughout the SID; (2) strive to maintain a reliable and consistent groundwater quality for the beneficial use of groundwater users in the SID; (3) strive to minimize the risk of future significant impacts from land surface subsidence; and (4) facilitate conjunctive use operations which will encourage the optimum beneficial use of water resources within SID. The Solano GSP supersedes the GMP as the groundwater management plan for the Basin.

### Westside Sacramento IRWMP

The most recent Westside Sacramento IRWMP was adopted in 2019. The 13 regional goals stated in the IRWMP include: (1) acknowledge and respect the cultural values and resources of the Westside Sacramento Region (Region), (2) improve education and awareness throughout the

---

<sup>15</sup> SID, 2006. Solano Irrigation District Groundwater Management Plan, dated January 2010. Accessed From: <https://www.usbr.gov/mp/watershare/docs/2010/solano-id-final-plan2010cd.pdf>.

Region about water, watershed functions, and ecosystems and the need for sustainable resource management to protect community health and well-being, (3) improve the collective understanding of watershed characteristics and functions (natural and human-induced) within the Region as needed to respond effectively to evolving water resources management challenges and opportunities (e.g., climate change), (4) improve the form and function of degraded natural channels, (5) improve water-related public health across the Region and emphasize improvements for populations most in need, (6) preserve and enhance water-related recreational opportunities, (7) preserve, improve, and manage water quality to meet designated beneficial uses for all water bodies within the Region, (8) promote reasonable use of water and watershed resources, (9) protect and enhance habitat and biological diversity of native and migratory species, (10) provide reliable water supplies of suitable quality for multiple beneficial uses (e.g., urban, agriculture, environmental, and recreation) within the Region, (11) reduce the risks of disruptive natural and human-caused disturbances affecting the Region's water resources, including flooding, fire, and significant institutional interruptions that reduce resources management services, (12) support improved regional water management through governance throughout the Region that uses science and collaboration to make fair and equitable decisions and investments, and (13) support sustainable economic activities consistent with local and state government planning efforts within the Region.<sup>16</sup>

### 6.2.3 SGMA Groundwater Management

In 2014, the California State Legislature enacted SGMA with subsequent amendments in 2015. Among other things, SGMA requires the formation of GSAs and the development and implementation of GSPs for groundwater basins that are designated by DWR as medium or high priority. As a medium priority, non-critically overdrafted and non-adjudicated basin, the Solano Subbasin is subject to the requirements of SGMA, including the requirement to be covered by one or more GSAs and to prepare and submit to DWR one or more GSPs by 31 January 2022.

Pursuant to SGMA, five GSAs were formed in the Basin – the Solano GSA, City of Vacaville GSA, Sacramento County GSA, SID GSA, and the Northern Delta GSA. Collectively the five GSAs formed the Solano Collaborative to develop a single GSP for the Basin.<sup>17</sup> The Solano Collaborative operates a GSA Advisory Group which consists of representatives from all Solano Subbasin GSAs and agricultural community representatives. The District has a Cal Water representative that serves on the Solano GSA Board of Directors, as well as a representative that serves on the Solano GSA Technical Advisory Committee. Additional discussion of the Solano Subbasin GSP as it relates to District supply is included in Sections 6.2.5 and 7.1.1. The Solano Collaborative submitted the

---

<sup>16</sup> Regional Water Management Group, 2019. Westside Sacramento Integrated Regional Water Management Plan Update, dated January 2019. Accessed From: <https://westsideirwm.com/irwm-plan/>.

<sup>17</sup> Solano Collaborative, 2021. Solano Subbasin Groundwater Sustainability Plan, dated November 2021. Accessed From: <https://sgma.water.ca.gov/portal/gsp/preview/117>.

GSP to DWR on 27 January 2022, and DWR approved the GSP on 18 January 2024. The District falls under the jurisdiction of the Solano Subbasin GSA.

Under SGMA, sustainable yield means “the maximum quantity of water, calculated over a base period representative of long-term conditions in a basin and including any temporary surplus, that can be withdrawn annually from a groundwater supply without causing undesirable results.”<sup>18</sup> Based on development and application of a numerical groundwater flow model for the Basin (Solano Integrated Hydrologic Model) the sustainable yield of the Basin is approximately 190,000 acre-feet per year (AFY) under 2070 climate change conditions. The Basin-level estimate was supplemented by local water budget information, but the local sustainable yield was not formally allocated in the GSP. Both the average historical groundwater pumping in the Basin (180,000 AFY) and the average projected groundwater pumping (170,000 AFY) are less than the sustainable yield estimate.<sup>19</sup>

The P/MAs to support achievement of the Basin’s sustainability goal under SGMA are proposed by the Solano Collaborative and documented in the GSP. The P/MAs in the GSP that include the District are briefly summarized below:

- The Solano Collaborative has implemented Municipal and Industrial Water Use Efficiency Outreach & Implementation Program. Although specifically focused on water conservation rebates and online educational resources offered by the Solano County Water Agency and an educational program offered by the Solano Resource Conservation District, this program aligns with and is supported by Cal Water’s own aggressive and comprehensive water conservation program (see Section 7.4).
- The Solano Collaborative plans may implement a Demand Management Program to “incentivize, enable, or possibly require water users to reduce their consumptive use” on an as-needed basis. The Solano Collaborative is not currently planning to implement the Demand Management Program.<sup>20</sup>
- Other groundwater management strategies – including the incentivization of recycled water use, development of in-lieu recharge programs, increased conjunctive management, or increased well regulation – may be considered and implemented on an as needed basis. Although the Solano Collaborative is not currently planning to implement any of these strategies, these strategies align with and are supported by Cal Water’s own

---

<sup>18</sup> California Water Code (CWC) §10721(w)

<sup>19</sup> Solano Collaborative, 2021. Solano Subbasin Groundwater Sustainability Plan, dated November 2021. Accessed From: <https://sgma.water.ca.gov/portal/gsp/preview/117>.

<sup>20</sup> Ibid.

recycled water development strategy (Section 6.5.4) and water quality monitoring program (Section 7.1.2).<sup>21</sup>

As reported in the Basin’s Annual Report for Water Year (WY) 2024, the Solano Collaborative has made progress towards implementing P/MAs since the release of GSP. For example, the Solano Collaborative is actively expanding the Municipal and Industrial Water Use Efficiency and Outreach Program, supported by a \$4.4 million SGMA Implementation Grant awarded in February 2024. Additional details regarding implementation of P/MAs within the Solano Subbasin are included in the Annual Report for WY 2024.<sup>22</sup>

#### 6.2.4 Cal Water Coordination with Groundwater Sustainability Agencies

Cal Water’s groundwater basin management philosophy is to engage collaboratively with all stakeholders in the basins where it operates, prioritizing the long-term sustainability of groundwater resources. Cal Water recognizes and deeply supports the goals, objectives, and intended outcomes of SGMA. Moreover, Cal Water recognizes the numerous challenges of implementing the legislation along a variety of technical, legal, political, and financial/economic dimensions, particularly when the geographical diversity of Cal Water’s service territory is considered. Nonetheless, Cal Water intends to take an active role in the local and state-wide management of groundwater resources by fully supporting and participating in the principal edicts of SGMA. A number of specific steps that Cal Water has taken with respect to this position and role include (among others):

- Coordination with public agencies and DWR, to ensure that Cal Water’s presence, rights and interests, as well as historical and current resource management concerns are honored/incorporated within the GSA and GSP formulation process(es);
- The District has a Cal Water representative that serves on the Solano GSA Board of Directors, as well as a representative that serves on the Solano GSA Technical Advisory Committee;
- Coordination with applicable local and regulatory agencies to ensure that Cal Water is at full participation, while also meeting the requirements and expectations set forth by SGMA;
- Enhanced use of digital/electronic groundwater monitoring equipment and other new technology aimed at measuring withdrawal rates, pumping water levels, and key water quality parameters within the context of day-to-day operations;

---

<sup>21</sup> Ibid.

<sup>22</sup> Solano Collaborative & Solano County Water Agency, 2025. Solano County and Solano Subbasin Groundwater Sustainability Annual Report — Water Year 2024, dated March 2025. Accessed From: <https://sgma.water.ca.gov/portal/gspar/preview/458>.

- Full participation in the development and implementation of GSP's and formulation of groundwater models being constructed in basins where Cal Water has an operating presence;
- Participation in individual and/or joint projects aimed at mitigating seawater intrusion or other "undesirable results" where appropriate;
- Inclusion of sound groundwater management principles and data in all applicable technical reports, studies, facility master plans, and UWMPs (including this 2025 update), particularly as these undertakings relate or pertain to water resource adequacy and reliability;
- Ensure reliable water service for historically underserved and/or vulnerable communities within Cal Water's service areas; and
- Inclusion of sound groundwater management principles and data in all general rate case (GRC) filings and grant applications to ensure that resource management objectives remain visible and central to Cal Water's long-term planning/budgeting efforts.

#### 6.2.5 Historical Pumping and Supply Sufficiency


Cal Water holds certain water rights to groundwater it has pumped and used as an overlying owner and appropriator. Cal Water's water rights have been dedicated to a public use, and Cal Water is required by the California Public Utilities Commission (CPUC) to provide water to all customers within its designated service area under reasonable rules and regulations. State policy supports and protects municipal and domestic uses (California Water Code §§106-“highest use,” 106.5- “protected to the fullest extent for existing and future needs”), which courts have recognized as warranting significant consideration in balancing water rights. Consistent with this, SGMA preserved existing rights and priorities without modification (CWC §10720.5.). Therefore, the projected groundwater supply volumes presented herein are not intended to and do not determine, limit or represent Cal Water's water rights or maximum pumping volumes. Any determination of Cal Water's water rights, as an overlying owner, appropriator, municipal water purveyor or otherwise, is beyond the scope of this report and the UWMP statutes and regulations.

The District has a total of nine wells located within the District service area boundaries shown in **Figure 6-1**.

There are two surface storage structures, enabling the groundwater wells to pump to storage during non-peak demand periods and provide peak day demand. The District has sufficient production capacity to supply all of the District's current annual average day and maximum day demand.

As noted above, groundwater is the only source of supply for the District. **Table 6-1** lists the amount of groundwater pumped by Cal Water over the past five years. Historically, the groundwater supplies available to the District from the Basin have always been sufficient to meet District demands, and the Cal Water supply wells have not dewatered, even during historical drought periods. Due to successful conservation efforts and response to the historic drought spanning water years 2012-2015 and 2021-2022, groundwater demands (and thus, District groundwater pumping volumes) were approximately 16 percent lower from 2016 through 2025 (i.e., averaging 1,270 AFY) in comparison to the previous ten years (i.e., averaging 1,516 AFY from 2006 through 2015; see **Figure 6-2**).

**Figure 6-2. Dixon District Historical Pumping (1980–2025)**



**Table 6-1. Groundwater Volume Pumped (DWR Table 6-1)**

<input type="checkbox"/>	Check the box if the Supplier does not pump groundwater.						
<input type="checkbox"/>	Check the box if all or part of the groundwater below is desalinated. (OPTIONAL)						
Groundwater Type	Water Type (OPTIONAL)	Location or Basin Name	2021	2022	2023	2024	2025
			(AF)	(AF)	(AF)	(AF)	(AF)
Alluvial Basin	Potable	Solano Subbasin	1,311	1,238	1,280	1,337	1,348
<b>TOTAL</b>			<b>1,311</b>	<b>1,238</b>	<b>1,280</b>	<b>1,337</b>	<b>1,348</b>
<b>Notes:</b>							
(a) The Solano Subbasin is neither critically overdrafted nor adjudicated, and the projected groundwater supply volumes are not intended to and do not determine, limit or represent Cal Water's water rights or maximum pumping volumes. Any determination of Cal Water's water rights, as an overlying owner, appropriator, municipal water purveyor or otherwise, is beyond the scope of this report and the UWMP statutes and regulations.							

The projected District pumping is consistent with the GSP goals to maintain groundwater levels in the Basin at or above 1991-2014 ("base period") average groundwater levels.<sup>23</sup> During the base period, the District pumped an average of 1,625 AF (0.9 percent of total Basin pumping) to meet service area demands (see **Figure 6-2**), while Basin-wide pumping averaged 180,000 AFY. Basin-wide pumping during the base period was less than the sustainable yield of 190,000 AFY and did not result in the lowering of groundwater levels or a decrease in groundwater storage. Given that the current (see **Table 6-8**) and projected future pumping (see **Table 6-9**) both within the District and across the Basin are projected to be less than the average pumping during the GSP-defined base period, it is reasonable to conclude that the groundwater supply is sufficient to meet the projected future demands of the District in normal and multiple dry year periods through 2050 and that the projected groundwater demand within the District will not impact the Basin's ability to achieve its sustainability goal. Section 7.1.1 presents an analysis of the availability of groundwater supply for the District based on historical groundwater use and assessments conducted in the GSP. Based on the best available information, the available groundwater supply is expected to be sufficient to meet the projected future demands of the District in normal and multiple dry year periods through 2050.

<sup>23</sup> Solano Collaborative, 2021. Solano Subbasin Groundwater Sustainability Plan, dated November 2021. Accessed From: <https://sgma.water.ca.gov/portal/gsp/preview/117>.

### 6.3 Surface Water

Cal Water does not impound or divert surface water as a means to meet demands in the Dixon District.

### 6.4 Stormwater

Cal Water does not divert stormwater for beneficial uses in the Dixon District.

### 6.5 Wastewater and Recycled Water

**CWC § 10633**

*The plan shall provide, to the extent available, information on recycled water and its potential for use as a water source in the service area of the urban water supplier. The preparation of the plan shall be coordinated with local water, wastewater, groundwater, and planning agencies that operate within the supplier's service area.*

The recycling of wastewater offers several benefits to Cal Water and its customers. One of these benefits is to help maintain a sustainable groundwater water supply either through direct recharge, or by reducing potable supply needs by utilizing recycled water for appropriate uses (e.g., landscape irrigation) now being served by potable water. Cal Water is evaluating the feasibility of specific recycled water projects that could be implemented and will incorporate these findings in future water supply planning. The potential amount of recycled water that can be produced is proportional to the amount of wastewater that is locally generated and is discussed in the following sections.

#### 6.5.1 Recycled Water Coordination

The District relies on and coordinates with the City of Dixon (City or Dixon) for relevant wastewater collection, treatment, and discharge. There are no current plans identified by the City to bring recycled water into the District area.

#### 6.5.2 Wastewater Collection, Treatment, and Disposal

**CWC § 10633 (a)**

*A description of the wastewater collection and treatment systems in the supplier's service area, including a quantification of the amount of wastewater collected and treated and the methods of wastewater disposal.*

**CWC § 10633 (b)**

*A description of the quantity of treated wastewater that meets recycled water standards, is being discharged, and is otherwise available for use in a recycled water project.*

A summary of wastewater collection for the District is shown in **Table 6-2**, including estimates of the volume of wastewater collected from District customers in 2025. The estimate is calculated by annualizing 90 percent of January water use in the service area. As shown in **Table 6-3**, no wastewater is treated or disposed of within the District.

Wastewater is collected by the City at the Dixon Wastewater Treatment Facility (WWTF). The Dixon WWTF has a capacity to treat an average dry weather flow of 1.92 million gallons per day (MGD) but currently receives an average flow of 1.13 MGD from residential and commercial customers.<sup>24,25</sup> Approximately 69 percent (0.78 MGD) of the wastewater flow is attributed to the District.

In 2017, the Dixon WWTF was upgraded to fully comply with Waste Discharge Requirements. The upgrade also addressed several code deficiencies for fire control, earthquake, hazardous waste materials and worker safety. The upgraded Dixon WWTF uses an activated sludge process and the treated wastewater discharged from the facility is used to recharge the Basin. An additional project approved by the City of Dixon in December 2023 will increase WWTF capacity to 3.3 MGD and is scheduled to take place from early 2025 through 2027.<sup>26</sup>

Currently, no wastewater is recycled for direct reuse within the District service area. The cost of implementation of a recycled water system in the District is not justified at the present time, and a recycled water system will likely only be considered if conditions related to District supply change significantly in the future.

---

<sup>24</sup> City of Dixon, 2023. City of Dixon Sewer Collection System Master Plan, dated March 2023. Accessed From: <https://www.cityofdixonca.gov/media/Sewer/Final%20SCSMP-Complete-2023-03-01.pdf>.

<sup>25</sup> City of Dixon, 2023. City of Dixon Wastewater Treatment Facility Expansion Project, dated December 2023. Accessed From:

<https://www.cityofdixonca.gov/media/EnvironmentalReviewDocuments/2023%20NOD%20WWTF%20Expansion%20Project/12072023-231%20-%20NOD%20-%20City%20of%20Dixon%20-%20Wastewater%20Treatment%20Facility%20Expansion%20Project.pdf>.

<sup>26</sup> Ibid.

**Table 6-2. Wastewater Collected Within Service Area in 2025 (DWR Table 6-2)**

<input type="checkbox"/>	Check the box if there is no wastewater collection system.			
	Percentage of 2025 service area covered by wastewater collection system (OPTIONAL)			
	Percentage of 2025 service area population covered by wastewater collection system (OPTIONAL)			
Wastewater Collection			Recipient of Collected Wastewater	
Name of Wastewater Collection Agency	Wastewater Volume Metered or Estimated? (OPTIONAL)	Volume of Wastewater Collected from UWMP Service Area 2025	Name of Wastewater Treatment Plant (WWTP) and Place ID Number	Is WWTP Located Within UWMP Area?
		(AF)		
City of Dixon	Estimated	820	Dixon WWTF, Place ID 220396	No
<b>Total Wastewater Collected from Service Area in 2025:</b>		820		
<b>Notes:</b>				
(a) The volume of wastewater collected from the Dixon District service area in 2025 is estimated by annualizing 90 percent of January water use.				
(b) WWTP = Wastewater Treatment Plant.				

**Table 6-3. Wastewater Treatment and Outcomes Within UWMP Service Area in 2025 (DWR Table 6-3)**

<input checked="" type="checkbox"/> Check box if no wastewater is treated or disposed of within the UWMP service area.														
Wastewater Treatment Plant Name and Place ID Number	Does This Plant Treat Wastewater Generated Outside the UWMP Service Area?	2025 Volume of Wastewater Received from UWMP Service Area (AF)	Total 2025 Volume of Water Treated (AF)	2025 Outcomes of Treated Wastewater										
				Water Recycled Within UWMP Service Area		Water Recycled Outside of UWMP Service Area		Effluent Discharge that is not a Permitted Recycled Water Use		Required Discharge for Instream Flow		Delivered to Another Entity for Additional Treatment		
				Treatment Level	Volume (AF)	Treatment Level	Volume (AF)	Treatment Level	Volume (AF)	Treatment Level	Volume (AF)	Treatment Level	Volume (AF)	Name of other entity
<b>Total</b>														
<b>Notes:</b>														

### 6.5.3 Recycled Water System and Recycled Water Beneficial Uses

**CWC § 10633 (c-g)**

*(c) A description of the recycled water currently being used in the supplier's service area, including, but not limited to, the type, place, and quantity of use.*

*(d) A description and quantification of the potential uses of recycled water, including, but not limited to, agricultural irrigation, landscape irrigation, wildlife habitat enhancement, wetlands, industrial reuse, groundwater recharge, indirect potable reuse, and other appropriate uses, and a determination with regard to the technical and economic feasibility of serving those uses.*

*(e) The projected use of recycled water within the supplier's service area at the end of 5, 10, 15, and 20 years and a description of the actual use of recycled water in comparison to uses previously projected pursuant to this subdivision.*

*(f) A description of actions, including financial incentives, which may be taken to encourage the use of recycled water, and the projected results of these actions in terms of acre-feet of recycled water used per year.*

*(g) A plan for optimizing the use of recycled water in the supplier's service area, including actions to facilitate the installation of dual distribution systems, to promote recirculating uses, to facilitate the increased use of treated wastewater that meets recycled water standards, and to overcome any obstacles to achieving that increased use.*

Currently, as shown in **Table 6-4** and **Table 6-5**, the District does not have any specific current or projected projects for the beneficial use of recycled water but are assessing the feasibility of such projects.

**Table 6-4. Recycled Water Direct Beneficial Uses Within Service Area (DWR Table 6-4)**

<input checked="" type="checkbox"/> Check box if recycled water is not used and is not planned for use within the service area of the supplier.										
Name(s) of Facility/ies Producing (Treating) the Recycled Water (OPTIONAL):										
Name of Supplier Operating the Recycled Water Distribution System (OPTIONAL):										
Supplemental Water Added in 2025 (Volume) (OPTIONAL):										
Source of 2025 Supplemental Water (OPTIONAL):										
Use Type	Water Type (after treatment if treated) (OPTIONAL)	Additional Information (as needed)	2025	2030	2035	2040	2045	2050 (opt)	Potential Recycled Water Use	
			(AF)	(AF)	(AF)	(AF)	(AF)	(AF)	Volume	Narrative Page Number (OPTIONAL)
									0	
<b>Total:</b>									0	
<b>Notes:</b>										

**Table 6-5. 2020 UWMP Recycled Water Use Projection Compared to 2025 Actual (DWR Table 6-5)**

<input checked="" type="checkbox"/>	Check the box if recycled water was not used in 2025 nor projected for use in 2020.	
Use Type	2020 Projection for 2025	2025 Actual Use
	(AF)	(AF)
<b>Total</b>		
<b>Notes:</b>		

6.5.4 Actions to Encourage and Optimize Future Recycled Water Use

At this time, as shown in **Table 6-6**, a specific recycled water system for beneficial use within the District has not been identified at this time. Cal Water’s supply portfolio in some districts already includes recycled water. Cal Water has also recently developed a Water Reuse Strategic Plan that evaluated potential reuse opportunities across all Cal Water Districts, including Non-Potable Reuse (NPR), Indirect Potable Reuse (IPR), and Direct Potable Reuse (DPR). It further outlined key aspects of potable reuse projects including project structure, interagency coordination, and source control. Cal Water will utilize this Strategic Plan to further evaluate the feasibility of specific opportunities and is eager to expand its water supply portfolio to utilize water reuse where feasible, and to form partnerships with other agencies and jurisdictions to accomplish this.

**Table 6-6. Methods to Expand Future Recycled Water Use (DWR Table 6-6)**

<input checked="" type="checkbox"/>	Check the box if the Supplier does not plan to expand recycled water use in the future.		
Section 6.5.4; Page 76	Page location of narrative in UWMP		
Name of Action	Description	Planned Implementation Year	Expected Increase in Recycled Water Use
			(AF)
<b>Total</b>			
<b>Notes:</b>			

## 6.6 Desalinated Water Opportunities

**CWC § 10631 (g)** *A plan shall be adopted in accordance with this chapter and shall do all of the following:*

*Describe the opportunities for development of desalinated water, including, but not limited to, ocean water, brackish water, and groundwater, as a long-term supply.*

The Dixon District is located many miles from the nearest source of saline water. As such, there are no opportunities for the development of desalinated water in the District.

## 6.7 Water Exchanges and Transfers

**CWC § 10631 (c)** *A plan shall be adopted in accordance with this chapter and shall do all of the following:*

*Describe the opportunities for exchanges or transfers of water on a short-term or long-term basis.*

Groundwater has proven to be a reliable source of supply in the Dixon District (see Sections 6.2.5 and 7.1.1). Therefore, there has not been any need to acquire additional supplies. Cal Water does not hold any surface water rights in this area that could be transferred to other agencies. Therefore, Cal Water is not pursuing water transfers or exchanges at this time.

### 6.7.1 Exchanges

Cal Water is not pursuing water exchanges involving the Dixon District and other entities at this time.

### 6.7.2 Transfers

Cal Water is not pursuing water transfers involving the Dixon District and other entities at this time.

### 6.7.3 Emergency Interties

Cal Water has three emergency interconnections with the City of Dixon.

## 6.8 Future Water Projects

**CWC § 10631** A plan shall be adopted in accordance with this chapter and shall do all of the following:

*(b) (3) For any planned sources of water supply, a description of the measures that are being undertaken to acquire and develop those water supplies.*

*(f) Include a description of all water supply projects and water supply programs that may be undertaken by the urban water supplier to meet the total projected water use, as established pursuant to subdivision (a) of Section 10635. The urban water supplier shall include a detailed description of expected future projects and programs that the urban water supplier may implement to increase the amount of the water supply available to the urban water supplier in normal and single-dry water years and for a period of drought lasting five consecutive water years. The description shall identify specific projects and include a description of the increase in water supply that is expected to be available from each project. The description shall include an estimate with regard to the implementation timeline for each project or program.*

Cal Water has an active well maintenance program to monitor all of the wells and identify which wells need to be replaced to maintain the reliability of the system. Cal Water will maintain sufficient wells and distribution facilities to meet the anticipated increases in future demand as needed. In addition to routine well maintenance, Cal Water is currently advancing additional supply-augmentation projects to support reliability and growth, including adding additional wells to its system. As shown in **Table 6-7**, Cal Water plans to bring one previously inactive well back online by 2028 with an anticipated additional supply of 1,614 AFY.

**Table 6-7. Expected Future Water Supply Projects or Programs (DWR Table 6-7)**

<input type="checkbox"/>	No expected future water supply projects or programs that provide a quantifiable increase to the agency's water supply.						
<input type="checkbox"/>	Some or all of the supplier's future water supply projects or programs are not compatible with this table and are described in a narrative format.						
	Provide page location of narrative in the UWMP						
Name of Future Projects or Programs	Joint Project with Other Suppliers?		Additional Description (as needed)	Water Type (after treatment if treated) (OPTIONAL)	Planned Implementation Year	Planned for Use in Year Type	Expected Increase in Water Supply to Supplier
	Yes/No	If Yes, Supplier Name					(AF)
Reactivation of Well - Station 4	No			Potable	2028	All Year Types	1,614
<b>Notes:</b>							

## 6.9 Summary of Existing and Planned Sources of Water

- ☑ **CWC § 10631 (b)** *Identify and quantify, to the extent practicable, the existing and planned sources of water available to the supplier over the same five-year increments described in subdivision (a).*
- ☑ **CWC § 10631 (b) (2)** *When multiple sources of water supply are identified, a description of the management of each supply in correlation with the other identified supplies.*
- ☑ **CWC § 10631 (b) (4) (D)** *A detailed description and analysis of the amount and location of groundwater that is projected to be pumped by the urban water supplier. The description and analysis shall be based on information that is reasonably available, including, but not limited to, historic use records.*

**Table 6-8** summarizes the actual volumes of groundwater production for calendar year 2025.

As discussed above, groundwater will be used to serve all projected demand within the Dixon District through 2050. Therefore, the groundwater supply volumes shown in **Table 6-9** equal the projected demand in each year. Section 7.1.1 presents an analysis of the availability of groundwater supply for the District based on historical groundwater use and assessments conducted by the Solano Collaborative as part of the GSP development process. Based on the available information, the available groundwater supply is expected to be sufficient to meet the projected future demands of the District in normal and multiple dry year periods through 2050.

It should also be noted that the Solano Subbasin is not adjudicated and is not in a state of critical overdraft, and the projected groundwater supply volumes are not intended to and do not determine, limit or represent Cal Water's water rights or maximum pumping volumes. Any determination of Cal Water's water rights, as an overlying owner, appropriator, municipal water purveyor or otherwise, is beyond the scope of this report and the UWMP statutes and regulations.

**Table 6-8. Water Supplies – Actual (DWR Table 6-8)**

Water Supply	Additional Description (As Needed)	2025		
		Water Type (after treatment if treated) (OPTIONAL)	Actual Volume	Total Entitlement (OPTIONAL)
			(AF)	(AF)
Groundwater (not desalinated)	Solano Subbasin	Potable	1,348	
Subtotal Potable			1,348	
Subtotal Non-Potable			0	
<b>Total</b>			<b>1,348</b>	
<p><b>Notes:</b></p> <p>(a) The Solano Subbasin is not critically overdrafted and is not adjudicated. The projected groundwater supply volumes are not intended to and do not determine, limit or represent Cal Water’s water rights or maximum pumping volumes. Any determination of Cal Water’s water rights, as an overlying owner, appropriator, municipal water purveyor or otherwise, is beyond the scope of this report and the UWMP statutes and regulations.</p>				

**Table 6-9. Water Supplies – Projected (DWR Table 6-9)**

Water Supply	Additional Detail on Water Supply	Water Type (OPTIONAL)	Projected Water Supply									
			2030		2035		2040		2045		2050 (opt)	
			Reasonably Available Volume	Total Entitlement (OPTIONAL)	Reasonably Available Volume	Total Entitlement (OPTIONAL)	Reasonably Available Volume	Total Entitlement (OPTIONAL)	Reasonably Available Volume	Total Entitlement (OPTIONAL)	Reasonably Available Volume	Total Entitlement (OPTIONAL)
			(AF)	(AF)	(AF)	(AF)	(AF)	(AF)	(AF)	(AF)	(AF)	(AF)
Groundwater (not desalinated)	Solano Subbasin	Potable	1,082		1,048		1,025		1,008		993	
Subtotal Potable			1,082		1,048		1,025		1,008		993	
Subtotal Non-Potable			0		0		0		0		0	
<b>Total</b>			1,082		1,048		1,025		1,008		993	

**Notes:**

(a) The Solano Subbasin is not critically overdrafted and is not adjudicated. The projected groundwater supply volumes are not intended to and do not determine, limit or represent Cal Water’s water rights or maximum pumping volumes. Any determination of Cal Water’s water rights, as an overlying owner, appropriator, municipal water purveyor or otherwise, is beyond the scope of this report and the UWMP statutes and regulations.

## 6.10 Special Conditions

### 6.10.1 Climate Change Effects

Cal Water is committed to incorporating climate change into its ongoing water supply planning. Section 4.4 of this Plan includes a description of plausible changes to projected demands under climate change conditions, and Cal Water is currently working to consider the effects of climate change in future demand modeling. The impact of climate change on District supplies is addressed in detail in the key resources described below, which are incorporated into this Plan by reference:

- In 2016, Cal Water completed a study of climate change impacts on a representative subset of its districts to gain a better understanding of the potential impacts of climate change on the availability of its diverse supplies.<sup>27</sup> The 2016 study relied on the best available projections of changes in climate (temperature and precipitation) through the end of the century to examine how surface water flows and groundwater recharge rates may change. The executive summary of this study is included in this Plan in **Appendix F**.
- Cal Water developed a multi-phase climate change study to assess the climate-related impacts on Cal Water assets, supplies, demands, and vulnerabilities. Phase 1, which primarily consisted of a literature and tools review of previous and complementary studies, was completed in December 2020. Phase 2 included a District-level vulnerability assessment of Cal Water's facilities and operations, an assessment approach that evaluates climate impacts to Cal Water, identification of asset vulnerabilities, and prioritization of climate risks. Phase 2 also included an assessment of climate-driven impacts to water supply resources and demand, and was completed in December 2021. The executive summary for Phase 1 and the Summary for Decision Makers for Phase 2 of these studies are included in this Plan in **Appendix F**.
- SGMA dictates that GSPs include basin-wide water budget models under various climate change scenarios, including future conditions which account for the effects of estimated climate change. The GSP for the Basin is available on the DWR SGMA Portal website:  
<https://sgma.water.ca.gov/portal/gsp/preview/117>.

### 6.10.2 Regulatory Conditions and Project Development

Emerging regulatory conditions (e.g., issues surrounding the Water Quality Control Plan for the San Francisco/Sacramento-San Joaquin Delta Estuary [Bay-Delta Plan]) may affect planned future projects and the characterization of future water supply availability and analysis. Beyond bringing an inactive well back online, the District does not have any current plans to develop additional

---

<sup>27</sup> California Water Service Company, 2016. Potential Climate Change Impacts on the Water Supplies of California Water Service, prepared by Gary Fiske and Associates, Inc. and Balance Hydrologics, Inc., dated January 2016.

supply sources. If the District does move forward with any plans to develop supply projects, emerging regulatory conditions will be considered, and the associated water supply reliability impacts will be assessed in future UWMP updates.

### 6.10.3 Other Locally Applicable Criteria

Other locally applicable criteria may affect characterization and availability of an identified water supply (e.g., changes in regional water transfer rules may alter the availability of a water supply that had historically been readily available). Beyond bringing an inactive well back online, the District does not have any current plans to develop additional supply sources. If the District does move forward with any plans to develop supply projects, locally applicable criteria will be considered, and the associated water supply reliability impacts will be assessed in future UWMP updates.

Under SGMA, GSAs have the authority to implement P/MAs that help the Basin reach its sustainability goal, including such actions as setting allocations for groundwater pumping or implementing fees for pumping volumes. However, the Solano Collaborative expects that no demand management actions will be needed to ensure sustainable groundwater conditions in the Basin. As described in Section 6.2, the GSP was completed and adopted in 2021, and submitted to DWR in early 2022, and approved by DWR in January 2024. If any demand management actions are planned in the future, Cal Water will consider them as a part of its supply planning efforts.

## 6.11 Energy Intensity

### CWC § 10631.2

- (a) *In addition to the requirements of Section 10631, an urban water management plan shall include any of the following information that the urban water supplier can readily obtain:*
- (1) *An estimate of the amount of energy used to extract or divert water supplies.*
  - (2) *An estimate of the amount of energy used to convey water supplies to the water treatment plants or distribution systems.*
  - (3) *An estimate of the amount of energy used to treat water supplies.*
  - (4) *An estimate of the amount of energy used to distribute water supplies through its distribution systems.*
  - (5) *An estimate of the amount of energy used for treated water supplies in comparison to the amount used for nontreated water supplies.*
  - (6) *An estimate of the amount of energy used to place water into or withdraw from storage.*
  - (7) *Any other energy-related information the urban water supplier deems appropriate.*
- (b) *The department shall include in its guidance for the preparation of urban water management plans a methodology for the voluntary calculation or estimation of the energy intensity of urban water systems. The department may consider studies and calculations conducted by the Public Utilities Commission in developing the methodology.*
- (c) *The Legislature finds and declares that energy use is only one factor in water supply planning and shall not be considered independently of other factors.*

The “Total Utility Approach” as defined by DWR in the 2025 UWMP Guidebook is used to report water-related energy-consumption data for the Dixon District. Calendar year 2024 is selected as the one-year reporting period, and utility bills for the associated time period are used as the source for energy consumption data. Utility bills reported the following energy consumption data for the Dixon District during calendar year 2024:

*Total Energy Consumed by the Dixon District = 752,696 kilowatt hour (kWh)*

**Table 6-10** shows the energy consumed for each acre-foot (AF) of water entering the distribution system in the Dixon District, including energy associated with the pumping, treatment, conveyance, and distribution of drinking water, but not including energy associated with the treatment of wastewater. Based on this, the energy intensity is estimated to be 563 kilowatt hours per acre-foot (kWh/AF), or 1,728 kWh per million gallon consistent with the DWR 2025 UWMP Submittal Tables (see **Table 6-10**).

**Table 6-10. Recommended Energy Intensity – Total Utility Approach (DWR Table O-1B)**

Water Delivery Product	Retail Potable Deliveries	Only for Water Delivery Products Under the Urban Water Supplier's Operational Control		
		Sum of All Water Management Processes	Non-Consequential Hydropower	
Start Date of Reporting Period	1/1/2024			
End Date of Reporting Period	12/31/2024			
Is Upstream Embedded Energy in the Values Reported?	No			
Units of Measure for Water	(AF)	<b>Total Utility</b>	<b>Hydropower</b>	<b>Net Utility</b>
Volume of Water Entering Process		1,337	-	1,337
Energy Consumed (kWh)		752,696	-	752,696
Energy Intensity (kWh/vol. converted to MG)		1,728	-	1,728
<b>Quantity of Self-Generated Renewable Energy</b>				
N/A				
<b>Data Quality</b> (Estimate, Metered Data, Combination of Estimates and Metered Data)				
Metered Data				
<b>Data Quality Narrative:</b>				
Utility bills for the associated time period are used as the source for energy consumption data.				
<b>Narrative:</b>				
Total energy consumption represents the energy consumed during pumping, treatment, conveyance, and distribution.				
<b>Notes:</b>				



## Chapter 7

### Water Supply Reliability Assessment

**CWC § 10620 (f)**

*An urban water supplier shall describe in the plan water management tools and options used by that entity that will maximize resources and minimize the need to import water from other regions.*

**CWC § 10630.5**

*Each plan shall include a simple lay description of how much water the agency has on a reliable basis, how much it needs for the foreseeable future, what the agency's strategy is for meeting its water needs, the challenges facing the agency, and any other information necessary to provide a general understanding of the agency's plan.*

This chapter describes the reliability of the California Water Service (Cal Water) Dixon District's (also referred to herein as the "District") water supplies. Assessment of water supply reliability is complex and dependent upon a number of factors, such as the number of water sources, regulatory and legal constraints, hydrological and environmental conditions, climate change, and expected growth, among others. Based on available historical information and projections of future water uses, regulatory and legal constraints, and hydrological and environmental conditions, including climate change, Cal Water has made its best determination of future water supply reliability for the District. This chapter includes the following sections:

7.1 Constraints on Water Sources

7.2 Reliability by Type of Year

7.3 Supply and Demand Assessment

7.4 Water Supply Management Tools and Options

7.5 Drought Risk Assessment

#### 7.1 Constraints on Water Sources

Groundwater pumped from the Solano Subbasin (Basin) is the sole supply for the Dixon District. Cal Water has identified several potential constraints on future water supply for the District including groundwater supply availability, water quality, climate change, and evolving regulations such as the Sustainable Groundwater Management Act (SGMA). These constraints, along with associated management strategies are summarized in the following sections.

### 7.1.1 Supply Availability

Cal Water holds certain water rights to groundwater it has pumped and used as an overlying owner and appropriator. Cal Water's water rights have been dedicated to a public use, and Cal Water is required by the California Public Utilities Commission (CPUC) to provide water to all customers within its designated service area under reasonable rules and regulations. State policy supports and protects municipal and domestic uses (California Water Code §§106-“highest use,” 106.5- “protected to the fullest extent for existing and future needs”), which courts have recognized as warranting significant consideration in balancing water rights. Consistent with this, Sustainable Groundwater Management Act (SGMA) preserved existing rights and priorities without modification (CWC §10720.5). Use of water for domestic purposes is recognized as the “highest use” of water in the State of California pursuant to CWC §106, and the rights of urban water purveyors should be protected to the fullest extent necessary for existing and future uses, pursuant to CWC §106.5.

Historically, the groundwater supplies available to the Dixon District from the Basin have always been sufficient to meet District demands, and the Cal Water supply wells have not dewatered, even during historical drought periods. Due to successful conservation efforts and response to the historic drought spanning water years 2012-2015 and 2021-2022, groundwater demands (and thus, District groundwater pumping volumes) were approximately 16 percent lower from 2016 through 2025 (i.e., averaging 1,270 acre-feet per year [AFY]) in comparison to the previous ten years (i.e., averaging 1,516 AFY from 2006 through 2015; see **Figure 6-2**). Current and projected District-wide pumping is not expected to exceed the Basin sustainable yield of 190,000 AFY. Based on the water budget information presented in the Basin's Groundwater Sustainability Plan (GSP), the average annual groundwater pumping from 1991 through 2018 totaled approximately 180,000 AFY from the Basin (pumping by sector was not specifically enumerated for the historical water budget). In the projected water budget scenario, average groundwater pumping from the Basin totaled 170,000 AFY, including approximately 140,000 AFY for irrigated agriculture and 28,000 AFY for urban use.<sup>28</sup> These data show that urban pumping accounts for approximately 16 percent of total pumping in the Basin. The District's average pumping over the historical period 1991-2018 (1,560 AFY) accounted for 0.9 percent of total Basin pumping. Additionally, Table 4-1 of the Water Year (WY) 2024 Annual Report indicated that for WY 2024, urban pumping (27,000 AFY) made up approximately 18 percent of total Basin pumping (150,000 AFY). In WY 2024 Cal Water's pumping (1,324 AFY) accounted for 0.88 percent of total Basin pumping. It is therefore likely that management of agricultural groundwater use, rather than urban use, will be a much larger determining factor in maintaining Basin-wide groundwater sustainability in the future.<sup>29</sup>

---

<sup>28</sup> Ibid.

<sup>29</sup> Solano Collaborative, 2025. Solano County and Solano Subbasin Groundwater Sustainability Annual Report Water Year 2024, dated March 2025. Accessed From: <https://sgma.water.ca.gov/portal/gspar/preview/458>.

Further, projected District pumping is consistent with the GSP goal to maintain groundwater levels in the Basin at or above WY 1991-2014 (“base period”) average levels. Between WY 1991 and 2014, the District pumped 1,625 AFY to meet service area demands as discussed further in Section 6.2.5 and shown on **Figure 6-2**. Given that the projected future District pumping under all hydrologic scenarios through 2050 is less than its base period average, and that Basin-wide pumping during the base period was less than the sustainable yield, it is reasonable to conclude that the District’s projected groundwater demand will not impact the Basin’s ability to achieve the sustainability goal. As such, the groundwater supply is assumed to be 100 percent reliable, up to the District’s pre-SGMA baseline pumping volume (1,625 AFY; Section 6.2.5).

However, it is important to note that the Solano Subbasin is neither critically overdrafted nor adjudicated, and the projected groundwater supply volumes are not intended to and do not determine, limit or represent Cal Water’s water rights or maximum pumping volumes. SGMA was intended to preserve the security of water rights in the state and was not intended to determine, modify or alter any surface water or groundwater rights or priorities. (CWC §10720.1(b), 10720.5(a) and (b)). SGMA should therefore not reduce, adversely impact or limit Cal Water’s present or future exercise of its domestic water rights or its obligation to serve its municipal customers. As such, any determination of Cal Water’s water rights, as an overlying owner, appropriator, municipal water purveyor or otherwise, is beyond the scope of this report and the UWMP statutes and regulations.

### 7.1.2 Water Quality

#### CWC § 10634

*The plan shall include information, to the extent practicable, relating to the quality of existing sources of water available to the supplier over the same five-year increments as described in subdivision (a) of Section 10631, and the manner in which water quality affects water management strategies and supply reliability.*

Impaired water quality also has the potential to affect water supply reliability. Cal Water is committed to meeting all state and federal water quality regulations. All drinking water standards are set by the U.S. Environmental Protection Agency (EPA) under the authorization of the Federal Safe Drinking Water Act of 1974. In California, the State Water Resources Control Board (SWRCB), Division of Drinking Water (DDW) can either adopt the EPA standards or set more stringent standards, which are then codified in Title 22 of the California Code of Regulations. There are two general types of drinking water standards:

- **Primary Maximum Contaminant Levels (MCLs)** are health protective standards and are established using a very conservative risk-based approach for each constituent that takes into potential health effects, detectability and treatability, and costs of treatment. Public water systems may not serve water that exceeds Primary MCLs for any constituent.

- **Secondary MCLs** are based on the aesthetic qualities of the water such as taste, odor, color, and certain mineral content, and are considered limits for constituents that may affect consumer acceptance of the water.

Cal Water routinely monitors its wells and the water that is treated and served to customers to ensure that water delivered to customers meets these drinking water standards. The results of this testing are reported to the SWRCB DDW following each test and are summarized annually in Water Quality Reports (also known as “Consumer Confidence Reports”), which are provided to customers by mail and made available on Cal Water’s website:

<https://www.calwater.com/water-quality-reports/>.

Additionally, a detailed review of the water quality conditions of the underlying groundwater basin are provided in the GSP and Basin Annual Reports, available on the Department of Water Resources (DWR) SGMA Portal website:

<https://sgma.water.ca.gov/portal/gsp/all>.

Although there is the potential for some regulated constituents to be present in source water, as documented in the Water Quality Reports, the District’s monitoring, management, and treatment of its water results in high quality drinking water meeting all drinking water standards being served to customers. Cal Water tracks changes in constituent concentrations to proactively address water quality issues before they impact supply reliability.<sup>30</sup> In the event that water quality constituents are detected in source water at concentrations requiring treatment, the District is able to take impacted source(s) offline to implement appropriate treatment. Further, as part of the siting process for all new wells, Cal Water evaluates the presence of groundwater contamination and avoids placing wells in areas of known contamination.

Cal Water is committed to proactively addressing emerging contaminants and changing MCL requirements as needed.

Given Cal Water’s proactive monitoring and management of water quality in its source water supplies, water quality is not expected to impact the reliability of the District’s available supplies within the planning horizon (i.e., through 2050).

### 7.1.3 Climate Change

#### **CWC § 10631 (b) (1)**

*...For each source of water supply, consider any information pertinent to the reliability analysis conducted pursuant to Section 10635, including changes in supply due to climate change.*

---

<sup>30</sup> Cal Water, 2018. Direct Testimony of Director of Water Quality, 2018 CPUC Rate Case Filing.

Section 6.10 provides a summary of the assessments of climate change on supplies that Cal Water has previously performed and those planned for the near term, as well as those related to SGMA efforts for the Basin. The water budget modeling efforts in the GSP incorporated climate change factors for hydrology and surface water supplies using the DWR Central Tendency climate change scenarios to obtain estimated climate change impacts.<sup>31</sup> Section 4.4 of this UWMP presents information on how the impacts of climate change are factored into projected demands in the District. Cal Water is actively working to further quantify and consider future climate change impacts as part of its ongoing supply and operations planning.

## 7.2 Reliability by Type of Year

### **CWC § 10631 (b)**

*Identify and quantify, to the extent practicable, the existing and planned sources of water available to the supplier over the same five-year increments described in subdivision (a), providing supporting and related information, including all of the following:*

### **CWC § 10631 (b)(1)**

*A detailed discussion of anticipated supply availability under a normal water year, single dry year, and droughts lasting at least five years, as well as more frequent and severe periods of drought, as described in the drought risk assessment. For each source of water supply, consider any information pertinent to the reliability analysis conducted pursuant to Section 10635, including changes in supply due to climate change.*

### **CWC § 10635 (a)**

*Every urban water supplier shall include, as part of its urban water management plan, an assessment of the reliability of its water service to its customers during normal, dry, and multiple dry water years. This water supply and demand assessment shall compare the total water supply sources available to the water supplier with the long-term total projected water use over the next 20 years, in five-year increments, for a normal water year, a single dry water year, and a drought lasting five consecutive water years. The water service reliability assessment shall be based upon the information compiled pursuant to Section 10631, including available data from state, regional, or local agency population projections within the service area of the urban water supplier.*

Consistent with the 2025 UWMP Guidebook, the water service reliability assessment includes three unique types of years based on hydrologic conditions:

- A normal hydrologic year represents the water supplies available under normal conditions, this could be an averaged range of years or a single representative year,
- A single dry year represents the lowest available water supply, and
- A five-consecutive year drought represents the driest five-year period in the historical record.


<sup>31</sup> Solano Collaborative, 2021. Solano Subbasin Groundwater Sustainability Plan, dated November 2021. Accessed From: <https://sgma.water.ca.gov/portal/gsp/preview/117>.

Identification of these dry year periods consistent with the 2025 UWMP Guidebook methodology is provided below.

**Figure 7-1** compares annual rainfall to the historical average (20.08 inches for 1980 to 2024). The designation of Base Years for drought planning shown in **Table 7-1** below comes from the data underlying this chart. The production data record for the Dixon District begins in the year 1980; therefore, the following year type analysis uses the historical period from 1980 to 2024.

A normal hydrologic year occurred in 2016 when precipitation was 20.31 inches, or approximately 1.1 percent above the historic average for the period from 1980 to 2024. The driest year occurred in 2013 when the rainfall was approximately 74 percent below average (5.29 inches). This is taken as the single dry year shown in **Table 7-1**. The multiple dry water years used to represent a five-consecutive year drought are 1987 through 1991. This period represents the driest five-year period on record for the historical period from 1980 to 2024, with an average precipitation of 14.31 inches per year.

**Figure 7-1. Deviation of Annual Rainfall from Long-Term Average**



Source: PRISM Climate Group, Oregon State University, <http://prism.oregonstate.edu>

As discussed in Sections 6.2.5 and 7.1.1, the District’s projected water demands are below historic values and total supplies are expected to be sufficient to meet projected water demands of the District under all hydrologic conditions, including in normal, single dry, and multiple dry years.

As such, the projected “volume available” estimates presented in **Table 7-1** are equal to the maximum demands across projected years and year types shown in **Table 7-2**, **Table 7-3**, and **Table 7-4**. For example, the assumed volume available in a representative single dry year in **Table 7-1** is equal to the projected single dry year demand for the year 2030 as shown in **Table 7-3**.

It should be noted that the supply values shown in **Table 7-2** through **Table 7-4** do not represent the total supply available to the District in a given year, but rather reflect the fact that the groundwater supply has always been sufficient to meet demands (see Section 7.1.1).

**Table 7-1. Basis of Water Year Data (Reliability Assessment) (DWR Table 7-1)**

Year Type	Base Year	Available Supplies if Year Type Repeats	
		<input type="checkbox"/>	Quantification of available supplies is not compatible with this table and is provided elsewhere in the UWMP. Location: _____
		Quantification of available supplies is provided in this table as either volume only, percent only, or both.	
		Volume Available	% of Average Supply
		(AF)	
Average Year	2016	1,082	
Single-Dry Year	2013	1,126	
Consecutive Dry Years 1st Year	1987	1,153	
Consecutive Dry Years 2nd Year	1988	1,153	
Consecutive Dry Years 3rd Year	1989	1,153	
Consecutive Dry Years 4th Year	1990	1,153	
Consecutive Dry Years 5th Year	1991	1,153	

**Notes:**  
 (a) As discussed in Section 7.1, the projected “volume available” estimates presented in **Table 7-1** are equal to the maximum demands across projected years and year types shown in **Table 7-2**, **Table 7-3**, and **Table 7-4**. For example, the assumed volume available in a representative single dry year in **Table 7-1** is equal to the projected single dry year demand for the year 2030 as shown in **Table 7-3**.

### 7.3 Supply and Demand Assessment

Water supply and demand patterns change during normal, single dry, and multiple dry years. Cal Water has relied on the demand modeling described in Chapter 4 to forecast demands for normal, single dry and multiple dry years. As described above and detailed in Section 7.1.1, Cal Water’s groundwater supply for the Dixon District is expected to be able to serve those demands in all year types.<sup>32</sup>

**Table 7-2** shows the projected supply and demand totals for a normal year. The supply and demand totals are consistent with those in **Table 6-9** and **Table 4-2**, respectively. **Table 7-3** shows the projected supply and demand totals for the single dry year, and **Table 7-4** shows the projected supply and demand totals for multiple dry year periods extending five years.

**Table 7-2. Normal Year Supply and Use Comparison (DWR Table 7-2)**

	2030	2035	2040	2045	2050 (opt)
	(AF)	(AF)	(AF)	(AF)	(AF)
Supply Totals	1,082	1,048	1,025	1,008	993
Use Totals	1,082	1,048	1,025	1,008	993
Surplus/(Shortfall)	0	0	0	0	0

**Notes:**

(a) Groundwater is considered fully reliable in the District and groundwater pumping is set equal to predicted demands in the District. The Solano Subbasin is neither critically overdrafted nor adjudicated, and the projected groundwater supply volumes are not intended to and do not determine, limit or represent Cal Water’s water rights or maximum pumping volumes. Any determination of Cal Water’s water rights, as an overlying owner, appropriator, municipal water purveyor or otherwise, is beyond the scope of this report and the UWMP statutes and regulations.

<sup>32</sup> The balance between supply and demand totals excludes usage reductions that are not directly a function of Cal Water supplies, but are externally-imposed by other entities, such as the 2015 state-mandated cutbacks.

**Table 7-3. Single Dry Year Supply and Use Comparison (DWR Table 7-3)**

	2030	2035	2040	2045	2050 (opt)
	(AF)	(AF)	(AF)	(AF)	(AF)
Supply Totals	1,126	1,091	1,067	1,049	1,033
Use Totals	1,126	1,091	1,067	1,049	1,033
Surplus/(Shortfall)	0	0	0	0	0

**Notes:**

(a) Groundwater is considered fully reliable in the District and groundwater pumping is set equal to predicted demands in the District. The Solano Subbasin is neither critically overdrafted nor adjudicated, and the projected groundwater supply volumes are not intended to and do not determine, limit or represent Cal Water’s water rights or maximum pumping volumes. Any determination of Cal Water’s water rights, as an overlying owner, appropriator, municipal water purveyor or otherwise, is beyond the scope of this report and the UWMP statutes and regulations.

**Table 7-4. Multiple Dry Years Supply and Use Comparison (DWR Table 7-4)**

		2030	2035	2040	2045	2050 (Opt)
First Year	Supply Totals	1,153	1,117	1,092	1,075	1,059
	Demand Totals	1,153	1,117	1,092	1,075	1,059
	Surplus/(Shortfall)	0	0	0	0	0
Second Year	Supply Totals	1,153	1,117	1,092	1,075	1,059
	Demand Totals	1,153	1,117	1,092	1,075	1,059
	Surplus/(Shortfall)	0	0	0	0	0
Third Year	Supply Totals	1,153	1,117	1,092	1,075	1,059
	Demand Totals	1,153	1,117	1,092	1,075	1,059
	Surplus/(Shortfall)	0	0	0	0	0
Fourth Year	Supply Totals	1,153	1,117	1,092	1,075	1,059
	Demand Totals	1,153	1,117	1,092	1,075	1,059
	Surplus/(Shortfall)	0	0	0	0	0
Fifth Year	Supply Totals	1,153	1,117	1,092	1,075	1,059
	Demand Totals	1,153	1,117	1,092	1,075	1,059
	Surplus/(Shortfall)	0	0	0	0	0

**Notes:**

(a) Groundwater is considered fully reliable in the District and groundwater pumping is set equal to predicted demands in the District. The Solano Subbasin is neither critically overdrafted nor adjudicated, and the projected groundwater supply volumes are not intended to and do not determine, limit or represent Cal Water’s water rights or maximum pumping volumes. Any determination of Cal Water’s water rights, as an overlying owner, appropriator, municipal water purveyor or otherwise, is beyond the scope of this report and the UWMP statutes and regulations.

## 7.4 Water Supply Management Tools and Options

### **CWC § 10620 (f)**

*An urban water supplier shall describe in the plan water management tools and options used by that entity that will maximize resources and minimize the need to import water from other regions.*

Cal Water coordinates on an ongoing basis with all relevant agencies in the region to optimize the use of regional water supplies. This includes the City of Dixon, Solano County, the Solano Subbasin GSA, Solano Collaborative, and other public and private entities with which Cal Water can collaborate to protect and enhance local groundwater and surface water resources.

Cal Water developed multiple regional water supply reliability studies using integrated resource planning practices to create a long-term supply reliability strategy through 2050 for Cal Water districts throughout California. The studies created long-term strategies to address a wide range of water supply challenges including climate change, new regulatory requirements (e.g., SGMA), and potential growth in demands due to new development. These water supply reliability studies were completed on a rolling basis between 2021 and 2025. The District was included in the Delta Water Supply Reliability Study.

Cal Water also has its own aggressive and comprehensive water conservation program that has and will continue to reduce per-capita usage and therefore demands on critical water sources. Cal Water is committed to helping its customers use water efficiently and has developed a range of water conservation programs to support this goal. To ensure that it is providing the right mix of programs in the most cost-effective manner possible, Cal Water routinely conducts comprehensive conservation program analysis and planning. This is done on a five-year cycle in tandem with the UWMP. Cal Water's Conservation Master Plan (see Appendix H) provides the basis for the information on the implementation of and expected water savings from Demand Management Measures (DMMs) presented in Chapter 9.

Cal Water also monitors and supports the goals of the Westside Sacramento Integrated Regional Water Management Plan as well as SGMA implementation in the Basin.

In summary, Cal Water has a robust planning process in place with multiple supply projects for consideration to address future supply/demand gaps and to increase supply reliability. Additional conservation, if approved by the CPUC, will also support these efforts. Projects will be developed, as needed, to balance supply reliability and affordability.

## 7.5 Drought Risk Assessment

### **CWC § 10635(b)**

*Every urban water supplier shall include, as part of its urban water management plan, a drought risk assessment for its water service to its customers as part of information considered in developing the demand management measures and water supply projects and programs to be included in the urban water management plan. The urban water supplier may conduct an interim update or updates to this drought risk assessment within the five-year cycle of its urban water management plan update. The drought risk assessment shall include each of the following:*

*(1) A description of the data, methodology, and basis for one or more supply shortage conditions that are necessary to conduct a drought risk assessment for a drought period that lasts five consecutive water years, starting from the year following when the assessment is conducted.*

*(2) A determination of the reliability of each source of supply under a variety of water shortage conditions. This may include a determination that a particular source of water supply is fully reliable under most, if not all, conditions.*

*(3) A comparison of the total water supply sources available to the water supplier with the total projected water use for the drought period.*

*(4) Considerations of the historical drought hydrology, plausible changes on projected supplies and demands under climate change conditions, anticipated regulatory changes, and other locally applicable criteria.*

### 7.5.1 Data, Methods, and Basis for Water Shortage Condition

Section 7.1.1 presents an evaluation of the sufficiency of the Dixon District's groundwater supplies to meet projected water demands in dry year conditions, including an extended five-year drought period extending from 2026 through 2030. This evaluation considers historical drought hydrology and plausible changes on projected supplies and demands under climate change conditions, anticipated regulatory changes, and other locally applicable criteria.

In the District, the sole supply source is groundwater from the underlying Basin. As such, the same data, methodology, and basis for the conclusions of the above water supply sufficiency analysis for multiple dry year periods through 2050 holds true for purposes of this drought risk assessment (i.e., supply availability through 2030), see Section 7.1.1.

Accordingly, as shown in of the Plan, the groundwater supply is expected to be able to meet the projected demands through 2030, even if there is a five-year drought.

### 7.5.2 Drought Risk Assessment Water Source Reliability

As described in Chapter 6, groundwater is the sole source of water supply for the District. Based on discussion in Section 7.1.1, the District's groundwater supply is expected to be sufficient to meet demands in all hydrologic conditions, including an extended five-year drought period.

As described in Sections 4.4 and 6.10.1 of this Plan, the impacts on climate change have already been factored into the District's demand projections and the analysis of the near- and longer-term reliability of the groundwater supply source available to the District.

Regulatory conditions that could affect future water supply availability and project development (e.g., related to the Water Quality Control Plan for the San Francisco/Sacramento-San Joaquin Delta Estuary [Bay-Delta Plan]) are discussed in Section 6.10.3 of the Plan. However, beyond bringing an inactive well back online, the District does not currently have plans for projects to develop additional supply sources, and so these regulatory conditions will be assessed in future UWMP updates if or when the District moves forward with any plans to develop supply projects.

Implementation of SGMA in the Basin is a locally applicable consideration for the District. As discussed in Section 6.2.3 of this Plan, the long-term impacts of SGMA implementation in the Basin are still uncertain. However, it is the intent of the planned projects and management actions (P/MAs) to stabilize water levels as needed and continue the sustainable operation of the Basin. Pumping fees or similar restrictions (i.e., allocations) are not anticipated in the Basin. Should demand management P/MAs be required to address future shortfalls, actions will likely be focused on management of agricultural water use, as opposed to M&I pumping. If such actions are implemented, Cal Water will consider them as a part of its future supply planning efforts. Further description of the legal protections of M&I groundwater pumping rights and groundwater sufficiency are detailed in Section 7.1.1.

**Table 7-5** provides a comparison of the water supply sources available to the District with the total projected water use for an assumed drought period of 2026 through 2030. This includes current climate change conditions. It should be noted that the supply values shown in the table do not represent the total supply available to the District in a given year, but rather reflect the fact that the available groundwater supplies are sufficient to meet the demands as needed.

Although water shortage conditions are not expected to arise due to drought, Cal Water has developed a Water Shortage Contingency Plan ([WSCP]; **Appendix G**) to address potential water shortage conditions resulting from any cause (e.g., droughts, impacted distribution system infrastructure, regulatory-imposed shortage restrictions, etc.). The WSCP identifies a variety of actions that Cal Water will implement to reduce demands and further ensure supply reliability at various levels of water shortage.

**Table 7-5. Five-Year Drought Risk Assessment Tables (DWR Table 7-5)**

2026		Total
Total Water Use	(AF)	1,330
Total Supplies	(AF)	1,330
Surplus/Shortfall w/o WSCP Action		0
<b>OPTIONAL: Planned WSCP Actions (use reduction and supply augmentation)</b>		
WSCP - supply augmentation benefit	(AF)	
WSCP - use reduction savings benefit	(AF)	
Revised Surplus/(shortfall)		

2027		Total
Total Water Use (AF)	(AF)	1,319
Total Supplies (AF)	(AF)	1,319
Surplus/Shortfall w/o WSCP Action		0
<b>Planned WSCP Actions (use reduction and supply augmentation)</b>		
WSCP - supply augmentation benefit (AF)	(AF)	
WSCP - use reduction savings benefit (AF)	(AF)	
Revised Surplus/(shortfall)		

2028		Total
Total Water Use (AF)	(AF)	1,172
Total Supplies (AF)	(AF)	1,172
Surplus/Shortfall w/o WSCP Action		0
<b>Planned WSCP Actions (use reduction and supply augmentation)</b>		
WSCP - supply augmentation benefit (AF)	(AF)	
WSCP - use reduction savings benefit (AF)	(AF)	
Revised Surplus/(shortfall)		

2029		Total
Total Water Use (AF)	(AF)	1,163
Total Supplies (AF)	(AF)	1,163
Surplus/Shortfall w/o WSCP Action		0
<b>Planned WSCP Actions (use reduction and supply augmentation)</b>		
WSCP - supply augmentation benefit (AF)	(AF)	
WSCP - use reduction savings benefit (AF)	(AF)	
Revised Surplus/(shortfall)		

2030		Total
Total Water Use (AF)	(AF)	1,153
Total Supplies (AF)	(AF)	1,153
Surplus/Shortfall w/o WSCP Action		0
<b>Planned WSCP Actions (use reduction and supply augmentation)</b>		
WSCP - supply augmentation benefit (AF)	(AF)	
WSCP - use reduction savings benefit (AF)	(AF)	
Revised Surplus/(shortfall)		

**Notes:**

(a) In general, the District has sufficient supplies to meet demands in all year types through 2030 and it is not anticipated that WSCP actions will be required in the District during the drought period. However, during state, regional, or extreme circumstances, the WSCP would be implemented to reduce demand.

## Chapter 8

### Water Shortage Contingency Planning

#### CWC § 10640

*(a) Every urban water supplier required to prepare a plan pursuant to this part shall prepare its plan pursuant to Article 2 (commencing with Section 10630). The supplier shall likewise periodically review the plan as required by Section 10621, and any amendments or changes required as a result of that review shall be adopted pursuant to this article.*

*(b) Every urban water supplier required to prepare a water shortage contingency plan shall prepare a water shortage contingency plan pursuant to Section 10632. The supplier shall likewise periodically review the water shortage contingency plan as required by paragraph (10) of subdivision (a) of Section 10632 and any amendments or changes required as a result of that review shall be adopted pursuant to this article.*

The Water Shortage Contingency Plan (WSCP) for the California Water Service (Cal Water) Dixon District (also referred to herein as “District”) is included in this Urban Water Management Plan (UWMP) as **Appendix G**. The WSCP serves as a standalone document to be engaged in the case of a water shortage event, such as a drought or supply interruption, and defines specific policies and actions that will be implemented at various Shortage Level scenarios. The primary objective of the WSCP is to ensure that the District has in place the necessary resources and management responses needed to protect health and human safety, minimize economic disruption, and preserve environmental and community assets during water supply shortages and interruptions.

Consistent with California Water Code (CWC) §10632, the WSCP includes six Shortage Levels to address shortage conditions ranging from up to 10 percent to greater than 50 percent shortage, identifies a suite of demand mitigation measures for the District to implement at each Shortage Level, and identifies procedures for the District to annually assess whether or not a water shortage is likely to occur in the coming year, among other things.

A summary of the key elements of the WSCP including water Shortage Levels and demand-reduction actions is shown in **Table 8-1**, **Table 8-2**, and **Table 8-3**. Additional details are provided in **Appendix G**.

**Table 8-1. Water Shortage Contingency Plan Levels (DWR Table 8-1)**

<input checked="" type="checkbox"/>	Check the box if the Supplier uses the Standard six levels of water shortage. Proceed to the next table.		
Standard Shortage Levels	Percent Shortage Range	Suppliers Shortage Levels	Percent Shortage Range
1	Up to 10%		
2	Up to 20%		
3	Up to 30%		
4	Up to 40%		
5	Up to 50%		
6	>50%		
<b>Notes:</b>			

**Table 8-2. Supply Augmentation and Other Actions (DWR Table 8-2)**

<input checked="" type="checkbox"/>	Is the Supplier completing this table using the standard six levels? (yes/no)			
Shortage Level	Supply Augmentation Methods and Other Actions by Water Supplier	How much is this going to reduce the shortage gap?		Additional Explanation or Reference (OPTIONAL)
		Volume or Percentage	Shortage Gap Reduction Value	
			AF	
See note (a)	See note (a)	See note (a)	See note (a)	See note (a)
<b>Notes:</b>				
(a) Cal Water evaluates water supply augmentation projects on an on-going basis. At this time, Cal Water does not have supply augmentation projects planned specifically to address water shortage conditions.				

**Table 8-3. Demand Reduction Actions (DWR Table 8-3)**

X Is the Supplier completing this table using the standard six levels?					
Shortage Level	Demand Reduction Actions	How much is this going to reduce the shortage gap?		Additional Explanation or Reference (OPTIONAL)	Penalty, Charge, or Other Enforcement?
		Volume or Percentage	Shortage Gap Reduction Value		
			AF		
1	Other	Percentage	10%	1. Landscape - Limit landscape irrigation to specific times. 2. Other - Customers must repair leaks, breaks, and malfunctions in a timely manner. 3. Landscape - Restrict or prohibit runoff from landscape irrigation. 4. Prohibit application of potable water to outdoor landscapes within 48 hours of measurable rainfall. ( <i>Landscape - Other landscape restriction or prohibition</i> ). 5. Other - Prohibit use of potable water for washing hard surfaces. 6. Other – Require automatic shut off hoses ( <i>Other - Require automatic shut off hoses</i> ). 7. CII - Lodging establishments must offer opt out of linen service. 8. CII - Restaurants may only serve water upon request. 9. No watering of landscape of newly constructed homes and buildings in a manner inconsistent with regulations or other requirements established by the California Building Standards Commission, the Department of Housing and Community Development, or other State agency ( <i>Landscape - Other landscape restriction or prohibition</i> ). 10. Prohibit Potable Water Use for Decorative Water Features that do not Recirculate Water ( <i>Water Features - Restrict water use for decorative water features, such as fountain</i> ).	Yes

X Is the Supplier completing this table using the standard six levels?					
Shortage Level	Demand Reduction Actions	How much is this going to reduce the shortage gap?		Additional Explanation or Reference (OPTIONAL)	Penalty, Charge, or Other Enforcement?
		Volume or Percentage	Shortage Gap Reduction Value		
			AF		
1	Other	--	--	1. Expand Public Information Campaign. 2. Water Bill Inserts ( <i>Improve Customer Billing</i> ). 3. Promote online water waste reporting ( <i>Expand Public Information Campaign</i> ). 4. Expand Rebates or Giveaways of Plumbing Fixtures and Devices. ( <i>Provide Rebates on Plumbing Fixtures and Devices</i> ). 5. Expand Rebates for Landscape irrigation Efficiency ( <i>Provide Rebates for Landscape irrigation Efficiency</i> ). 6. Expand CII Water Use Surveys ( <i>Offer Water Use Surveys</i> ). 7. Expand Res Water Use Surveys ( <i>Offer Water Use Surveys</i> ).	No
2	Other	Percentage	20%	1. Continue with Shortage Level 1 restrictions and prohibitions except where superseded by more stringent restrictions and prohibitions. 2. Landscape - Limit landscape irrigation to specific days. <sup>(b)</sup> 3. CII - Prohibit the use of non-recirculating systems in all new conveyer car wash and commercial laundry systems ( <i>CII – Other CII restriction or prohibition</i> ). 4. Prohibit the use of single pass cooling systems in new connections ( <i>Other</i> ).	Yes
2	Other	--	--	1. Continue with Shortage Level 1 actions except where superseded by more stringent actions. 2. Water Efficiency Workshops, Public Events ( <i>Other</i> ).	Yes

X Is the Supplier completing this table using the standard six levels?					
Shortage Level	Demand Reduction Actions	How much is this going to reduce the shortage gap?		Additional Explanation or Reference (OPTIONAL)	Penalty, Charge, or Other Enforcement?
		Volume or Percentage	Shortage Gap Reduction Value		
			AF		
3	Other	Percentage	30%	1. Continue with Shortage Level 2 restrictions and prohibitions except where superseded by more stringent restrictions and prohibitions. 2. Other - Prohibit use of potable water for construction and dust control. 3. Prohibit use of potable water for street washing ( <i>Other</i> ) 4. Prohibit Filling Ornamental Lakes or Ponds ( <i>Other water feature or swimming pool restriction</i> ).	Yes
3	Other	--	--	1. Continue with Shortage Level 2 actions except where superseded by more stringent actions. 2. Home or Mobile Water Use Reports ( <i>Expand Public Information Campaign</i> ). 3. Decrease Frequency and Length of Line Flushing ( <i>Decrease Line Flushing</i> ). 4. Reduce System Water Loss. 5. Increase Water Waste Patrols/Enforcement ( <i>Increase Water Waste Patrols</i> ). 6. Implement Drought Rate Structure and Customer Water Budgets (Res)( <i>Implement or Modify Drought Rate Structure or Surcharge</i> ). 7. Implement Drought Rate Structure and Customer Water Budgets (CII) ( <i>Implement or Modify Drought Rate Structure or Surcharge</i> ).	Yes

X	Is the Supplier completing this table using the standard six levels?				
Shortage Level	Demand Reduction Actions	How much is this going to reduce the shortage gap?		Additional Explanation or Reference (OPTIONAL)	Penalty, Charge, or Other Enforcement?
		Volume or Percentage	Shortage Gap Reduction Value		
			AF		
4	Other	Percentage	40%	1. Continue with Shortage Level 3 restrictions and prohibitions except where superseded by more stringent restrictions and prohibitions. 2. Prohibit vehicle washing except with recirculated water or low-volume systems ( <i>Other - Prohibit vehicle washing except at facilities using recycled or recirculating water</i> ). 3. Prohibit use of water for recreational purposes such as water parks and the filling of pools ( <i>Other water feature or swimming pool restriction</i> ).	Yes
5	Other	Percentage	50%	1. Continue with Shortage Level 4 restrictions and prohibitions except where superseded by more stringent restrictions and prohibitions. 2. Require net zero demand increase on new water service connections ( <i>Moratorium or Net Zero Demand Increase on New Connections</i> ). 3. Prohibit single-pass cooling systems ( <i>Other</i> ).	Yes
5	Other	--	--	1. Continue with Shortage Level 4 actions except where superseded by more stringent actions. 2. Require Pool Covers ( <i>Pools and Spas - Require covers for pools and spas</i> ).	Yes

X Is the Supplier completing this table using the standard six levels?					
Shortage Level	Demand Reduction Actions	How much is this going to reduce the shortage gap?		Additional Explanation or Reference (OPTIONAL)	Penalty, Charge, or Other Enforcement?
		Volume or Percentage	Shortage Gap Reduction Value		
			AF		
	Other	Percentage	60%	1. Continue with Shortage Level 5 restrictions and prohibitions except where superseded by more stringent restrictions and prohibitions. 2. Moratorium on new water service connections ( <i>Moratorium or Net Zero Demand Increase on New Connections</i> ). 3. Landscape - Prohibit all landscape irrigation.	Yes
<b>Notes:</b> (a) In certain cases water use restrictions and consumption reduction actions implemented by Cal Water are not specifically called out in DWR’s provided demand reduction actions list. The most appropriate DWR provided demand reduction action is included in italics in parenthesis. (b) Watering restricted to no more than 3 days/week in Shortage Level 2 and Shortage Level 3; no more than 2 days/week in Shortage Level 4; no more than 1 day/week in Shortage Level 5. (c) Residential water budgets of up to 30% for Shortage Level 3, up to 40% for Shortage Level 4, up to 50% for Shortage Level 5, up to 60% for Shortage Level 6. (d) CII water budgets of up to 10% for Shortage Level 3, up to 20% for Shortage Level 4, up to 30% for Shortage Levels 5 and 6. (e) Estimates are not strictly additive because multiple actions may target the same end uses or customer behaviors, and combined implementation may result in overlapping or reinforcing effects. For example, irrigation restrictions and drought rate structures and customer water budgets both reduce outdoor water use and may achieve similar savings when implemented together, whereas public information and enforcement actions may improve compliance of other water use restrictions. (f) The actions listed above were modeled using the Drought Response Tool (DRT), many of which actions are implemented across a number of Shortage Levels, some at increasing implementation levels, and presented in the District’s 2025 Water Shortage Contingency Plan (WSCP). The estimated total percent savings with implementation of all demand reductions in: <ul style="list-style-type: none"> <li>Shortage Level 1 is 10%, Shortage Level 2 is 20%, Shortage Level 3 is 30%, Shortage Level 4 is 40%, Shortage Level 5 is 50%, Shortage Level 6 is 60%.</li> </ul>					



## Chapter 9

### Demand Management Measures

**CWC § 10631 (e)**

*Provide a description of the supplier's water demand management measures. This description shall include all of the following:*

*(1) (A) For an urban retail water supplier, as defined in Section 10608.12, a narrative description that addresses the nature and extent of each water demand management measure implemented over the past five years. The narrative shall describe the water demand management measures that the supplier plans to implement to achieve its water use targets pursuant to Section 10608.20.*

*(B) The narrative pursuant to this paragraph shall include descriptions of the following water demand management measures:*

*(i) Water waste prevention ordinances.*

*(ii) Metering.*

*(iii) Conservation pricing.*

*(iv) Public education and outreach.*

*(v) Programs to assess and manage distribution system real loss.*

*(vi) Water conservation program coordination and staffing support.*

*(vii) Other demand management measures that have a significant impact on water use as measured in gallons per capita per day, including innovative measures, if implemented.*

This chapter describes the demand management measures (DMMs) implemented by California Water Service (Cal Water) in its Dixon District (also referred to herein as the "District") to promote efficient water use and support long-term water supply reliability. These measures are organized in accordance with the categories identified in the Urban Water Management Planning Act and reflect both longstanding conservation practices and more recent programmatic developments.

Demand management plays a central role in Cal Water's resource planning strategy. As discussed in earlier chapters, historical reductions in per capita water use in the District have been driven by a combination of metering, conservation-oriented rate design, customer programs, and passive savings associated with plumbing codes and appliance efficiency standards. The measures described in this chapter build on those foundations and represent the primary tools available to manage future demand growth.

This chapter also provides important context for the State's Making Conservation a California Way of Life (MCCWL) regulation, which establishes new water use efficiency standards and performance requirements that extend beyond the Senate Bill (SB) X7-7 framework. While compliance with MCCWL-related Urban Water Use Objectives (UWUOs) is addressed

in Chapter 5, many of the actions required to support future compliance—particularly expanded conservation programs, enhanced reporting, and implementation of Commercial, Industrial, and Institutional (CII) performance measures—are described in this chapter.

For public utilities such as Cal Water that are regulated by the California Public Utilities Commission (CPUC), the scope and pace of demand management implementation are closely tied to authorization by the CPUC. Accordingly, this chapter describes both the measures currently in place and the institutional, staffing, and regulatory considerations that influence Cal Water’s ability to expand conservation activities in the Dixon District over time. This chapter has the following sections:

- 9.1 Water Waste Prevention Ordinances
- 9.2 Metering
- 9.3 Conservation Pricing
- 9.4 Customer Conservation Programs
- 9.5 Water Loss Management
- 9.6 Water Conservation Program Staffing
- 9.7 Summary and Implementation Considerations

## 9.1 Water Waste Prevention Ordinances

Cal Water’s authority to enforce water waste prevention measures and water use restrictions is established and overseen by the CPUC through Rule 14.1 or Schedule 14.1. In addition, local governments within Cal Water districts may adopt ordinances regulating water use. Cal Water coordinates its water waste prevention efforts with applicable local jurisdictions. For the Dixon District, this coordination includes the City of Dixon and Solano County.

CPUC Rule 14.1 defines the District’s Water Shortage Contingency Plan (WSCP; see **Appendix G**), including, but not limited to, permanent prohibitions on water waste and restrictions on water use. Prohibited water waste practices include, but are not limited to, the following:

- Use of potable water through a broken or defective plumbing fixture or irrigation system after Cal Water has provided written notice to repair the condition and the customer has failed to complete repairs within seven business days of receipt of the notice.
- Application of potable water to landscapes in a manner that results in runoff onto adjacent property, non-irrigated areas, sidewalks, roadways, parking lots, or structures.

- Use of a hose to wash vehicles—including cars, trucks, buses, boats, aircraft, and trailers—unless the hose is equipped with a shut-off nozzle or similar device that immediately stops water flow when not in use.

During water shortage conditions, Schedule 14.1 also authorizes Cal Water to implement additional water use restrictions and penalties, which may include the following:

- Limitations on outdoor irrigation, including restrictions on time of day and frequency of watering.
- Requirements to repair leaks, breaks, or malfunctions within five business days of written notification by Cal Water.
- Application of potable water to driveways, sidewalks, and other hardscapes.
- Use of potable water in water features unless the feature operates as a recirculating system.
- Application of potable water to outdoor landscapes during and within 48 hours following measurable rainfall.
- Serving drinking water in eating or drinking establishments unless requested by the customer.
- Irrigation of ornamental landscaping on public street medians.
- Irrigation of landscapes at newly constructed homes or buildings using potable water in a manner inconsistent with requirements established by the California Building Standards Commission or the Department of Housing and Community Development.
- Requirements for hotels and motels to provide guests with the option to decline daily laundering of towels and linens, with clear and prominent notice provided in each guest room.
- Limitations on filling ornamental lakes or ponds.
- Use of potable water for street cleaning, except for initial wash-down associated with construction activities.
- Use of potable water for construction-related purposes, such as dust control or backfill consolidation, unless no alternative water source or method is available.

These measures form a key component of the District’s overall demand management strategy and support compliance with state water conservation regulations.

## 9.2 Metering

### CWC § 526 (a)

*Notwithstanding any other provision of law, an urban water supplier that, on or after January 1, 2004, receives water from the federal Central Valley Project under a water service contract or subcontract ... shall do both of the following:*

*(1) On or before January 1, 2013, install water meters on all service connections to residential and nonagricultural commercial buildings constructed prior to January 1, 1992, located within its service area.*

*(2) On and after March 1, 2013, or according to the terms of the Central Valley Project water contract in operation, charge customers for water based on the actual volume of deliveries, as measured by a water meter.*

### CWC § 527 (a)

*(a) An urban water supplier that is not subject to Section 526 shall do both of the following:*

*(1) Install water meters on all municipal and industrial service connections located within its service area on or before January 1, 2025.*

All services in the Dixon District are metered. Meters are read monthly and are subject to routine maintenance and calibration to ensure accuracy. Customers are billed monthly based on metered water use.

Cal Water is also piloting automatic meter reading (AMR) and advanced metering infrastructure (AMI) in several of its districts. If deployed more broadly in the future, AMI would enhance the District's ability to detect leaks and other system issues and to notify customers of potential problems. AMI would also allow the provision of more timely and detailed water use information, supporting customer engagement as well as enabling customers to more closely monitor their own water usage and take appropriate actions to improve their water use efficiency.

## 9.3 Conservation Pricing

The CPUC reviews and authorizes the Dixon District's water rates in a General Rate Case (GRC) every three years. Currently, the District uses a four-tier increasing block rate design for residential water use and a single-tier uniform rate design for non-residential use. The District provides rate assistance to lower income households through its Customer Assistance Program (CAP).

## 9.4 Customer Conservation Programs

Cal Water has a long-standing water-use efficiency program designed to reduce water use across residential and non-residential customer classes. The program includes landscape conversion

incentives, irrigation equipment rebates, indoor device rebates, and customer education resources. Core programs available to residential customers are summarized below. Additional programs are offered to non-residential customers, and program offerings may be adjusted over time based on district-specific needs and program performance.

#### 9.4.1 Current Customer Conservation Programs

Cal Water currently offers residential customers a range of water-use efficiency rebates, support services, and educational resources, including the following:

##### **Turf Replacement**

- Turf replacement rebates of up to \$3 per square foot for removal of turf and conversion to California-friendly, low-water-use landscaping with efficient irrigation.

##### **Irrigation Equipment Rebates**

- Smart Landscape Tune-Up: A free, site-specific irrigation assessment that includes approved repairs to existing irrigation systems and installation of high-efficiency sprinkler nozzles and smart irrigation controllers, as appropriate.
- Smart irrigation controllers: Rebates of \$125 per controller for weather- and soil-based irrigation controllers that adjust watering schedules based on site conditions.
- High-efficiency sprinkler nozzles: Rebates of \$5 per nozzle for replacing conventional spray nozzles with high-efficiency nozzles that apply water more uniformly.

##### **Indoor Device Rebates**

- High-efficiency clothes washers: Rebates of \$150 per washer for eligible models that use substantially less water than standard washers.
- MaP Premium high-efficiency toilets: Rebates of \$50 per toilet for models using 1.1 gallons per flush or less.
- Conservation kits: Free kits containing water-saving plumbing devices, such as high-efficiency showerheads, faucet aerators, hose nozzles, leak detection tablets, and educational materials.

##### **Online Resources**

- Cal Water maintains a suite of online water-use efficiency resources to help customers understand and adopt water-saving practices.

## School Education

- Cal Water’s school education program includes the Aqua Adventures, A Splash of Creativity, H2Oath, and Water Smart Grant programs. Cal Water’s Teacher Toolkit provides teachers with practical guidance and teaching rubrics for helping students learn about resource sustainability and the importance of using water wisely.

These programs are implemented through a combination of in-house staff and contracted service providers. Cal Water conducts ongoing outreach and customer engagement to promote awareness and participation. In addition, customer service representatives are trained to assist customers with high water use or billing concerns by directing them to appropriate conservation programs and educational resources.

### 9.4.2 Future Customer Conservation Programs

Cal Water understands that its conservation programming must be adapted to the new MCCWL regulatory requirements. For instance, meeting the rigorous outdoor water use standards will require transitioning substantial amounts of turf area to more water efficient landscaping. Therefore, outdoor conservation measures, including turf replacement incentives and support services, will need to be prioritized to drive future water savings. While targeted indoor efficiency measures have also been retained to maximize water savings, the focus remains heavily on outdoor improvements.

Achieving continued water savings in the District requires a rapid market transformation towards landscape efficiency. Typically, market transformations can span decades as they require shifting both consumer behaviors and supply chain dynamics, even with incentives. Early adopters have already made necessary adjustments, but many property owners have not yet embraced this change. Landscape transformation represents a significant departure from traditional practices, often perceived as complex and undesirable by many. Overcoming this resistance and encouraging participation will be challenging.

A crucial aspect is convincing customers that embracing landscape efficiency enhances, rather than detracts from, the value of their property. The traditional view equates lush, green lawns with success and economic status. Therefore, changing this deep-seated perception to appreciate the aesthetics and benefits of water-sustainable landscaping is essential.

Given the urgency to transform landscapes without the luxury of time, Cal Water faces several challenges that require:

- Robust customer education.
- High levels of customer motivation.

- Accessibility to landscape design and plant knowledge.
- Considerable labor investment.
- Significant financial resources.

To increase customer engagement, Cal Water's programs must offer compelling incentives, clear communication about the required processes, and substantial support to guide customers through these changes. **Table 9-1** outlines the key barriers to successful deployment of landscape transformation programs.

**Table 9-1. Barriers and Customer Requirements of Landscape Transformation Programs**

Landscape Transformation Barriers	Customer Requirements
<ul style="list-style-type: none"> <li>• Customers lack motivation to reduce their water use.</li> <li>• Most customers are unaware of, or overwhelmed by, landscape efficiency programs.</li> <li>• Landscape efficiency solutions must be “customized” for each property.</li> <li>• Water suppliers do not currently have a deep understanding of their customers.</li> <li>• Agencies do not possess the resources to uniquely target and engage their customers.</li> </ul>	<ul style="list-style-type: none"> <li>• Customers desire to have a beautiful landscape.</li> <li>• Each customer has a different vision of what comprises landscape beauty.</li> <li>• Most customers have considered converting their lawn, but they need help to accomplish this.</li> <li>• Customers confirmed that design support is the most important need.</li> <li>• Incentives are necessary to pull the trigger on converting their lawn.</li> <li>• There are a number of misperceptions that disconnect the customer from their actual water usage. They believe most water is used indoors; that they already have efficient equipment; and saving money is the main driver.</li> </ul>

Many water users currently do not prioritize landscape water efficiency, lacking both understanding of its urgency and motivation to implement drastic changes.

Cal Water's strategy is to significantly enhance education about the need for outdoor water use reduction and how to achieve it. Fortunately, studies indicate a growing customer interest in aesthetically pleasing, water-efficient landscaping. Many property owners consider turf removal but require assistance to proceed. Time and cost are significant barriers.

To effectively encourage this shift, Cal Water must not only convince customers of the necessity of these changes but also provide them with extensive support—from design assistance to

continuous engagement and resources. Additionally, incentives must be compelling enough to convince customers of the value of investing in these changes.

Success will depend on expanding education, services, and incentives to accelerate market transformation. To support this enhanced program structure, Cal Water must accordingly increase its staff, marketing efforts, operational support, and budget to meet these elevated service demands.

In addition to turf replacement, Cal Water has identified a suite of customer conservation programs with demonstrated water-saving potential and meaningful market impact. Together, these measures represent a comprehensive portfolio that—subject to adequate staffing and funding—is intended to support compliance with the MCCWL regulation. The measures summarized in **Table 9-2** are representative of Cal Water’s current conservation approach. As program performance is evaluated and technologies evolve, Cal Water may refine this portfolio by modifying, replacing, or adding measures to ensure continued program effectiveness.

**Table 9-2. Representative Conservation Measures with Significant Savings Potential**

Conservation Measure	Remaining Potential	Reasoning for Selecting
<b>Home Water Budgets</b>	All single-family homes	<ul style="list-style-type: none"> <li>Identifies customers with inefficient usage, thus allowing better targeting of programs and assistance.</li> <li>Provides a foundational step in educating customers with powerful and personal information that identifies site-specific efficiency opportunities.</li> <li>As an educational tool alone, shown to reduce water use.</li> </ul>
<b>Outdoor Efficiency</b>		
<b>Turf Replacement</b>	All properties with remaining turf	<ul style="list-style-type: none"> <li>Required measure for meeting landscape and irrigation standards.</li> <li>Huge remaining opportunity.</li> <li>Long lifespan measure.</li> </ul>
<b>Sprinkler Tune-up</b>	All properties with remaining turf	<ul style="list-style-type: none"> <li>Nearly all irrigation systems need repair.</li> <li>Repairs are necessary before efficiency upgrades are made otherwise new products will not work as designed.</li> <li>High customer demand.</li> </ul>

Conservation Measure	Remaining Potential	Reasoning for Selecting
<b>Smart Controllers</b>	All properties with irrigation	<ul style="list-style-type: none"> <li>• High customer receptivity due to technical aspect of device.</li> <li>• Reduces overwatering by providing the appropriate amount of water based on the local weather.</li> </ul>
<b>Pressure Regulating Spray Heads</b>	All properties with popup spray heads	<ul style="list-style-type: none"> <li>• Millions of non-pressure regulating spray heads.</li> <li>• Reduces water use due to high water pressure and low head drainage.</li> </ul>
<b>High Efficiency Sprinkler Nozzles</b>	All properties with popup spray heads	<ul style="list-style-type: none"> <li>• Millions of high flow nozzles are available for retrofit.</li> <li>• Solution for customers electing to keep turf.</li> <li>• Reduces runoff.</li> <li>• High cost effectiveness.</li> <li>• Generally easy retrofit.</li> </ul>
<b>Indoor Efficiency</b>		
<b>Premium Efficiency Toilets</b>	Nearly 50% of existing fixtures are 1.6 GPF or above	<ul style="list-style-type: none"> <li>• Reliable 25-year life of water savings.</li> <li>• Easy retrofit.</li> </ul>
<b>High Efficiency Clothes Washers</b>	All single-family homes and multi-family in-unit washers	<ul style="list-style-type: none"> <li>• Customers prefer high efficiency models.</li> <li>• Easy to administer.</li> <li>• Washers have 10–12-year life</li> </ul>

### 9.4.3 CII Performance Measures

The MCCWL regulation requires urban retail water suppliers to implement a suite of actions intended to improve CII water use efficiency. These actions include converting certain mixed-use meters (MUMs) serving large landscaped areas to dedicated irrigation meters (DIMs), installing approved in-lieu technologies where DIM installation is not pursued, and implementing a broad set of CII best management practices (BMPs). The regulations also require suppliers to classify all CII accounts using a prescribed framework and to identify and catalog large, disclosable buildings.

Importantly, implementation of CII Performance Measures is required regardless of whether a supplier is otherwise projected to comply with its UWUO. As a result, compliance with these requirements will require substantial staffing, technical, and financial resources independent of UWUO compliance outcomes. The following subsections summarize the primary CII Performance Measure requirements applicable to the Dixon District.

### **DIM or In-Lieu Technology Installation**

The MCCWL regulation requires Cal Water to install DIMs or implement approved in-lieu technologies at all CII sites served by MUMs that irrigate one-half acre or more of landscaped area.

Installation of DIMs involves significant cost and logistical complexity for both Cal Water and its customers. Activities include site assessments, permitting, meter and backflow device installation, account setup, integration of additional meter reads, and ongoing maintenance and calibration. In recognition of these challenges, the regulations allow suppliers to satisfy the requirement through adoption of approved in-lieu technologies.

Approved in-lieu technologies include the following:

1. Water budget–based rate structures
2. Water budget–based management approaches not tied to rates
3. Hardware upgrades that enhance irrigation performance, including technologies that allow identification of outdoor water use, smart irrigation controllers, and pressure-regulated spray heads
4. Remote sensing technologies
5. Landscape plant palette transformation programs, including green infrastructure such as swales or rain gardens that reduce irrigation demand
6. Other efficient water use technologies, subject to demonstration of improved water use efficiency

For sites utilizing in-lieu technologies, the regulations further require Cal Water to provide education and communication services, irrigation system maintenance support (including audits and testing), and site-specific irrigation scheduling guidance. As a result, Cal Water will be required to take on an active role in supporting irrigation management at CII sites with large, landscaped areas. In addition, Cal Water must calculate landscape water budgets for these sites using prescribed methodologies by June 30, 2029.

### **CII Account Classification**

The MCCWL regulation requires Cal Water to classify all CII accounts using a regulatory classification system that includes the U.S. Environmental Protection Agency’s (EPA’s) 19 ENERGY STAR Portfolio Manager property types, along with additional categories for water recreation facilities, vehicle washes, and commercial laundries. Following classification, Cal Water must identify customers whose water use falls within the 80<sup>th</sup> and 97.5<sup>th</sup> percentiles within each category to support targeted delivery of BMPs.

## **CII Disclosable Buildings**

Under the MCCWL regulation, Cal Water is required to identify all disclosable buildings within its service area and provide water use reports upon request. Disclosable buildings are defined as non-manufacturing buildings exceeding 50,000 square feet.<sup>33</sup> Identification of these buildings was required by January 1, 2025, and by January 1 every year thereafter.

Upon request by a building owner or authorized agent, Cal Water must provide water use reports compatible with the EPA's ENERGY STAR Portfolio Manager Data Exchange Services. Reports must include detailed monthly and aggregated usage data for at least the preceding 12 months for each meter serving the building.

Compliance with this requirement will require development of new processes and reporting systems capable of integrating billing data with EPA reporting platforms. Meeting these requirements will necessitate coordinated effort across Cal Water's conservation, billing, and information technology departments.

## **CII BMPs**

The MCCWL regulations require implementation of CII BMPs for customers in the highest water-use percentiles. Cal Water must implement one BMP from each category (five total) for customers in the 80<sup>th</sup> percentile of usage and two BMPs from each of five categories (ten total) for customers in the 97.5<sup>th</sup> percentile of usage. The categories of BMPs include outreach and education, incentives, landscape practices, collaboration and coordination, and operational practices, with a range of eligible actions specified in the regulations.

Selection and implementation of BMPs will be guided by customer characteristics, site conditions, and feasibility, and will require substantial program oversight, customer coordination, and tracking.

## **CII Performance Measures and UWUO Compliance**

While the CII Performance Measures are an integral component of the MCCWL regulatory framework, water savings achieved through these measures do not directly contribute toward meeting the District's UWUO reduction targets. Under the regulations, CII Performance Measures contribute to UWUO compliance only through reductions in water use measured by DIMs. Cal Water does not currently utilize a DIM meter classification, and DIM water use is therefore not a component of the District's UWUO calculation. As a result, although implementation of CII Performance Measures is mandatory and expected to yield water use

---

<sup>33</sup> For the precise definition of a disclosable building, see California Code of Regulations, title 20, section 1683.

efficiency benefits, the associated water savings will not be credited toward UWUO compliance for the District.

## 9.5 Water Loss Management

Cal Water conducts annual distribution system water loss audits using the American Water Works Association (AWWA) Free Water Audit Software and reports the results to the California Department of Water Resources (DWR).<sup>34</sup>

To guide ongoing water loss management, Cal Water has developed a Water Loss Control Compliance Plan and a Water Loss Control Policy. These documents provide a framework for:

- Meeting current and future CPUC and state water loss standards and regulatory requirements;
- Improving audit data quality and validation scores; and
- Identifying and implementing cost-effective water loss control actions.

Cal Water has also conducted a comprehensive assessment comparing each district's current and projected distribution system water loss to applicable water loss standards. The results show that the Dixon District's distribution system loss rates currently exceed the state-established efficient water loss standards applicable to the District pursuant to SB 555 by 45 to 50 percent. Achieving the necessary reductions in real water loss will depend on Cal Water's ability to implement water loss management programs in the District. For public utilities regulated by the CPUC, expansion of water loss management programs necessary to achieve reductions require CPUC authorization. Accordingly, future compliance with the water loss component of the MCCWL regulation for the District will depend on timely approval of expanded water loss management programs and related measures necessary to meet the state water loss standards.

## 9.6 Water Conservation Program Staffing

Cal Water's Conservation Department is currently staffed by nine full-time equivalent (FTE) positions. In light of mandated UWUO reductions and the extensive reporting and performance requirements associated with the MCCWL regulation, Cal Water has identified a need to expand its conservation program staffing.

While the use of consultants could provide short-term support, the ongoing and long-term nature of the regulatory requirements makes exclusive reliance on temporary staffing impractical. In particular, the data analysis, program tracking, and reporting obligations associated with the

---

<sup>34</sup> Completed water audits may be accessed at: <https://wuedata.water.ca.gov/>

MCCWL framework require sustained institutional knowledge and continuity that are best supported through permanent staff.

Cal Water’s staffing strategy therefore emphasizes strengthening internal capacity to manage conservation programs, lead outreach and customer engagement efforts, support customers, oversee ongoing CII activities, and fulfill reporting and compliance obligations. Consultants are expected to continue to play a targeted role by providing short-term, specialized expertise as needed, allowing flexibility while maintaining a strong in-house program foundation.

Consistent with this strategy, Cal Water has proposed in its 2024 GRC an increase in Conservation Department staffing from nine to 15 positions. The six requested positions and their primary responsibilities are summarized in **Table 9-9-3**. At the time this UWMP was prepared, a final decision in the 2024 GRC had not yet been issued. As a result, it remains uncertain whether the requested staffing increases necessary to support compliance with state conservation requirements will be authorized.

**Table 9-3. Proposed New Conservation Staff Positions**

New Position	Responsibilities
Conservation Manager	<ul style="list-style-type: none"> <li>• Program development/implementation/management</li> <li>• Budgeting</li> <li>• Staff oversight</li> </ul>
Regional Conservation Coordinator (2 positions)	<ul style="list-style-type: none"> <li>• Regional program implementation</li> <li>• District coordination</li> <li>• Customer engagement</li> </ul>
Water Resource Sustainability Analyst	<ul style="list-style-type: none"> <li>• Program tracking/analysis</li> <li>• Compliance assessment/reporting</li> <li>• Data management</li> </ul>
Water Resource Sustainability Assistant	<ul style="list-style-type: none"> <li>• Data entry</li> <li>• Analysis support</li> <li>• Compliance reporting support</li> </ul>
Conservation Assistant	<ul style="list-style-type: none"> <li>• Program application/rebate processing</li> <li>• Customer assistance</li> <li>• Data entry/processing</li> </ul>

## 9.7 Summary and Implementation Considerations

Cal Water has developed and implemented a comprehensive suite of DMMs in the Dixon District that address each category identified in the Urban Water Management Planning Act. These measures include water waste prevention and enforcement, universal metering, conservation-oriented pricing, public education and outreach, active management of distribution system water losses, and a broad portfolio of customer conservation programs. Collectively, these actions have

contributed to substantial long-term reductions in per capita water use and have positioned the District well relative to historical conservation benchmarks.

Looking ahead, demand management will play an increasingly important role in meeting the requirements of the MCCWL regulation and supporting water supply reliability. While many conservation-driven reductions are already embedded in the District’s baseline demand projections—through authorized programs, plumbing codes and appliance standards, and implementation of conservation rates—additional reductions are anticipated to be needed in future years as state efficiency standards become more stringent. As described in Chapter 5, achieving these reductions will require conservation efforts beyond those currently reflected in the baseline forecast.

For Cal Water, the ability to expand conservation programs, modify rate structures, and implement additional demand management actions is contingent on CPUC authorization. Program funding levels, staffing capacity, and implementation timelines are therefore closely linked to regulatory approval processes, including GRC proceedings. The measures described in this chapter represent both Cal Water’s current conservation framework and the foundation upon which expanded efforts may be built, subject to future CPUC decisions.

In this context, this chapter provides a practical and forward-looking assessment of how demand management measures support water use efficiency, regulatory compliance, and long-term resource reliability in the District, while acknowledging the institutional and regulatory factors that shape implementation over the UWMP planning horizon.

## Chapter 10

### Plan Adoption, Submittal, and Implementation

**CWC § 10621 (b)**

*Every urban water supplier required to prepare a plan pursuant to this part shall, at least 60 days before the public hearing on the plan required by Section 10642, notify any city or county within which the supplier provides water supplies that the urban water supplier will be reviewing the plan and considering amendments or changes to the plan. The urban water supplier may consult with, and obtain comments from, any city or county that receives notice pursuant to this subdivision.*

This chapter provides information on the public hearing, the adoption process for the Urban Water Management Plan (UWMP) and Water Shortage Contingency Plan (WSCP), the adopted UWMP and WSCP submittal process, Plan implementation, and the process for amending the adopted UWMP or WSCP. This chapter includes the following sections:

10.1 Inclusion of All 2025 Data

10.2 Notice of Public Hearing

10.3 Public Hearing and Adoption

10.4 Plan Submittal

10.5 Public Availability

10.6 Notification of Public Utilities Commission

10.7 Amending an Adopted UWMP or Water Shortage Contingency Plan

#### 10.1 Inclusion of All 2025 Data

This UWMP includes the water use and planning data for the entire calendar year of 2025, per the California Department of Water Resources' (DWR's) 2025 UWMP Guidebook.

## 10.2 Notice of Public Hearing

### **CWC § 10642**

*Each urban water supplier shall encourage the active involvement of diverse social, cultural, and economic elements of the population within the service area prior to and during the preparation of both the plan and the water shortage contingency plan. Prior to adopting either, the urban water supplier shall make both the plan and the water shortage contingency plan available for public inspection and shall hold a public hearing or hearings thereon. Prior to any of these hearings, notice of the time and place of the hearing shall be published within the jurisdiction of the publicly owned water supplier pursuant to Section 6066 of the Government Code. The urban water supplier shall provide notice of the time and place of a hearing to any city or county within which the supplier provides water supplies. Notices by a local public agency pursuant to this section shall be provided pursuant to Chapter 17.5 (commencing with Section 7290) of Division 7 of Title 1 of the Government Code. A privately owned water supplier shall provide an equivalent notice within its service area. After the hearing or hearings, the plan or water shortage contingency plan shall be adopted as prepared or as modified after the hearing or hearings.*

Prior to adopting the Plan, California Water Service (Cal Water) held a formal public hearing to present information on its Dixon District (also referred to herein as “District”) 2025 UWMP and WSCP on May 20, 2026, 6:30 PM.

Relevant entities were notified of the UWMP and WSCP review at least 60 days prior to the public hearing, including: (1) cities, counties, and Groundwater Sustainability Agencies (GSAs), and (2) the public. These entities were noticed again with the specific date, time and location of the hearing at least two weeks prior to the public hearing. The notice to the public, as specified in Government Code 6066, and letters to relevant agencies can be found in **Appendix B** and **Appendix C**, respectively.

### 10.2.1 Notice to Cities and Counties

#### **CWC § 10631 (a)** A plan shall be adopted in accordance with this chapter that shall do all of the following:

*Urban water suppliers shall coordinate with local or regional land use authorities to determine the most appropriate land use information, including, where appropriate, land use information obtained from local or regional land use authorities, as developed pursuant to Article 5 (commencing with Section 65300) of Chapter 3 of Division 1 of Title 7 of the Government Code.*

**Table 10-1** lists the cities and counties that were notified. Copies of these letters are provided in **Appendix B**.

**Table 10-1. Notification to Cities and Counties (DWR Table 10-1)**

City Name	60 Day Notice Drop Down (yes/no)	Notice of Public Hearing Drop Down (yes/no)
Add additional rows as needed		
City of Dixon	Yes	Yes
County Name Drop Down List	60 Day Notice Drop Down (yes/no)	Notice of Public Hearing Drop Down (yes/no)
Add additional rows as needed		
Solano County	Yes	Yes
<b>Notes:</b>		
(a) In addition to the Cities and Counties notified, Cal Water additionally notified the Solano County Water Agency, the Solano Irrigation District, and the five Groundwater Sustainability Agencies in the Solano Subbasin (i.e. the Solano Collaborative).		

10.2.2 Notice to the Public

Notification to the public and to cities and counties also provided instructions on how to view the 2025 UWMP and WSCP prior to the hearing, the revision schedule, and contact information of the UWMP and WSCP preparer. A copy of this notice is included in **Appendix C**.

10.3 Public Hearing and Adoption

**CWC § 10608.26**

*(a) In complying with this part, an urban retail water supplier shall conduct at least one public hearing to accomplish all of the following:*

- (1) Allow community input regarding the urban retail water supplier’s implementation plan for complying with this part.*
- (2) Consider the economic impacts of the urban retail water supplier’s implementation plan for complying with this part.*
- (3) Adopt a method, pursuant to subdivision (b) of Section 10608.20, for determining its urban water use target.*

**CWC § 10621 (b)**

*Every urban water supplier required to prepare a plan pursuant to this part shall, at least 60 days before the public hearing on the plan required by Section 10642, notify any city or county within which the supplier provides water supplies that the urban water supplier will be reviewing the plan and considering amendments or changes to the plan. The urban water supplier may consult with, and obtain comments from, any city or county that receives notice pursuant to this subdivision.*

The deadline for public comments on the UWMP and WSCP was May 23, 2026, three days after the public hearing. The final Plan was formally adopted by Cal Water's Vice President, Water Resources Planning and Sustainability on June 26, 2026, and was submitted to DWR within 30 days of approval. **Appendix I** presents a copy of the signed Resolution of Plan Adoption. **Appendix B** contains the following:

- Letters sent to and received from various agencies regarding this Plan, and
- Correspondence between Cal Water and participating agencies.

## 10.4 Plan Submittal

### **CWC § 10621 (f)**

*(1) Each urban water supplier shall update and submit its 2020 plan to the department by July 1, 2021.*

### **CWC § 10635 (c)**

*The urban water supplier shall provide that portion of its urban water management plan prepared pursuant to this article to any city or county within which it provides water supplies no later than 60 days after the submission of its urban water management plan.*

### **CWC § 10644 (a)**

*(1) An urban water supplier shall submit to the department, the California State Library, and any city or county within which the supplier provides water supplies a copy of its plan no later than 30 days after adoption. Copies of amendments or changes to the plans shall be submitted to the department, the California State Library, and any city or county within which the supplier provides water supplies within 30 days after adoption.*

*(2) The plan, or amendments to the plan, submitted to the department pursuant to paragraph (1) shall be submitted electronically and shall include any standardized forms, tables, or displays specified by the department.*

This UWMP and WSCP were submitted to DWR within 30 days of adoption and by the July 1, 2026 deadline. The submittal was done electronically through DWR's Water Use Efficiency Data Portal, an online submittal tool. The adopted UWMP and WSCP were also sent to the California State Library and to the cities and counties listed in **Table 10-1** no later than 30 days after adoption.

## 10.5 Public Availability

### **CWC § 10645**

*(a) Not later than 30 days after filing a copy of its plan with the department, the urban water supplier and the department shall make the plan available for public review during normal business hours.*

*(b) Not later than 30 days after filing a copy of its water shortage contingency plan with the department, the urban water supplier and the department shall make the plan available for public review during normal business hours.*

On April 20, 2026, electronic versions of the draft 2025 UWMP and WSCP were made available for review by visiting Cal Water’s website:

<https://www.calwater.com/conservation/uwmp2025>

## 10.6 Notification of Public Utilities Commission

**CWC § 10621 (c)**

*An urban water supplier regulated by the Public Utilities Commission shall include its most recent plan and water shortage contingency plan as part of the supplier’s general rate case filings.*

Cal Water is an urban water supplier regulated by the California Public Utilities Commission. Cal Water will include the District’s 2025 UWMP and WSCP as part of its General Rate Case Filings.

## 10.7 Amending an Adopted UWMP or Water Shortage Contingency Plan

**CWC § 10644 (b)**

*If an urban water supplier revises its water shortage contingency plan, the supplier shall submit to the department a copy of its water shortage contingency plan prepared pursuant to subdivision (a) of Section 10632 no later than 30 days after adoption, in accordance with protocols for submission and using electronic reporting tools developed by the department.*

If either the 2025 UWMP or WSCP is amended, each of the steps for notification, public hearing, adoption and submittal will also be followed for the amended UWMP or WSCP.



## Appendix A: UWMP Act Checklist

Retail (x = required)	Wholesale (x = required)	2025 Guidebook Location	Water Code Section	Summary as Applies to UWMP	Subject	Relevant Submittal Table	2025 UWMP Location
x	x	Chapter 1	10615	A plan shall describe and evaluate sources of supply, reasonable and practical efficient uses, reclamation and demand management activities.	Introduction and overview	n/a	Chapter 1 - Chapter 10 (pdf pg. 13 - 125)
x	x	Chapter 1	10630.5	Each plan shall include a simple description of the Supplier's plan including water availability, future requirements, a strategy for meeting needs, and other pertinent information. Additionally, a Supplier may also choose to include a simple description at the beginning of each chapter.	Plan preparation	n/a	Section 1.6 (pdf pg. 17)
x	x	Section 2.1	10620(b)	Every person that becomes a Supplier shall adopt UWMP within one year after it has become a Supplier.	Plan preparation	n/a	Section 2.4 (pdf pg. 24)
x	n/a	Section 2.5	10644	Supplier shall report the Public Water Systems number, volume of delivered water, and number of connections that are included in this UWMP.	Plan preparation	2-1	Section 2.1 (pdf pg. 21) Table 2-1 (pdf pg. 22)
x	x	Section 2.5	10644	Supplier shall report if this UWMP is an individual UWMP and whether the Supplier belongs to a regional UWMP or regional alliance.	Plan preparation	2-2	Section 2.3 (pdf pg. 22) Table 2-2 (pdf pg. 23)
x	x	Section 2.5	10644	Supplier shall report whether the data is in fiscal or calendar years and the units of measure used for reporting water volumes.	Plan preparation	2-3	Section 2.4 (pdf pg. 24) Table 2-3 (pdf pg. 25)
x	x	Section 2.4	10642	Provide supporting documentation that the Supplier has encouraged active involvement of diverse social, cultural, and economic elements of the population within the service area prior to and during the preparation of the plan and contingency plan.	Plan preparation	n/a	Section 2.5.2 (pdf pg. 27) Section 10.2 (pdf pg. 126) Appendix C (pdf pg. 150)
x	x	Section 2.4.2	10620(d)(3)	Coordinate the preparation of its plan with other appropriate agencies in the area, including other Suppliers that share a common source, water management agencies, and relevant public agencies, to the extent practicable.	Plan preparation	n/a	Section 2.5 (pdf pg. 25) Section 10.2 (pdf pg. 126) Appendix B (pdf pg. 146)

Retail (x = required)	Wholesale (x = required)	2025 Guidebook Location	Water Code Section	Summary as Applies to UWMP	Subject	Relevant Submittal Table	2025 UWMP Location
x	n/a	Section 2.4.1	10631(h)	Retail Suppliers will include documentation that they have provided their Wholesale Supplier(s)—if any—with water use projections from that source.	Plan preparation	2-4 R	Section 2.5.1 (pdf pg. 26) Table 2-4 (pdf pg. 26) Section 4.5 (pdf pg. 54)
n/a	x	Section 2.4.1	10631(h)	Wholesale Suppliers will provide their Suppliers with identification and quantification of the existing and planned sources of water available from the Wholesale Supplier to the Supplier during various water year types.	Plan preparation	2-4 W	N/A
x	x	Chapter 3.0	10631(a)	Describe the Supplier service area.	System description	n/a	Chapter 3 (pdf pg. 29)
x	x	Section 3.3	10631(a)	Describe the climate of the Supplier’s service area.	System description	n/a	Section 3.3 (pdf pg. 31) Figure 3-2 (pdf pg. 32)
x	x	Section 3.4.1	10631(a)	Provide the current and projected service area populations for 2030, 2035, 2040, 2045 and optionally 2050.	System description	3-1	Section 3.4 (pdf pg. 32) Table 3-1 (pdf pg. 33)
x	x	Section 3.4.2	10631(a)	Describe other social, economic, and demographic factors affecting the Supplier’s water management planning.	System description	n/a	Section 3.4 (pdf pg. 32) Table 3-2 (pdf pg. 34)
x	x	Section 3.5	10631(a)	Describe the land uses within the service area... include the current and projected land uses within the existing or anticipated service area affecting the Supplier’s water management planning. Describe the land uses within the service area.	System description and baselines	n/a	Section 3.5 (pdf pg. 34) Table 3-1 (pdf pg. 33)
x	Optional	Sections 4.2.3 and 4.2.4	10631(d)(1)	Quantify past, current, and projected water use, identifying the uses among water use sectors.	System water use	4-1 and 4-2	Section 4.2 (pdf pg. 38) Table 4-1 (pdf pg. 40) Table 4-2 (pdf pg. 43)

Retail (x = required)	Wholesale (x = required)	2025 Guidebook Location	Water Code Section	Summary as Applies to UWMP	Subject	Relevant Submittal Table	2025 UWMP Location
x	Optional	Section 4.3.1	10631(d)(3)(A)	Report the distribution system water loss for each of the five years preceding the plan update.	System water use	4-5	Section 4.3.1 (pdf pg. 49) Table 4-5 (pdf pg. 49)
x	n/a	Section 4.3.2	10631(d)(3)(C)	Retail Suppliers shall provide data to show the distribution loss standards were met.	System water use	4-6	Section 4.3.2 (pdf pg. 49) Table 4-6 (pdf pg. 51)
x	n/a	Section 4.2.5.4	10631.1(a)	Include projected water use needed for lower income housing projected in the service area of the Supplier.	System water use	4-3	Section 4.2.2 (pdf pg. 42) Table 4-3 (pdf pg. 45)
x	n/a	Section 4.2.5.3	10631(d)(4)(A)	In projected water use, include estimates of water savings from adopted codes, plans, and other policies or laws.	System water use	4-3	Section 4.2.3(1) (pdf pg. 44) Table 4-4 (pdf pg. 48)
x	n/a	Section 4.2.5.3	10631(d)(4)(B)	Provide citations of codes, standards, ordinances, or plans used to make water use projections.	System water use	4-3	Section 4.2.3(1) (pdf pg. 44) Table 4-4 (pdf pg. 48)
x	n/a	Section 4.2.5.3	10631(d)(4)(B)(ii)	To the extent that a Supplier reports the information described in subparagraph (A), an urban water Supplier shall... Indicate the extent that the water use projections consider savings from codes, standards, ordinances, or transportation and land use plans. Water use projections that do not account for these water savings shall be noted of that fact.	System water use	4-3	Section 4.2.3(1) (pdf pg. 44) Table 4-4 (pdf pg. 48)
x	x	Section 4.2.5.6	10635(b)	Demands under climate change considerations must be included as part of the drought risk assessment.	System water use	n/a	Section 4.4 (pdf pg. 52) Section 7.5 (pdf pg. 99) Table 4-7 (pdf pg. 54) Table 7-5 (pdf pg. 101)
n/a	x	Section 5.1	10608.36	Wholesale Suppliers shall include an assessment of present and proposed future measures, programs, and policies to help their Retail Suppliers achieve targeted water use reductions.	Baselines and targets	n/a	N/A

Retail (x = required)	Wholesale (x = required)	2025 Guidebook Location	Water Code Section	Summary as Applies to UWMP	Subject	Relevant Submittal Table	2025 UWMP Location
x	n/a	Section 5.2	10608.4	Retail Suppliers shall report on their compliance in meeting their water use targets. Reporting requirements will vary depending on whether the Supplier: - Was considered an urban retail water supplier in 2020, - Met its 2020 target in 2020, or - Was part of a merger or consolidation since 2020. Chapter 5 Subsections 5.2.1, 5.2.2, and 5.2.3 address each of these situations.	Baselines and targets	5-1	Chapter 5 (pdf pg. 55) Table 5-1 (pdf pg. 56)
x	x	Section 6.1	10631(b)(2)	When multiple sources of water supply are identified, describe the management of each supply in relationship to other identified supplies.	System supplies	n/a	Section 6.9 (pdf pg. 82) Table 6-9 (pdf pg. 84)
x	x	Sections 6.1 and 6.2	10631(b)(1)	Provide a discussion of anticipated supply availability under a normal, single dry year, and a drought lasting five years, as well as more frequent and severe periods of drought, including changes in supply due to climate change.	System supplies	n/a	Chapter 7 (pdf pg. 89)
x	x	Section 6.2.2	10631(b)(4)(C)	Indicate whether groundwater is an existing or planned source of water available to the Supplier. If groundwater is identified as an existing or planned source of water... (include) a detailed description and analysis of the location, amount and sufficiency of groundwater pumped by the Supplier for the past five years.	Water supplies and recycled water	6-1	Section 6.2 (pdf pg. 62) Table 6-1 (pdf pg. 71)
x	x	Section 6.2.2	10631(b)(4)(A)	Indicate whether a groundwater sustainability plan or groundwater management plan has been adopted by the Supplier or if there is any other specific authorization for groundwater management. Include a copy of the plan or authorization.	System supplies	n/a	Section 6.2 (pdf pg. 62)
x	x	Section 6.2.2	10631(b)(4)(B)	Describe the groundwater basin.	System supplies	n/a	Section 6.2.1 (pdf pg. 63)
x	x	Section 6.2.2	10631(b)(4)(B)	Indicate if the basin has been adjudicated and include a copy of the court order or decree and a description of the amount of water the Supplier has the legal right to pump.	System supplies	n/a	Section 6.2.1 (pdf pg. 63)
x	x	Section 6.2.2	10631(b)(4)(B)	For unadjudicated basins... (include) information as to whether DWR has identified the basin as a high- or medium-priority basin in the most current official departmental bulletin...	Water supplies and recycled water	n/a	Section 6.2.1 (pdf pg. 63)

Retail (x = required)	Wholesale (x = required)	2025 Guidebook Location	Water Code Section	Summary as Applies to UWMP	Subject	Relevant Submittal Table	2025 UWMP Location
x	x	Section 6.2.2	10631(b)(4)(B)	For unadjudicated basins... describe efforts by the Supplier to coordinate with sustainability or groundwater agencies to achieve sustainable groundwater conditions.	Water supplies and recycled water	n/a	Section 6.2.3 (pdf pg. 66)
x	x	Section 6.2.2.	10631(b)(4)(C)	If groundwater is identified as an existing or planned source of water... (include) a detailed description and analysis of the location, amount and sufficiency of groundwater pumped by the Supplier for the past five years.	System supplies	n/a	Section 6.2.5 (pdf pg. 69) Table 6-1 (pdf pg. 71)
x	x	Section 6.2.2	10631(b)(4)(D)	Provide a detailed description and analysis of the amount and location of groundwater that is projected to be pumped.	System supplies	6-9	Section 6.9 (pdf pg. 82) Table 6-9 (pdf pg. 84)
x	x	Section 6.1	10631(b)	Identify and quantify the existing and planned sources of water available for 2025, 2030, 2035, 2040, 2045 and optionally 2050.	System supplies	6-8 and 6-9	Section 6.9 (pdf pg. 82) Table 6-9 (pdf pg. 84)
x	x	Section 6.2.7	10631(c)	Describe the opportunities for exchanges or transfers of water on a short-term or long-term basis.	System supplies	n/a	Section 6.7 (pdf pg. 79)
x	n/a	Section 6.2.5	10633(a)	Describe the wastewater collection and treatment systems in the Supplier's service area with quantified amount of collection and treatment and the disposal methods.	System supplies (recycled water)	6-2	Section 6.5.2 (pdf pg. 72) Table 6-2 (pdf pg. 74)
x	x	Section 6.2.5	10633(b)	Describe the quantity of treated wastewater that meets recycled water standards, is being discharged, and is otherwise available for use in a recycled water project.	System supplies (recycled water)	6-3	Section 6.5.2 (pdf pg. 72) Table 6-3 (pdf pg. 75)
x	x	Section 6.2.5	10633(c)	Describe the recycled water currently being used in the Supplier's service area.	System supplies (recycled water)	6-4	Section 6.5.3 (pdf pg. 76) Table 6-4 (pdf pg. 77)

Retail (x = required)	Wholesale (x = required)	2025 Guidebook Location	Water Code Section	Summary as Applies to UWMP	Subject	Relevant Submittal Table	2025 UWMP Location
x	x	Section 6.2.5	10633(d)	Describe and quantify the potential uses of recycled water and provide a determination of the technical and economic feasibility of those uses.	System supplies (recycled water)	6-4	Section 6.5.3 (pdf pg. 76) Table 6-4 (pdf pg. 77)
x	x	Section 6.2.5	10633(e)	Describe the projected use of recycled water within the Supplier's service area at the end of 5, 10, 15, and 20 years, and describe the actual use of recycled water in comparison to uses previously projected.	System supplies (recycled water)	6-4 and 6-5	Section 6.5.3 (pdf pg. 76) Table 6-4 (pdf pg. 77) Table 6-5 (pdf pg. 78)
x	x	Section 6.2.5	10633(f)	Describe the actions that may be taken to encourage the use of recycled water and the projected results of these actions in terms of acre-feet of recycled water used per year.	System supplies (recycled water)	6-6	Section 6.5.4 (pdf pg. 78) Table 6-6 (pdf pg. 78)
x	x	Section 6.2.5	10633(g)	Provide a plan for optimizing the use of recycled water in the Supplier's service area.	System supplies (recycled water)	n/a	Section 6.5.4 (pdf pg. 78) Table 6-6 (pdf pg. 78)
x	x	Section 6.2.6	10631(g)	Describe desalinated water project opportunities for long-term supply.	System supplies	6-7	Section 6.6 (pdf pg. 79)
x	x	Section 6.2.10	10631(f)	Describe the expected future water supply projects and programs that may be undertaken by the water Supplier to address water supply reliability in average, single-dry, and for a period of drought lasting five consecutive water years.	System supplies	6-7	Section 6.8 (pdf pg. 80) Table 6-7 (pdf pg. 81)
x	x	Section 6.3 and Appendix O	10631.2(a)	The UWMP must include energy information, as stated in the code, that a Supplier can readily obtain.	System suppliers, energy intensity	O-1A, O-1B, O-1C, and O-2	Section 6.11 (pdf pg. 86) Table 6-10 (pdf pg. 87)
x		Section 7.1	10634	Provide information on the quality of existing sources of water available to the Supplier and the manner in which water quality affects water management strategies and supply reliability.	Water supply reliability assessment	n/a	Section 7.1.2 (pdf pg. 91)

Retail (x = required)	Wholesale (x = required)	2025 Guidebook Location	Water Code Section	Summary as Applies to UWMP	Subject	Relevant Submittal Table	2025 UWMP Location
x	x	Section 7.2	10635(a)	Service Reliability Assessment: Assess the water supply reliability during normal, dry, and a drought lasting five consecutive water years by comparing the total water supply sources available to the Supplier with the total projected water use over the next 20 years.	Water supply reliability assessment	7-2, 7-3, and 7-4	Section 7.2 (pdf pg. 93) Section 7.3 (pdf pg. 96) Table 7-1 (pdf pg. 95) Table 7-2 (pdf pg. 96) Table 7-3 (pdf pg. 95) Table 7-4 (pdf pg. 95)
x	x	Section 7.2.3	10620(f)	Describe water management tools and options to maximize resources and minimize the need to import water from other regions.	Water supply reliability assessment	n/a	Section 7.4 (pdf pg. 98)
x	x	Section 7.3	10635(b)	Provide a drought risk assessment as part of information considered in developing the demand management measures and water supply projects.	Water supply reliability assessment	n/a	Section 7.5 (pdf pg. 99) Table 7-5 (pdf pg. 101)
x	x	Section 7.3	10635(b)(1)	Include a description of the data, methodology, and basis for one or more supply shortage conditions that are necessary to conduct a drought risk assessment for a drought period that lasts five consecutive years.	Water supply reliability assessment	n/a	Section 7.5.1 (pdf pg. 99)
x	x	Section 7.3	10635(b)(2)	Include a determination of the reliability of each source of supply under a variety of water shortage conditions.	Water supply reliability assessment	n/a	Section 7.5.2 (pdf pg. 99)
x	x	Section 7.3	10635(b)(3)	Include a comparison of the total water supply sources available to the Supplier with the total projected water use for the drought period.	Water supply reliability assessment	7-5	Section 7.5 (pdf pg. 99) Table 7-5 (pdf pg. 101)
x	x	Section 7.3	10635(b)(4)	Include considerations of the historical drought hydrology, plausible changes on projected supplies and demands under climate change conditions, anticipated regulatory changes, and other locally applicable criteria.	Water supply reliability assessment	n/a	Section 7.5 (pdf pg. 99) Table 7-5 (pdf pg. 101)
x	x	Chapter 8	10632(a)	Provide a water shortage contingency plan (WSCP) with specified elements below.	Water shortage contingency planning	n/a	Appendix G (pdf pg. 220)

Retail (x = required)	Wholesale (x = required)	2025 Guidebook Location	Water Code Section	Summary as Applies to UWMP	Subject	Relevant Submittal Table	2025 UWMP Location
x	x	Chapter 8	10632(a)(1)	Provide an analysis of water supply reliability (from Guidebook Chapter 7) in the WSCP.	Water shortage contingency planning	n/a	Appendix G (Chapter 2) (pdf pg. 225)
x	x	Section 8.2	10632(a)(2)(A)	Provide the written decision-making process and other methods that the Supplier will use each year to determine its water reliability.	Water shortage contingency planning	n/a	Appendix G (Chapter 3) (pdf pg. 226)
x	x	Section 8.2	10632(a)(2)(B)	Provide data and methodology to evaluate the Supplier's water reliability for the current year and one dry year pursuant to factors in the code.	Water shortage contingency planning	n/a	Appendix G (Chapter 3) (pdf pg. 226)
x	x	Section 8.3	10632(a)(3)(A)	Define six standard water shortage levels of 10%, 20%, 30%, 40%, 50% shortage, and greater than 50% shortage. These levels shall be based on supply conditions, including percent reductions in supply, changes in groundwater levels, changes in surface elevation, or other conditions. The shortage levels shall also apply to a catastrophic interruption of supply.	Water shortage contingency planning	n/a	Appendix G (Chapter 4) (pdf pg. 230)
x	x	Section 8.3	10632(a)(3)(B)	Suppliers with an existing WSCP that uses different water shortage levels must cross reference their categories with the six standard categories.	Water shortage contingency planning	8-1	Appendix G (Chapter 4) (pdf pg. 230)
x	x	Section 8.4	10632(a)(4)(A)	Suppliers with WSCPs that align with the defined shortage levels must specify locally appropriate supply augmentation actions.	Water shortage contingency planning	8-2	Appendix G (Section 5.2) (pdf pg. 240)
x	x	Section 8.4	10632(a)(4)(B)	Specify locally appropriate demand reduction actions to adequately respond to shortages.	Water shortage contingency planning	8-3	Appendix G (Section 5.1) (pdf pg. 231)
x	x	Section 8.4	10632(a)(4)(C)	Specify locally appropriate operational changes.	Water shortage contingency planning	8-2	Appendix G (Section 5.3) (pdf pg. 240)

Retail (x = required)	Wholesale (x = required)	2025 Guidebook Location	Water Code Section	Summary as Applies to UWMP	Subject	Relevant Submittal Table	2025 UWMP Location
x	x	Section 8.4	10632(a)(4)(D)	Specify additional mandatory prohibitions against specific water use practices that are in addition to State-mandated prohibitions are appropriate to local conditions.	Water shortage contingency planning	Table 8-3	Appendix G (Section 5.4, Table 5-1) (pdf pg. 234, 240)
x	x	Section 8.4	10632(a)(4)(E)	Estimate the extent to which the gap between supplies and demand will be reduced by implementation of the action.	Water shortage contingency planning	8-2 and 8-3	Appendix G (Section 5.1, Section 5.2, Section 5.7, Table 5-1) (pdf pg. 231, 234, 240, 242)
x	x	Section 8.4.6	10632.5	The UWMP shall include a seismic risk assessment and mitigation plan.	Water shortage contingency plan	n/a	Appendix G (Section 5.6) (pdf pg. 242)
x	x	Section 8.5	10632(a)(5)(A)	Suppliers must describe that they will inform customers, the public and others regarding any current or predicted water shortages.	Water shortage contingency planning	n/a	Appendix G (Chapter 6) (pdf pg. 243)
x	x	Section 8.5	10632(a)(5)(B), 10632(a)(5)(C)	Suppliers must describe that they will inform customers, the public and others regarding any shortage response actions triggered or anticipated to be triggered and other relevant communications.	Water shortage contingency planning	n/a	Appendix G (Chapter 6) (pdf pg. 243)
x	n/a	Section 8.6	10632(a)(6)	Retail Supplier must describe how it will ensure compliance with and enforce provisions of the WSCP.	Water shortage contingency planning	n/a	Appendix G (Chapter 7) (pdf pg. 244)
x	x	Section 8.7	10632(a)(7)(A)	Describe the legal authority that empowers the Supplier to enforce shortage response actions.	Water shortage contingency planning	n/a	Appendix G (Chapter 8) (pdf pg. 248)
x	x	Section 8.7	10632(a)(7)(B)	Provide a statement that the Supplier will declare a water shortage emergency per Water Code Chapter 3. Water Shortage Emergencies.	Water shortage contingency planning	n/a	Appendix G (Chapter 8) (pdf pg. 248)

Retail (x = required)	Wholesale (x = required)	2025 Guidebook Location	Water Code Section	Summary as Applies to UWMP	Subject	Relevant Submittal Table	2025 UWMP Location
x	x	Section 8.7	10632(a)(7)(C)	Provide a statement that the Supplier will coordinate with any city or county within which it provides water for the possible proclamation of a local emergency.	Water shortage contingency planning	n/a	Appendix G (Chapter 8) (pdf pg. 248)
x	x	Section 8.8	10632(a)(8)(A)	Describe the potential revenue reductions and expense increases associated with activated shortage response actions.	Water shortage contingency planning	n/a	Appendix G (Chapter 9) (pdf pg. 249)
x	x	Section 8.8	10632(a)(8)(B)	Provide a description of mitigation actions needed to address revenue reductions and expense increases associated with activated shortage response actions.	Water shortage contingency planning	n/a	Appendix G (Chapter 9) (pdf pg. 249)
x	n/a	Section 8.8	10632(a)(8)(C)	Retail Suppliers must describe the cost of compliance with Water Code Chapter 3.3, Excessive Residential Water Use During Drought.	Water shortage contingency planning	n/a	Appendix G (Chapter 9) (pdf pg. 249)
x	n/a	Section 8.9	10632(a)(9)	Retail Suppliers must describe the monitoring and reporting requirements and procedures that ensure appropriate data are collected, tracked, and analyzed for purposes of monitoring customer compliance.	Water shortage contingency planning	n/a	Appendix G (Chapter 10) (pdf pg. 250)
x	x	Section 8.10	10632(a)(10)	Describe reevaluation and improvement procedures for monitoring and evaluation the WSCP to ensure risk tolerance is adequate and appropriate water shortage mitigation strategies are implemented.	Water shortage contingency planning	n/a	Appendix G (Chapter 11) (pdf pg. 251)
x	n/a	Section 8.11	10632(b)	Analyze and define water features that are artificially supplied with water, including ponds, lakes, waterfalls, and fountains, separately from swimming pools and spas.	Water shortage contingency planning	n/a	Appendix G (Section 5.1.1, Table 5-1) (pdf pg. 233, 234)
x	x	Section 8.12	10632(c)	Make available the WSCP to customers and any city or county where it provides water within 30 days after adoption of the plan.	Water shortage contingency planning	n/a	Appendix G (Chapter 12) (pdf pg. 252)

Retail (x = required)	Wholesale (x = required)	2025 Guidebook Location	Water Code Section	Summary as Applies to UWMP	Subject	Relevant Submittal Table	2025 UWMP Location
x	n/a	Sections 9.1	10631(e)(1)	Retail Suppliers shall provide a description of the nature and extent of each demand management measure implemented over the past five years. The description will address specific measures listed in code.	Demand management measures	n/a	Chapter 9 (pdf pg. 111)
n/a	x	Sections 9.2	10631(e)(2)	Wholesale Suppliers shall describe specific demand management measures listed in code, their distribution system asset management program, and Supplier assistance program.	Demand management measures	n/a	N/A
x	n/a	Chapter 10	10608.26(a)	Retail Suppliers shall conduct a public hearing to discuss adoption, implementation, and economic impact of water use targets (recommended to discuss compliance).	Plan adoption, submittal, and implementation	n/a	Section 2.5.2 (pdf pg. 27) Section 10.3 (pdf pg. 127)
x	x	Section 10.2.1	10621(b)	Notify, at least 60 days prior to the public hearing, any city or county within which the Supplier provides water that the Supplier will be reviewing the UWMP and considering amendments or changes to the plan.	Plan adoption, submittal, and implementation	10-1	Section 2.5.2 (pdf pg. 27) Section 10.3 (pdf pg. 127)
x	x	Section 10.4	10621(f)	Each urban water Supplier shall update and submit its 2025 plan to DWR by July 1, 2026.	Plan adoption, submittal, and implementation	n/a	Section 2.4 (pdf pg. 24) Section 10.4 (pdf pg. 128)
x	x	Sections 10.2.2, 10.3, and 10.5	10642	Provide supporting documentation that the Supplier made the UWMP and WSCP available for public inspection, published notice of the public hearing, and held a public hearing about the UWMP and WSCP.	Plan adoption, submittal, and implementation	n/a	Chapter 10 (pdf pg. 125) Appendix C (pdf pg. 150)
x	x	Section 10.2.2	10642	The Supplier is to provide the time and place of the hearing to any city or county within which the Supplier provides water.	Plan adoption, submittal, and implementation	10-1	Section 10.2.1 (pdf pg. 126) Table 10-1 (pdf pg. 127) Appendix B (pdf pg. 146)
x	x	Section 10.3.2	10642	Provide supporting documentation that the UWMP and WSCP has been adopted as prepared or modified.	Plan adoption, submittal, and implementation	n/a	Section 10.3 (pdf pg. 127) Appendix I (pdf pg. 333)

Retail (x = required)	Wholesale (x = required)	2025 Guidebook Location	Water Code Section	Summary as Applies to UWMP	Subject	Relevant Submittal Table	2025 UWMP Location
x	x	Section 10.4	10644(a)	Provide supporting documentation that the Supplier has submitted their UWMP to the California State Library.	Plan adoption, submittal, and implementation	n/a	Section 10.4 (pdf pg. 128)
x	x	Section 10.4	10644(a)(1)	Provide supporting documentation that the Supplier has submitted their UWMP to any city or county within which the Supplier provides water no later than 30 days after adoption.	Plan adoption, submittal, and implementation	n/a	Section 10.4 (pdf pg. 128)
x	x	Sections 10.4.1 and 10.4.2	10644(a)(2)	The UWMP, or amendments to the UWMP, submitted to DWR shall be submitted electronically.	Plan adoption, submittal, and implementation	n/a	Section 10.4 (pdf pg. 128)
x	x	Section 10.7.2	10644(b)	If revised, submit a copy of the WSCP to DWR within 30 days of adoption.	Plan adoption, submittal, and implementation	n/a	Section 10.7 (pdf pg. 129)
x	x	Section 10.5	10645(a)	Provide supporting documentation that, not later than 30 days after filing a copy of its UWMP with DWR, the Supplier has or will make the plan available for public review during normal business hours.	Plan adoption, submittal, and implementation	n/a	Section 10.5 (pdf pg. 128)
x	x	Section 10.5	10645(b)	Provide supporting documentation that, not later than 30 days after filing a copy of its WSCP with DWR, the Supplier has or will make the plan available for public review during normal business hours.	Plan adoption, submittal, and implementation	n/a	Section 10.5 (pdf pg. 128)
x	x	Section 10.6	10621(c)	If Supplier is regulated by the Public Utilities Commission, include its plan and contingency plan as part of its general rate case filings.	Plan adoption, submittal, and implementation	n/a	Section 10.6 (pdf pg. 129)

## Appendix B: Correspondence

- UWMP and WSCP Notice of Preparation
- District Mailing List
- UWMP and WSCP Public Draft Comments

Note: There were no public comments received on the UWMP and WSCP Public Draft.



# The Cal Water Difference

Dear XXXX,

We hope that this note finds you well. California Water Service (Cal Water) is beginning the process of updating our Urban Water Management Plans (UWMP) and Water Shortage Contingency Plans (WSCP) and wanted to ensure you had the pertinent information to participate in the process, which is included in the following notification.

These plans are a critical component of the steps we are taking to meet the current and future water supply needs of our customers, and to elevate our urban water use efficiency.

To develop well-rounded plans, **we are requesting data from the partners that serve our customers** to ensure the plans are representative of the communities we serve. The specific data points we are seeking can be found below the following notice.

At your earliest convenience, **please confirm you have received this Notice of Preparation**. If you have any questions, need any additional information, or would like to find time to meet virtually with our team to discuss this further, please reach out at your convenience.

## **Notice of Preparation of Urban Water Management Plan and Water Shortage Contingency Plan – 2025 Update**

The Urban Water Management Planning Act (California Water Code §10608–10656) requires that California Water Service Company (Cal Water) update its Urban Water Management Plan (UWMP) and associated Water Shortage Contingency Plan (WSCP) every 5 years. The updated UWMP and WSCP are due by July 1, 2026.

Cal Water is currently reviewing its existing UWMP and associated WSCP, which were updated in 2021, and considering revisions to the documents. Coordination with water suppliers, cities, counties, and community organizations in the region is an important part of the preparation of Cal Water's UWMP and WSCP. We invite your agency's participation in this revision process. We are available to discuss the assumptions used in the development of the plans including available water supply, water demands, land use, as well as other aspects of the plans.

A draft of the 2025 UWMP and WSCP will be made available for public review and a public hearing will be scheduled in 2026. In the meantime, if you would like more information regarding Cal Water's 2020 UWMP and WSCP and the schedule for updating these documents, or if you would like to participate in the preparation of the 2025 UWMP and WSCP, please contact Jake Lam at:

### **Jake Lam**

Associate Engineer  
California Water Service  
[jlam@calwater.com](mailto:jlam@calwater.com)

## DATA REQUEST – Help Develop Our UWMP and WSCP

We're seeking to coordinate with community partners to ensure we develop a UWMP and associated WSCP that are reflective of our communities. We'd like to begin this partnership today and ask that you provide the following information to Jake Lam ([jlam@calwater.com](mailto:jlam@calwater.com)):

- Description of current land use
- GIS files for land use and zoning
- Population growth projections
- Most recent General Plans

**We are looking to gather this information by XXXX XX, XXXX.**

Once again, we thank you for your continued partnership. If you have any questions, need any additional information, or would like to find time to meet virtually with our team to discuss this further, please reach out at your convenience.

Sincerely,

Kevin McCusker

Director of Government & Community Affairs

### About Cal Water

California Water Service provides safe, clean, and affordable water utility service to more than 2 million people statewide. What sets Cal Water apart is its commitment to enhancing the quality of life for its customers and communities. Guided daily by their promise to provide quality, service, and value, the utility's employees lead the way in working to protect the planet, care for people, and operate with the utmost integrity. Integral to Cal Water's strategy is investing responsibly in infrastructure, sustainability initiatives, and community well-being. The utility has been named one of "America's Most Responsible Companies" and the "World's Most Trustworthy Companies" by *Newsweek* and a Great Place to Work®. More information is available at

<https://link.edgepilot.com/s/4069251c/CvANuC690u9ITiwQCmjDg?u=http://www.calwaterdifference.com/>.

Quality. Service. Value.®



California Water Service  
1720 North 1<sup>st</sup> Street - San Jose, CA 95112  
[Unsubscribe](#)

Name	Position (if known)	Agency	Other Agency Affiliation (if applicable)
Ms. Leslie Rodriguez	Partner	California Strategies	
Mr. Jim Cunneen	Partner	California Strategies	
Don Hendershot	District 4 Councilmember	City of Dixon	
Kevin Johnson	District 3 Councilmember	City of Dixon	
Jim Lindley	City Manager	City of Dixon	
Jim Ernest	District 1 Councilmember	City of Dixon	
Steve Bird	Mayor	City of Dixon	
Justen Cole	Assistant Director of Utilities	City of Vacaville GSA	
Cookie Powell	Executive Director	Dixon Family Services	
Dave Robinson	Manager	Reclamation District 3	
Joe Salman		Reclamation District No. 349 GSA	
Erik Ringelberg	Regional Vice President	Reclamation District No. 501 GSA, Reclamation District No. 2111 GSA	Freshwater Trust
Austin Miller	Environmental Specialist	Sacramento County GSA - Solano	
Terry Schmidtbauer	Director of Resource Management	Solano County	
Mitch Mashburn	District 5 Supervisor	Solano County	
John Vasquez	District 4 Supervisor	Solano County	
Monica Brown	District 2 Supervisor	Solano County	
Mr. Matt Tuggle	Public Works Engineering Manager	Solano County	
Matt Tuggle	Public Works Engineering Manager	Solano County	
Mr. Ronald Sanford	General Manager	Solano County Water Agency	
Mr. Cary Keaten	General Manager	Solano Irrigation District	
Paul Fuchslin	Director of Engineering	Solano Irrigation District GSA	
Mr. Chris Lee	General Manager	Solano Subbasin GSA	Solano County Water Agency

## **Appendix C: Public Meeting Notice**

- Public Meeting Notice of Intent
- Proof of Publication
- Public Meeting Presentation



# The Cal Water Difference

Dear XXXX,

As a defined urban water supplier, California Water Service (Cal Water) is preparing an update to its Urban Water Management Plans (UWMP) and Water Shortage Contingency Plans (WSCP) that will address the water service conditions in our service areas. These documents support a water supplier's long-term resource planning to ensure that adequate water supplies are available to meet existing and future water demands under defined conditions. Within the UWMP, Cal Water provides its projected water use from each source, in five-year increments, through the year 2050. Cal Water intends to adopt and file that UWMP plan, and the incorporated WSCP, as required with the Department of Water Resources, the California State Library, and any applicable city or county within which Cal Water provides service no later than 30 days after adoption.

Schedule of upcoming actions: After a public review period, a public meeting to receive comments on the Draft UWMP and WSCP will be held. As the information becomes available for each service area, the electronic copy of the UWMP, WSCP, deadline for public comments, and information on the public meeting are available at:

[www.calwater.com/conservation/uwmp2025](http://www.calwater.com/conservation/uwmp2025)

If you are unable to attend the scheduled public meeting but want to provide comments regarding the proposed UWMP or WSCP, you may send your comments through the inquiry form, located at the URL above.

Sincerely,

Kevin McCusker  
Director of Government & Community Affairs

## About Cal Water

California Water Service provides safe, clean, and affordable water utility service to more than 2 million people statewide. This year, the company commemorates a century of service. What sets Cal Water apart is its commitment to enhancing the quality of life for its customers and communities. Guided daily by their promise to provide quality, service, and value, the utility's employees lead the way in working to protect the planet, care for people, and operate with the utmost integrity. Integral to Cal Water's strategy is investing responsibly in infrastructure, sustainability initiatives, and community well-being. The utility has been named one of "America's Most Responsible Companies" and the "World's Most Trustworthy Companies" by *Newsweek* and a Great Place to Work®. More information is available at [www.calwaterdifference.com](http://www.calwaterdifference.com).

Quality. Service. Value.®



California Water Service  
1720 North 1<sup>st</sup> Street - San Jose, CA 95112

[Unsubscribe](#)

# CALIFORNIA NEWSPAPER SERVICE BUREAU

## DAILY JOURNAL CORPORATION

Mailing Address : 915 E 1ST ST, LOS ANGELES, CA 90012  
Telephone (213) 229-5300 / Fax (213) 229-5481  
Visit us @ WWW.LEGALADSTORE.COM

Karlee Kaylor  
CALIFORNIA WATER SERVICE CO  
1720 NORTH FIRST STREET  
SAN JOSE, CA 95112

### COPY OF NOTICE

Notice Type: GOV2 Government Legal Notice (2Pub)  
Ad Description: UWMP DIX 2026

To the right is a copy of the notice you sent to us for publication in the DIXONS INDEPENDENT VOICE. Please read this notice carefully and call us with any corrections. The Proof of Publication will be filed with the County Clerk, if required, and mailed to you after the last date below. Publication date(s) for this notice is (are):

05/01/2026 , 05/08/2026

An invoice will be sent after the last date of publication. If you prepaid this order in full, you will not receive an invoice.

#### Daily Journal Corporation

Serving your legal advertising needs throughout California. Call your local

BUSINESS JOURNAL, RIVERSIDE	(951) 784-0111
DAILY COMMERCE, LOS ANGELES	(213) 229-5300
LOS ANGELES DAILY JOURNAL, LOS ANGELES	(213) 229-5300
ORANGE COUNTY REPORTER, SANTA ANA	(714) 543-2027
SAN FRANCISCO DAILY JOURNAL, SAN FRANCISCO	(800) 640-4829
SAN JOSE POST-RECORD, SAN JOSE	(408) 287-4866
THE DAILY RECORDER, SACRAMENTO	(916) 444-2355
THE DAILY TRANSCRIPT, SAN DIEGO	(619) 232-3486
THE INTER-CITY EXPRESS, OAKLAND	(510) 272-4747

CNS 4036785

#### NOTICE OF INTENT TO ADOPT AN URBAN WATER MANAGEMENT PLAN AND WATER SHORTAGE CONTINGENCY PLAN AND HOLD A PUBLIC MEETING TO RECEIVE COMMENTS ON THE PROPOSED PLANS CALIFORNIA WATER SERVICE - DIXON DISTRICT

California Water Code (CWC) sections 10610 through 10656, known as the "Urban Water Management Planning Act" (Act), require all urban water suppliers that provide water for municipal purposes either directly or indirectly to more than 3,000 customers or supply more than 3,000 acre-feet of water annually to prepare an Urban Water Management Plan (UWMP) at least once every five years. UWMPs support a water supplier's long-term resource planning to confirm that adequate water supplies are available to meet existing and future water demands under defined conditions. The UWMP must describe and evaluate sources of supply, reasonable and practical efficient uses, reclamation, and demand management activities. The components of the plan may vary according to an individual community or area's characteristics and its capabilities to efficiently use and conserve water. The UWMP must also address measures for residential, commercial, governmental, commercial, industrial water demand management. Further, Section 10632 of the CWC requires that every urban water supplier shall prepare and adopt a Water Shortage Contingency Plan (WSCP) as part of its plan (UWMP). Section 10632.2 provides that, "An urban water supplier shall follow, where feasible and appropriate, the prescribed procedures and implement determined shortage response actions in its water shortage contingency plan...or reasonable alternative actions, provided that descriptions of the alternative actions are submitted with the annual water shortage assessment report pursuant to Section 10632.1." The WSCP will

be incorporated as an appendix of the UWMP. California Water Service's (Cal Water) Dixon District, located in Solano County, serves the City of Dixon. As a defined urban water supplier, Cal Water is preparing an update to its UWMP that will address water service conditions in the Dixon District. Cal Water intends to adopt and file that UWMP plan, and the incorporated WSCP, as required with the Department of Water Resources, the California State Library, and any applicable city or county within which Cal Water provides service no later than 30 days after adoption.

#### Schedule of upcoming actions:

On or about April 20, 2026, an electronic copy of the draft 2025 UWMP and WSCP will be available for review. After a public review period, a public meeting to receive comments on the draft UWMP and WSCP for the Dixon District will be held online on May 20, 2026, at 6:30 p.m. The UWMP, WSCP, and additional information on the public meeting, including a link to participate, are available at:

[www.calwater.com/conservation/uwmp2025](http://www.calwater.com/conservation/uwmp2025)

If you are unable to attend the scheduled public meeting but want to provide comments regarding the proposed UWMP or WSCP, you may send your comments through the inquiry form, located at the URL above. Cal Water will receive comments on the draft 2025 UWMP and WSCP through May 23, 2026.

Please share this notice with others who may have interest in this matter. 5/1 5/8/26

**CNS-4036785#  
DIXONS INDEPENDENT VOICE**



\* A 0 0 0 0 0 7 3 7 9 2 0 5 \*



# 2025 Urban Water Management Plan 2025 Water Shortage Contingency Plan

Dixon District

May 20, 2026



# Meeting Agenda

- Introduce California Water Service (CWS) staff and consultants
- Purpose and Objectives
- Presentation of the 2025 Urban Water Management Plan (UWMP)
- Presentation of 2025 Water Shortage Contingency Plan (WSCP)
- Public comments and questions



# 2025 UWMP Update: Public Outreach

- Notice of Preparation to relevant entities by February 2026
- Notice of Intent to relevant entities in April 2026
- Two notices posted in local newspaper in May 2026
- Draft 2025 UWMP and WSCP available for review at:  
<https://www.calwater.com/conservation/uwmp2025>
- Public hearing held today (May 20, 2026)



# Urban Water Management Planning Act

- Supports long-term water resource planning to ensure adequate supplies
- California Water Code - Sections 10610-10656
- Threshold: Utilities with 3,000+ services or 3,000+ acre-feet per year (AFY) water sales
- At least a 20-year planning horizon, Cal Water's plan cover 25 years
- Must be updated every 5 years and submitted by July 1, 2026
- Basis for SB-610 Water Supply Assessments




# 2025 UWMP Elements

- Service area description
- Population forecast
- Supply and demand projections through 2050 in normal, single dry, and multiple dry years
- Water supply reliability
- Conservation / Demand Management Measures
- Climate change
- WSCP


# District Overview

- Formed in 1927
- Serves a portion of the City of Dixon in Solano County
- Delivers groundwater
- Operates nine groundwater wells, two storage tanks, three booster pumps, and 35 miles of pipeline



# Water Supply Sources

- Groundwater is the sole supply (100% of supply between 2021 – 2025) for the District:
  - Groundwater pumped from the Solano Subbasin







# Demand Projection Methodology

- Forecast horizon is beyond 20 years required by UWMP
- Generates normal-, wet-, and dry-year demand forecasts
- Directly considers impacts of climate change
- Demand model uses historical data on services, sales, production, population, and proposed conservation measures
- Projected water use based on regional or general plan growth projections, historical water use trends, anticipated conservation, and compliance with state water use efficiency regulations

# Population & Services


- Population Projections
  - 2050 population projected to be 9,900
  - 5% increase relative to 2025 population
- Service Growth
  - 2050 services projected to be 3,200
  - 5% increase relative to 2025 services



# Water Demand by Customer Class


- Water demand decreased 6% between 2021 and 2025
- Largest customer sector is Single Family Residential (80% of total District demand) between 2021 - 2025

## Customer Categories



Note: values may not sum to 100% due to independent rounding.


## Water Demand



Note: values may not sum to 100% due to independent rounding.

# Demand – Current and Projected


- By 2050, demand projected to be 1,000 acre-feet per year (AFY) under normal year conditions and up to 1,100 AFY under multi-dry year conditions
- 20% decrease relative to 2025 demands





# Supply Sufficiency

- Supply sufficiency analysis is based on the following factors:
  - The District has consistently met historical water demands using locally pumped groundwater.
  - Urban demands for groundwater are relatively small within the Basin
  - Projected District pumping is less than pre-SGMA baseline (WY 1991 – 2014) pumping volume, consistent with the Solano Subbasin Groundwater Sustainability Plan goal to maintain groundwater levels in the Basin at or above baseline conditions.
- Supply is projected to be sufficient to meet projected demand under normal, single dry, and multiple dry year conditions
- Any regulatory or actual shortages will be addressed by the WSCP





# Conservation

- **Key Foundational Measures**

- Metering & Conservation Pricing: All connections are metered to ensure accurate billing, and tiered rate structures are used to incentivize lower water use
- System Loss Management: Ongoing leak detection and repair programs minimize “real losses” within the distribution system
- Education & Outreach: Public information campaigns, school education programs and dedicated staffing support and coordinate conservation initiatives
- Water Waste Prevention: Ordinances prohibit activities such as excessive runoff and washing down driveways

- **Programs & Compliance**

- Customer Programs: Landscape tune-ups and rebates for high efficiency irrigation equipment and indoor devices, and conservation kits
- Target Achievement: Successful implementation of these measures enabled the District to meet its 2020 water use target



# Water Shortage Contingency Plan Elements


- Comprehensive drought response plan
  - Procedures for the Annual Water Supply and Demand Assessments
  - Six standard water Shortage Levels (10% to >50%)
  - Shortage response actions
  - Communication protocols
  - Monitoring, enforcement, and reporting
- Quantitatively assessed using Drought Response Tool (DRT)

eki Drought Response Tool

Home Input Baseline Year Water Use Profile Baseline Year Water Use Profile Drought Response Actions Estimated Water Savings Drought Response Tracking

1 - Home  
California Water Service - Dixon

Enter Agency Information	
Agency Name	Dixon
Total Population Served	9,468
Conservation Goal (%)	10%
Drought Shortage Level	Shortage Level 1
Number of Residential Accounts	2,877
Number of Commercial, Industrial, and Institutional (CII) Accounts	190
Number of Dedicated Irrigation Accounts	1
Baseline Year(s)	2024
Percentage of Residential Indoor Use During Minimum Month (%)	99%
Percentage of CII Indoor Use During Minimum Month (%)	92%
Comments	




# Questions or Comments



- Review the draft 2025 UWMP and 2025 WSCP and submit public comments at:  
<https://www.calwater.com/conservation/uwmp2025>
- Comments on the draft 2025 UWMP and 2025 WSCP will be accepted through **May 23, 2026** (three days from today)

## Appendix D: City of Dixon Land Use Map

**Figure LCC-4: Land Use Designations**



**Land Use Designations**

*Residential*

- Low Density Residential
- Medium Density Residential

*Mixed Use*

- Corridor Mixed Use
- Campus Mixed Use
- Downtown Mixed Use

*Commercial*

- Neighborhood Commercial
- Regional Commercial
- Service Commercial

*Other*

- Industrial
- Public Facilities
- Parks

*Map Features*

- Dixon City Limit
- Sphere of Influence
- Railroad

Amended 4/2/24

## **Appendix E: Historical and Projected Service Area Population, Services, Sales, and Production**

# California Water Service

## Dixon District

### Water Supply/Demand Analysis Projections Summary



June 2026

California Water Service - Dixon District  
 Water Supply/Demand Analysis and Projections Summary

**Table 1. Historical & Projected Population**

YEAR	TYPE	HOUSEHOLD	GROUP	
			QUARTERS	TOTAL
2000	Historical	9,346	41	9,387
2001	Historical	9,379	37	9,416
2002	Historical	9,412	33	9,445
2003	Historical	9,446	29	9,474
2004	Historical	9,479	25	9,503
2005	Historical	9,512	21	9,533
2006	Historical	9,545	16	9,562
2007	Historical	9,578	12	9,591
2008	Historical	9,612	8	9,620
2009	Historical	9,645	4	9,649
2010	Historical	9,678	0	9,678
2011	Historical	9,636	0	9,636
2012	Historical	9,593	0	9,593
2013	Historical	9,551	0	9,551
2014	Historical	9,508	0	9,508
2015	Historical	9,466	0	9,466
2016	Historical	9,423	0	9,423
2017	Historical	9,381	0	9,381
2018	Historical	9,338	0	9,338
2019	Historical	9,296	0	9,296
2020	Historical	9,253	0	9,253
2021	Historical	9,393	0	9,393
2022	Historical	9,396	0	9,396
2023	Historical	9,403	0	9,403
2024	Historical	9,405	0	9,405
2025	Historical	9,394	0	9,394
2030	Projected	9,489	0	9,489
2035	Projected	9,584	0	9,584
2040	Projected	9,680	0	9,680
2045	Projected	9,777	0	9,777
2050	Projected	9,876	0	9,876
<b>2025 to 2050</b>				
<b>Compound Annual Growth Rate (CAGR)</b>				0.2%

**California Water Service - Dixon District**  
**Water Supply/Demand Analysis and Projections Summary**

**Table 2. Historical & Projected Services**

YEAR	TYPE	SFR-M	SFR-F	MFR	COM	IND	GOV	IRR	OTH	REC	TOTAL
2000	Historical	2,635	0	17	136	4	23	0	0	0	2,815
2001	Historical	2,634	0	17	134	4	22	0	0	0	2,812
2002	Historical	2,640	0	17	136	5	24	0	0	0	2,821
2003	Historical	2,637	0	17	136	5	25	0	0	0	2,821
2004	Historical	2,636	0	17	137	5	24	3	1	0	2,822
2005	Historical	2,657	0	17	137	4	24	5	3	0	2,847
2006	Historical	2,667	0	17	136	4	25	7	4	0	2,860
2007	Historical	2,654	0	16	145	4	24	7	4	0	2,855
2008	Historical	2,609	0	20	154	4	31	3	3	0	2,824
2009	Historical	2,589	0	21	153	3	36	1	2	0	2,804
2010	Historical	2,611	0	15	156	3	36	1	0	0	2,821
2011	Historical	2,620	0	22	161	3	36	1	0	0	2,844
2012	Historical	2,623	0	23	161	3	34	1	0	0	2,845
2013	Historical	2,632	0	23	162	3	30	1	2	0	2,852
2014	Historical	2,631	0	25	157	3	28	1	2	0	2,847
2015	Historical	2,633	0	26	156	3	28	1	1	0	2,847
2016	Historical	2,640	0	27	153	3	29	1	4	0	2,858
2017	Historical	2,656	0	27	152	3	30	1	3	0	2,871
2018	Historical	2,710	0	27	153	3	30	1	3	0	2,928
2019	Historical	2,747	0	27	154	3	30	1	4	0	2,965
2020	Historical	2,801	0	27	154	3	31	1	2	0	3,018
2021	Historical	2,846	0	27	153	3	30	1	0	0	3,060
2022	Historical	2,847	0	27	155	3	30	1	1	0	3,064
2023	Historical	2,849	0	27	156	3	32	1	1	0	3,068
2024	Historical	2,850	0	27	154	3	33	1	0	0	3,068
2025	Historical	2,846	0	27	152	3	33	1	1	0	3,063
2030	Projected	2,875	0	27	152	3	33	1	1	0	3,092
2035	Projected	2,904	0	27	152	3	33	1	1	0	3,121
2040	Projected	2,933	0	27	152	3	33	1	1	0	3,150
2045	Projected	2,962	0	27	152	3	33	1	1	0	3,179
2050	Projected	2,992	0	27	152	3	33	1	1	0	3,209

**2025 to 2050**

**Compound Annual Growth Rate (CAGR)**

0.2%

SFR-M = Single-Family Metered

SFR-F = Single-Family Unmetered (Flat Service)

MFR = Multi-Family

COM = Commercial

IND = Industrial

GOV = Government

IRR = Irrigation

OTH = Other/Miscellaneous

REC = Recycled

**California Water Service - Dixon District**  
**Water Supply/Demand Analysis and Projections Summary**

**Table 3. Historical & Projected Service Shares**

YEAR	TYPE	SFR-M	SFR-F	MFR	COM	IND	GOV	IRR	OTH	REC	TOTAL
2000	Historical	93.6%	0.0%	0.6%	4.8%	0.1%	0.8%	0.0%	0.0%	0.0%	100.0%
2001	Historical	93.7%	0.0%	0.6%	4.8%	0.1%	0.8%	0.0%	0.0%	0.0%	100.0%
2002	Historical	93.6%	0.0%	0.6%	4.8%	0.2%	0.8%	0.0%	0.0%	0.0%	100.0%
2003	Historical	93.5%	0.0%	0.6%	4.8%	0.2%	0.9%	0.0%	0.0%	0.0%	100.0%
2004	Historical	93.4%	0.0%	0.6%	4.8%	0.2%	0.9%	0.1%	0.0%	0.0%	100.0%
2005	Historical	93.3%	0.0%	0.6%	4.8%	0.2%	0.9%	0.2%	0.1%	0.0%	100.0%
2006	Historical	93.3%	0.0%	0.6%	4.8%	0.2%	0.9%	0.2%	0.1%	0.0%	100.0%
2007	Historical	93.0%	0.0%	0.6%	5.1%	0.1%	0.9%	0.2%	0.1%	0.0%	100.0%
2008	Historical	92.4%	0.0%	0.7%	5.5%	0.1%	1.1%	0.1%	0.1%	0.0%	100.0%
2009	Historical	92.3%	0.0%	0.7%	5.5%	0.1%	1.3%	0.0%	0.1%	0.0%	100.0%
2010	Historical	92.5%	0.0%	0.5%	5.5%	0.1%	1.3%	0.0%	0.0%	0.0%	100.0%
2011	Historical	92.2%	0.0%	0.8%	5.7%	0.1%	1.3%	0.0%	0.0%	0.0%	100.0%
2012	Historical	92.2%	0.0%	0.8%	5.7%	0.1%	1.2%	0.0%	0.0%	0.0%	100.0%
2013	Historical	92.3%	0.0%	0.8%	5.7%	0.1%	1.0%	0.0%	0.1%	0.0%	100.0%
2014	Historical	92.4%	0.0%	0.9%	5.5%	0.1%	1.0%	0.0%	0.1%	0.0%	100.0%
2015	Historical	92.5%	0.0%	0.9%	5.5%	0.1%	1.0%	0.0%	0.0%	0.0%	100.0%
2016	Historical	92.4%	0.0%	0.9%	5.4%	0.1%	1.0%	0.0%	0.2%	0.0%	100.0%
2017	Historical	92.5%	0.0%	0.9%	5.3%	0.1%	1.0%	0.0%	0.1%	0.0%	100.0%
2018	Historical	92.6%	0.0%	0.9%	5.2%	0.1%	1.0%	0.0%	0.1%	0.0%	100.0%
2019	Historical	92.6%	0.0%	0.9%	5.2%	0.1%	1.0%	0.0%	0.1%	0.0%	100.0%
2020	Historical	92.8%	0.0%	0.9%	5.1%	0.1%	1.0%	0.0%	0.1%	0.0%	100.0%
2021	Historical	93.0%	0.0%	0.9%	5.0%	0.1%	1.0%	0.0%	0.0%	0.0%	100.0%
2022	Historical	92.9%	0.0%	0.9%	5.1%	0.1%	1.0%	0.0%	0.0%	0.0%	100.0%
2023	Historical	92.9%	0.0%	0.9%	5.1%	0.1%	1.0%	0.0%	0.0%	0.0%	100.0%
2024	Historical	92.9%	0.0%	0.9%	5.0%	0.1%	1.1%	0.0%	0.0%	0.0%	100.0%
2025	Historical	92.9%	0.0%	0.9%	5.0%	0.1%	1.1%	0.0%	0.0%	0.0%	100.0%
2030	Projected	93.0%	0.0%	0.9%	4.9%	0.1%	1.1%	0.0%	0.0%	0.0%	100.0%
2035	Projected	93.1%	0.0%	0.9%	4.9%	0.1%	1.1%	0.0%	0.0%	0.0%	100.0%
2040	Projected	93.1%	0.0%	0.9%	4.8%	0.1%	1.0%	0.0%	0.0%	0.0%	100.0%
2045	Projected	93.2%	0.0%	0.8%	4.8%	0.1%	1.0%	0.0%	0.0%	0.0%	100.0%
2050	Projected	93.2%	0.0%	0.8%	4.7%	0.1%	1.0%	0.0%	0.0%	0.0%	100.0%

SFR-M = Single-Family Metered

SFR-F = Single-Family Unmetered (Flat Service)

MFR = Multi-Family

COM = Commercial

IND = Industrial

GOV = Government

IRR = Irrigation

OTH = Other/Miscellaneous

REC = Recycled

**California Water Service - Dixon District**  
**Water Supply/Demand Analysis and Projections Summary**

**Table 4. Historical & Projected Sales in Acre-Feet**

YEAR	TYPE	SFR-M	SFR-F <sup>1</sup>	MFR	COM	IND	GOV	IRR	OTH	REC	TOTAL
2000	Historical	1,342	0	85	130	1	39	0	0	0	1,597
2001	Historical	1,386	0	89	127	1	43	0	0	0	1,645
2002	Historical	1,405	0	85	130	1	44	0	0	0	1,665
2003	Historical	1,329	0	85	129	1	85	0	11	0	1,641
2004	Historical	1,376	0	87	125	1	88	2	5	0	1,686
2005	Historical	1,301	0	86	111	0	79	4	6	0	1,587
2006	Historical	1,293	0	73	108	1	78	10	3	0	1,565
2007	Historical	1,333	0	65	122	0	83	12	13	0	1,629
2008	Historical	1,288	0	78	126	0	112	4	1	0	1,609
2009	Historical	1,114	0	66	109	0	102	1	1	0	1,392
2010	Historical	1,036	0	59	104	0	110	1	0	0	1,311
2011	Historical	957	0	71	99	0	94	1	0	0	1,222
2012	Historical	1,009	0	77	104	0	44	1	0	0	1,235
2013	Historical	1,036	0	82	114	0	47	1	3	0	1,284
2014	Historical	903	0	79	99	0	73	2	0	0	1,157
2015	Historical	724	0	74	84	0	39	0	0	0	921
2016	Historical	707	0	71	82	0	32	1	2	0	895
2017	Historical	755	0	79	83	0	40	1	5	0	963
2018	Historical	797	0	78	80	0	44	1	12	0	1,013
2019	Historical	774	0	82	82	0	38	1	2	0	979
2020	Historical	898	0	92	84	0	38	1	4	0	1,118
2021	Historical	850	0	89	80	0	24	1	0	0	1,045
2022	Historical	763	0	97	71	0	27	1	0	0	958
2023	Historical	715	0	83	70	0	24	1	0	0	893
2024	Historical	744	0	85	72	0	34	0	0	0	935
2025	Historical	713	0	74	65	0	31	1	0	0	884
2030	Projected	686	0	76	63	0	28	1	0	0	854
2035	Projected	659	0	73	59	0	26	1	0	0	818
2040	Projected	642	0	70	55	0	24	1	0	0	792
2045	Projected	630	0	69	52	0	23	1	0	0	774
2050	Projected	618	0	67	49	0	21	1	0	0	756

**2025 to 2050**

**Compound Annual Growth Rate (CAGR)** -0.6%

SFR-M = Single-Family Metered

COM = Commercial

IRR = Irrigation

SFR-F = Single-Family Unmetered (Flat Service)

IND = Industrial

OTH = Other/Miscellaneous

MFR = Multi-Family

GOV = Government

REC = Recycled

<sup>1</sup> SFR-F sales is an estimate.

**California Water Service - Dixon District**  
**Water Supply/Demand Analysis and Projections Summary**

**Table 5. Historical & Projected Sales Shares**

YEAR	TYPE	SFR-M	SFR-F <sup>1</sup>	MFR	COM	IND	GOV	IRR	OTH	REC	TOTAL
2000	Historical	84%	0%	5%	8%	0%	2%	0%	0%	0%	100%
2001	Historical	84%	0%	5%	8%	0%	3%	0%	0%	0%	100%
2002	Historical	84%	0%	5%	8%	0%	3%	0%	0%	0%	100%
2003	Historical	81%	0%	5%	8%	0%	5%	0%	1%	0%	100%
2004	Historical	82%	0%	5%	7%	0%	5%	0%	0%	0%	100%
2005	Historical	82%	0%	5%	7%	0%	5%	0%	0%	0%	100%
2006	Historical	83%	0%	5%	7%	0%	5%	1%	0%	0%	100%
2007	Historical	82%	0%	4%	8%	0%	5%	1%	1%	0%	100%
2008	Historical	80%	0%	5%	8%	0%	7%	0%	0%	0%	100%
2009	Historical	80%	0%	5%	8%	0%	7%	0%	0%	0%	100%
2010	Historical	79%	0%	5%	8%	0%	8%	0%	0%	0%	100%
2011	Historical	78%	0%	6%	8%	0%	8%	0%	0%	0%	100%
2012	Historical	82%	0%	6%	8%	0%	4%	0%	0%	0%	100%
2013	Historical	81%	0%	6%	9%	0%	4%	0%	0%	0%	100%
2014	Historical	78%	0%	7%	9%	0%	6%	0%	0%	0%	100%
2015	Historical	79%	0%	8%	9%	0%	4%	0%	0%	0%	100%
2016	Historical	79%	0%	8%	9%	0%	4%	0%	0%	0%	100%
2017	Historical	78%	0%	8%	9%	0%	4%	0%	1%	0%	100%
2018	Historical	79%	0%	8%	8%	0%	4%	0%	1%	0%	100%
2019	Historical	79%	0%	8%	8%	0%	4%	0%	0%	0%	100%
2020	Historical	80%	0%	8%	7%	0%	3%	0%	0%	0%	100%
2021	Historical	81%	0%	9%	8%	0%	2%	0%	0%	0%	100%
2022	Historical	80%	0%	10%	7%	0%	3%	0%	0%	0%	100%
2023	Historical	80%	0%	9%	8%	0%	3%	0%	0%	0%	100%
2024	Historical	80%	0%	9%	8%	0%	4%	0%	0%	0%	100%
2025	Historical	81%	0%	8%	7%	0%	3%	0%	0%	0%	100%
2030	Projected	80%	0%	9%	7%	0%	3%	0%	0%	0%	100%
2035	Projected	81%	0%	9%	7%	0%	3%	0%	0%	0%	100%
2040	Projected	81%	0%	9%	7%	0%	3%	0%	0%	0%	100%
2045	Projected	81%	0%	9%	7%	0%	3%	0%	0%	0%	100%
2050	Projected	82%	0%	9%	6%	0%	3%	0%	0%	0%	100%

SFR-M = Single-Family Metered

COM = Commercial

IRR = Irrigation

SFR-F = Single-Family Unmetered (Flat Service)

IND = Industrial

OTH = Other/Miscellaneous

MFR = Multi-Family

GOV = Government

REC = Recycled

<sup>1</sup> SFR-F sales is an estimate.

**California Water Service - Dixon District**  
**Water Supply/Demand Analysis and Projections Summary**

**Table 6. Historical & Projected Sales Per Service in Gallons/Service/Day**

YEAR	TYPE	SFR-M	SFR-F <sup>1</sup>	MFR	COM	IND	GOV	IRR	OTH	REC	TOTAL
2000	Historical	454	0	4,509	858	182	1,510	0	0	0	507
2001	Historical	470	0	4,654	841	268	1,708	0	0	0	522
2002	Historical	475	0	4,486	854	200	1,663	0	0	0	527
2003	Historical	450	0	4,486	846	130	3,041	0	#####	0	519
2004	Historical	466	0	4,581	818	180	3,264	870	4,981	0	533
2005	Historical	437	0	4,530	728	79	2,872	788	1,925	0	498
2006	Historical	433	0	3,848	708	128	2,776	1,322	645	0	489
2007	Historical	448	0	3,575	752	95	3,031	1,529	3,000	0	509
2008	Historical	441	0	3,560	729	105	3,245	1,039	314	0	509
2009	Historical	384	0	2,811	638	95	2,555	461	301	0	443
2010	Historical	354	0	3,619	598	65	2,746	957	118	0	415
2011	Historical	326	0	2,896	547	83	2,328	728	762	0	384
2012	Historical	343	0	2,981	578	109	1,143	482	0	0	388
2013	Historical	352	0	3,201	629	94	1,418	446	1,925	0	402
2014	Historical	306	0	2,866	565	89	2,335	1,551	40	0	363
2015	Historical	245	0	2,555	482	87	1,238	328	197	0	289
2016	Historical	239	0	2,332	475	79	986	496	501	0	280
2017	Historical	254	0	2,604	487	76	1,178	596	1,824	0	299
2018	Historical	262	0	2,572	468	92	1,322	1,139	3,267	0	309
2019	Historical	252	0	2,707	475	88	1,149	859	405	0	295
2020	Historical	286	0	3,066	487	102	1,099	1,228	1,811	0	331
2021	Historical	267	0	2,947	468	72	723	518	0	0	305
2022	Historical	239	0	3,224	407	52	797	844	0	0	279
2023	Historical	224	0	2,739	400	51	679	621	16	0	260
2024	Historical	233	0	2,811	415	61	922	408	713	0	272
2025	Historical	224	0	2,447	384	55	827	566	311	0	258
2030	Projected	213	0	2,514	370	56	750	526	347	0	247
2035	Projected	203	0	2,405	345	56	698	521	347	0	234
2040	Projected	195	0	2,329	322	56	652	516	347	0	225
2045	Projected	190	0	2,272	302	56	612	511	347	0	217
2050	Projected	184	0	2,219	284	56	575	507	347	0	210

**2025 to 2050**

**Compound Annual Growth Rate (CAGR)** -0.8%

SFR-M = Single-Family Metered

COM = Commercial

IRR = Irrigation

SFR-F = Single-Family Unmetered (Flat Service)

IND = Industrial

OTH = Other/Miscellaneous

MFR = Multi-Family

GOV = Government

REC = Recycled

<sup>1</sup> SFR-F sales is an estimate.

**California Water Service - Dixon District**  
**Water Supply/Demand Analysis and Projections Summary**

**Table 7. Historical & Projected Per Capita Water Use in Gallons/Person/Day**

YEAR	TYPE	SFR-M	SFR-F <sup>1</sup>	MFR	COM	IND	GOV	IRR	OTH	REC	TOTAL
2000	Historical	128	0	8	12	0	4	0	0	0	152
2001	Historical	131	0	8	12	0	4	0	0	0	156
2002	Historical	133	0	8	12	0	4	0	0	0	157
2003	Historical	125	0	8	12	0	8	0	1	0	155
2004	Historical	129	0	8	12	0	8	0	0	0	158
2005	Historical	122	0	8	10	0	7	0	1	0	149
2006	Historical	121	0	7	10	0	7	1	0	0	146
2007	Historical	124	0	6	11	0	8	1	1	0	152
2008	Historical	120	0	7	12	0	10	0	0	0	149
2009	Historical	103	0	6	10	0	9	0	0	0	129
2010	Historical	96	0	5	10	0	10	0	0	0	121
2011	Historical	89	0	7	9	0	9	0	0	0	113
2012	Historical	94	0	7	10	0	4	0	0	0	115
2013	Historical	97	0	8	11	0	4	0	0	0	120
2014	Historical	85	0	7	9	0	7	0	0	0	109
2015	Historical	68	0	7	8	0	4	0	0	0	87
2016	Historical	67	0	7	8	0	3	0	0	0	85
2017	Historical	72	0	7	8	0	4	0	0	0	92
2018	Historical	76	0	7	8	0	4	0	1	0	97
2019	Historical	74	0	8	8	0	4	0	0	0	94
2020	Historical	87	0	9	8	0	4	0	0	0	108
2021	Historical	81	0	8	8	0	2	0	0	0	99
2022	Historical	72	0	9	7	0	3	0	0	0	91
2023	Historical	68	0	8	7	0	2	0	0	0	85
2024	Historical	71	0	8	7	0	3	0	0	0	89
2025	Historical	68	0	7	6	0	3	0	0	0	84
2030	Projected	65	0	7	6	0	3	0	0	0	80
2035	Projected	61	0	7	5	0	2	0	0	0	76
2040	Projected	59	0	6	5	0	2	0	0	0	73
2045	Projected	57	0	6	5	0	2	0	0	0	71
2050	Projected	56	0	6	4	0	2	0	0	0	68

**2025 to 2050**

**Compound Annual Growth Rate (CAGR)** -0.8%

SFR-M = Single-Family Metered

COM = Commercial

IRR = Irrigation

SFR-F = Single-Family Unmetered (Flat Service)

IND = Industrial

OTH = Other/Miscellaneous

MFR = Multi-Family

GOV = Government

REC = Recycled

<sup>1</sup> SFR-F sales is an estimate.

**California Water Service - Dixon District**  
**Water Supply/Demand Analysis and Projections Summary**

**Table 8. Historical & Projected Non-Revenue Water (NRW) in Acre-Feet<sup>1</sup>**

YEAR	TYPE	AUTHORIZED UNBILLED USE	APPARENT LOSS	REAL LOSS	RECYCLED LOSS	TOTAL
2000	Historical					72
2001	Historical					98
2002	Historical					98
2003	Historical					180
2004	Historical					237
2005	Historical					112
2006	Historical					115
2007	Historical					96
2008	Historical					142
2009	Historical					166
2010	Historical					192
2011	Historical					177
2012	Historical					170
2013	Historical					263
2014	Historical					282
2015	Historical					230
2016	Historical	8	23	188	0	219
2017	Historical	8	25	182	0	215
2018	Historical	8	26	195	0	230
2019	Historical	8	26	255	0	289
2020	Historical	58	29	186	0	273
2021	Historical	39	27	200	0	266
2022	Historical	34	24	221	0	279
2023	Historical	49	23	312	0	383
2024	Historical	46	24	332	0	402
2025	Historical	43	24	288	0	354
2030	Projected	43	24	161	0	228
2035	Projected	44	24	163	0	230
2040	Projected	44	24	164	0	233
2045	Projected	45	25	166	0	235
2050	Projected	45	25	167	0	237

<sup>1</sup>Total non-revenue water estimates are available prior to 2016, calculated as total water production less metered sales and estimated unmetered customer water use. Starting in 2016, non-revenue water estimates come from the Water Loss Report for the District that is filed annually with the Department of Water Resources.

**California Water Service - Dixon District**  
**Water Supply/Demand Analysis and Projections Summary**

**Table 9. Historical & Projected Non-Revenue Water in GCD<sup>1, 2</sup>**

YEAR	TYPE	SERVICES	AUTHORIZED UNBILLED USE	APPARENT LOSS	REAL LOSS	RECYCLED LOSS	TOTAL
2000	Historical	2,886					22
2001	Historical	2,883					30
2002	Historical	2,892					30
2003	Historical	2,892					56
2004	Historical	2,893					73
2005	Historical	2,919					34
2006	Historical	2,932					35
2007	Historical	2,927					29
2008	Historical	2,895					44
2009	Historical	2,875					52
2010	Historical	2,892					59
2011	Historical	2,915					54
2012	Historical	2,917					52
2013	Historical	2,924					80
2014	Historical	2,919					86
2015	Historical	2,919					70
2016	Historical	2,938	2	7	57	0	66
2017	Historical	2,938	2	8	55	0	65
2018	Historical	3,010	2	8	58	0	68
2019	Historical	2,993	2	8	76	0	86
2020	Historical	3,093	17	8	54	0	79
2021	Historical	3,139	11	8	57	0	76
2022	Historical	3,144	10	7	63	0	79
2023	Historical	3,139	14	6	89	0	109
2024	Historical	3,149	13	7	94	0	114
2025	Historical	3,141	12	7	82	0	101
2030	Projected	3,170	12	7	45	0	64
2035	Projected	3,199	12	7	45	0	64
2040	Projected	3,229	12	7	45	0	64
2045	Projected	3,260	12	7	45	0	64
2050	Projected	3,290	12	7	45	0	64

<sup>1</sup>GCD = gallons/connection/day, calculated with total connections (active + inactive)

<sup>2</sup>Total non-revenue water estimates are available prior to 2016, calculated as total water production less metered sales and estimated unmetered customer water use. Starting in 2016, non-revenue water estimates come from the District's Water Loss Report filed annually with the Department of Water Resources.

**California Water Service - Dixon District  
Water Supply/Demand Analysis and Projections Summary**

<b>Table 10. Projected Baseline and Adjusted Potable Demand in Acre-Feet</b>					
	<b>2030</b>	<b>2035</b>	<b>2040</b>	<b>2045</b>	<b>2050</b>
<b>Baseline Potable Water Demand</b>	1,265	1,276	1,286	1,297	1,308
<b>Demand Adjustments</b>					
Passive Conservation	-28	-49	-66	-80	-94
Active Conservation	-23	-40	-51	-58	-65
Water Service Cost Growth	-6	-11	-16	-21	-25
Household Income Growth	0	0	0	0	0
Water Loss Management	-126	-127	-128	-130	-131
<b>Total Adjustments</b>	<b>-183</b>	<b>-227</b>	<b>-261</b>	<b>-289</b>	<b>-315</b>
<b>Adjusted Potable Water Demand</b>	<b>1,082</b>	<b>1,048</b>	<b>1,025</b>	<b>1,008</b>	<b>993</b>

<b>Table 11. Projected Single-Dry-Year and Multi-Dry-Year Demand in Acre-Feet</b>					
	<b>2030</b>	<b>2035</b>	<b>2040</b>	<b>2045</b>	<b>2050</b>
Normal Year	1,082	1,048	1,025	1,008	993
Single-Dry-Year	1,126	1,091	1,067	1,049	1,033
Multi-Dry-Year	1,153	1,117	1,092	1,075	1,059

**California Water Service - Dixon District**  
**Water Supply/Demand Analysis and Projections Summary**

**Table 12. Historical & Projected Demand in Acre-Feet**

YEAR	TYPE	SALES	NRW <sup>1</sup>	DEMAND <sup>2</sup>	GPCD <sup>3</sup>
2000	Historical	1,597	72	1,669	159
2001	Historical	1,645	98	1,743	165
2002	Historical	1,665	98	1,763	167
2003	Historical	1,641	180	1,821	172
2004	Historical	1,686	237	1,922	181
2005	Historical	1,587	112	1,698	159
2006	Historical	1,565	115	1,680	157
2007	Historical	1,629	96	1,725	161
2008	Historical	1,609	142	1,751	162
2009	Historical	1,392	166	1,558	144
2010	Historical	1,311	192	1,503	139
2011	Historical	1,222	177	1,399	130
2012	Historical	1,235	170	1,405	131
2013	Historical	1,284	263	1,547	145
2014	Historical	1,157	282	1,438	135
2015	Historical	921	230	1,151	109
2016	Historical	895	219	1,114	106
2017	Historical	963	215	1,178	112
2018	Historical	1,013	230	1,242	119
2019	Historical	979	289	1,267	122
2020	Historical	1,118	273	1,391	134
2021	Historical	1,045	266	1,311	125
2022	Historical	958	279	1,238	118
2023	Historical	893	383	1,276	121
2024	Historical	935	402	1,337	127
2025	Historical	884	354	1,238	118
2030	Projected	854	228	1,082	102
2035	Projected	818	230	1,048	98
2040	Projected	792	233	1,025	95
2045	Projected	774	235	1,008	92
2050	Projected	756	237	993	90
<b>2025 to 2050</b>					
<b>Compound Annual Growth Rate (CAGR)</b>				-0.9%	-1.1%

<sup>1</sup>Non-Revenue Water (NRW)

<sup>2</sup>Demand is equal to the sum of water sales and non-revenue water.

<sup>3</sup>Gallons per capita per day.

**California Water Service - Dixon District**  
**Water Supply/Demand Analysis and Projections Summary**

**Table 13. Historical Water Production in Acre-Feet**

YEAR	TYPE	WELLS	SURFACE	PURCHASED	RECYCLED <sup>1</sup>	OTHER <sup>2</sup>	TOTAL
2000	Historical	1,669	0	0	0	0	1,669
2001	Historical	1,743	0	0	0	0	1,743
2002	Historical	1,763	0	0	0	0	1,763
2003	Historical	1,821	0	0	0	0	1,821
2004	Historical	1,922	0	0	0	0	1,922
2005	Historical	1,698	0	0	0	0	1,698
2006	Historical	1,680	0	0	0	0	1,680
2007	Historical	1,725	0	0	0	0	1,725
2008	Historical	1,751	0	0	0	0	1,751
2009	Historical	1,558	0	0	0	0	1,558
2010	Historical	1,503	0	0	0	0	1,503
2011	Historical	1,399	0	0	0	0	1,399
2012	Historical	1,405	0	0	0	0	1,405
2013	Historical	1,547	0	0	0	0	1,547
2014	Historical	1,438	0	0	0	0	1,438
2015	Historical	1,151	0	0	0	0	1,151
2016	Historical	1,113	0	0	0	0	1,113
2017	Historical	1,177	0	0	0	0	1,177
2018	Historical	1,242	0	0	0	0	1,242
2019	Historical	1,267	0	0	0	0	1,267
2020	Historical	1,391	0	0	0	0	1,391
2021	Historical	1,311	0	0	0	0	1,311
2022	Historical	1,238	0	0	0	0	1,238
2023	Historical	1,280	0	0	0	0	1,280
2024	Historical	1,337	0	0	0	0	1,337
2025	Historical	1,348	0	0	0	0	1,348

<sup>1</sup>Includes water from recycling and desalter supply sources.

<sup>2</sup>Other water may include leased and wheeled water, as well as backwash and wastewater from treatment plant operation. Negative volumes represent production that has not entered the distribution system.

**California Water Service - Dixon District**  
**Water Supply/Demand Analysis and Projections Summary**



**Table 14. Historical Water Production Shares**

<b>YEAR</b>	<b>TYPE</b>	<b>WELLS</b>	<b>SURFACE</b>	<b>PURCHASED</b>	<b>RECYCLED<sup>1</sup></b>	<b>OTHER<sup>2</sup></b>	<b>TOTAL</b>
2000	Historical	100%	0%	0%	0%	0%	100%
2001	Historical	100%	0%	0%	0%	0%	100%
2002	Historical	100%	0%	0%	0%	0%	100%
2003	Historical	100%	0%	0%	0%	0%	100%
2004	Historical	100%	0%	0%	0%	0%	100%
2005	Historical	100%	0%	0%	0%	0%	100%
2006	Historical	100%	0%	0%	0%	0%	100%
2007	Historical	100%	0%	0%	0%	0%	100%
2008	Historical	100%	0%	0%	0%	0%	100%
2009	Historical	100%	0%	0%	0%	0%	100%
2010	Historical	100%	0%	0%	0%	0%	100%
2011	Historical	100%	0%	0%	0%	0%	100%
2012	Historical	100%	0%	0%	0%	0%	100%
2013	Historical	100%	0%	0%	0%	0%	100%
2014	Historical	100%	0%	0%	0%	0%	100%
2015	Historical	100%	0%	0%	0%	0%	100%
2016	Historical	100%	0%	0%	0%	0%	100%
2017	Historical	100%	0%	0%	0%	0%	100%
2018	Historical	100%	0%	0%	0%	0%	100%
2019	Historical	100%	0%	0%	0%	0%	100%
2020	Historical	100%	0%	0%	0%	0%	100%
2021	Historical	100%	0%	0%	0%	0%	100%
2022	Historical	100%	0%	0%	0%	0%	100%
2023	Historical	100%	0%	0%	0%	0%	100%
2024	Historical	100%	0%	0%	0%	0%	100%
2025	Historical	100%	0%	0%	0%	0%	100%



<sup>1</sup>Includes water from recycling and desalter supply sources.

<sup>2</sup>Other water may include leased and wheeled water, as well as backwash and wastewater from treatment plant operation. Negative volumes represent production that has not entered the distribution system.



**California Water Service - Dixon District**  
**Water Supply/Demand Analysis and Projections Summary**



**California Water Service - Dixon District**  
**Water Supply/Demand Analysis and Projections Summary**





**California Water Service - Dixon District**  
**Water Supply/Demand Analysis and Projections Summary**



SFR-M = Single-Family Metered	COM = Commercial	IRR = Irrigation
SFR-F = Single-Family Unmetered (Flat Service)	IND = Industrial	OTH = Other/Miscellaneous
MFR = Multi-Family	GOV = Government	REC = Recycled

<sup>1</sup>Difference between the production and sales data series in Figure 5 is non-revenue water.

**California Water Service - Dixon District**  
**Water Supply/Demand Analysis and Projections Summary**



California Water Service - Dixon District  
Water Supply/Demand Analysis and Projections Summary

---

Water Supply Assessment (WSA) Information

---

---

Table 15. WSA Demand Treated as Additive to Regional Growth Projections

---

WSA	% of WSA Demand Added to Projection <sup>1</sup>
No WSAs	

---

<sup>1</sup>Percent of WSA demand considered to be additive to regional growth forecast.

California Water Service - Dixon District  
 Water Supply/Demand Analysis and Projections Summary

**Compound Annual Growth Rates (CAGR)**

**Table 16. Historical Service Growth**

<b>Class</b>	<b>2020 to 2025</b>	<b>2015 to 2025</b>	<b>2010 to 2025</b>	<b>2005 to 2025</b>
SFR <sup>1</sup>	0.3%	0.8%	0.6%	0.3%
MFR	0.1%	0.4%	4.2%	2.3%
COM	-0.2%	-0.2%	-0.2%	0.6%
IND	0.0%	0.0%	0.0%	-1.8%
GOV	1.4%	1.6%	-0.5%	1.5%
IRR	0.0%	0.0%	0.0%	-7.3%
OTH	-24.2%	0.0%	1.2%	-7.9%
REC	0.0%	0.0%	0.0%	0.0%

<sup>1</sup>Total metered and unmetered single-family services

**Table 17. Historical Growth between Decennial Censuses**

<b>Series</b>	<b>2010 to 2020</b>	<b>2000 to 2020</b>	<b>1990 to 2020</b>
Population	-0.45%	-0.07%	0.53%
Total Housing Units	-0.47%	0.23%	0.60%
Occupied Housing Units	-0.20%	0.18%	0.57%

**Table 18. Regional Growth Forecasts from Land Use Planning Entities**

**Source:** ABAG PBA50 TAZ Forecasts

**Range:** 2015-2050

<b>Series</b>	<b>CAGR</b>
Population	0.20%
Housing	0.58%
Employment	0.12%

**California Water Service - Dixon District**  
**Water Supply/Demand Analysis and Projections Summary**

---

**Compound Annual Growth Rates (CAGR) Used in Demand Projections**

---



---

**Table 19. Historical Service Growth**

---

<b>Time Series</b>	<b>Basis</b>	<b>Projection CAGR</b>	<b>Override CAGR<sup>1</sup></b>
Population	Metered Single-Family Services 2020-2025 CAGR	0.32%	0.20%
<b>Services</b>			
SFR	Metered Single-Family Services 2020-2025 CAGR	0.32%	0.20%
MFR	No Projected Growth	0.00%	
COM	No Projected Growth	0.00%	
IND	No Projected Growth	0.00%	
GOV	No Projected Growth	0.00%	
IRR	No Projected Growth	0.00%	
OTH	No Projected Growth	0.00%	
REC	No Projected Growth	0.00%	
SFR = Single-Family		IND = Industrial	OTH = Other/Miscellaneous
MFR = Multi-Family		GOV = Government	REC = Recycled
COM = Commercial		IRR = Irrigation	

---

<sup>1</sup>If value is present, then the demand model uses this value instead of the Basis value.

## **Appendix F: Climate Change Studies – Executive Summaries**

- Potential Climate Change Impacts on the Water Supplies of California Water Service
- Climate Change – Water Resource Monitoring and Adaptation Plan – Phase 1 and Phase 2

# Potential Climate Change Impacts on the Water Supplies of California Water Service

---

*Prepared by*

Gary Fiske and Associates, Inc.  
Balance Hydrologics, Inc.

*January 2016*



# Executive Summary

---

## Introduction

California Water Service Company (Cal Water) provides water service to roughly 478,000 customers – about 1.7 million people – located in 83 state-wide communities in 24 service districts. Cal Water’s districts rely on a variety of supply sources, including local groundwater, local surface water, and imported supplies. It is critical for Cal Water to gain a better understanding of the potential impacts of climate change on the availability of those supplies. Impacts are inherently uncertain, but Cal Water believes that the only responsible course is to carefully incorporate climate change into its ongoing water supply planning.

The present project and report represent a first step in that path. In order for Cal Water to determine how its long-term water supply planning should reflect climate change impacts, it must first have an understanding of what the impacts of climate change on its supply sources might be. That is the purpose of this study.

The work reported on here focuses on the sample of Cal Water districts highlighted in Figure ES-1. These districts account for 85% of Cal Water’s total 2014 production and reflect the diversity of all Cal Water districts, including geographic, hydrologic, and climatic conditions and primary and secondary supply sources.

Changes in climate can affect the availability of local groundwater and surface water supplies, as well as purchased imported supplies. This study separately addresses the impacts on each of these for each sample district. It relies on the best available projections of changes in climate (temperature and precipitation) through the end of the century. It then uses the climate projections to examine how surface water flows and groundwater recharge rates may change.

For imported supplies, this study relies on studies already completed by wholesale providers where possible. Where no such studies have been done or where the data from such studies was unavailable, other approaches were developed to estimate climate change impacts on these supplies.

The results reported here provide an integrated view of how projected climate changes may affect water supply availability for Cal Water’s service districts. The results also represent a first step in integrating potential future climate change impacts into Cal Water’s ongoing supply planning. Because of the inherent uncertainties, a nuanced risk assessment may be needed to guide the incorporation of these results into long-range planning. Beyond the Company’s supply/infrastructure planning, the results also can affect the Company’s triennial General Rate Cases; they may also have potential operational implications.

**Figure ES- 1. Cal Water Service Districts with Sample Districts Highlighted**



## Estimating Changes in Climate

Climate change is primarily driven by increased concentrations of greenhouse gases (GHGs) in the atmosphere. The trajectory of future climate change is a function of the rate at which those concentrations are projected to increase and the manner in which the atmosphere and oceans respond to increased concentrations. Both are difficult to model. Thus, while the scientific community overwhelmingly agrees that climate change will occur (and indeed may already have begun), the trajectory of those changes is very uncertain.

The projections of temperature and precipitation that underlie this study are based on 40 of the latest Global Circulation Models (GCMs) run as part of the Coupled Model Intercomparison Project Phase 5 (CMIP5). Generally speaking, this type of approach is termed an ensemble analysis, for which the downscaled climate projections for any particular Cal Water Service District were based on the median of the 40 downscaled GCM datasets. The GCMs used by the analysis are driven by two GHG emission pathways that bound the possible trajectories of GHG concentrations.

## Impacts of Climate Change on Water Supplies

The supplies for each district consist of a mix of local surface water, local groundwater, and/or purchased imports. Climate change impacts were estimated for each of these components. The approaches used for each are described below. Based on the breakdown of district production among the supply sources, Table ES-1 shows the ranges of projected overall climate change impacts on available supply, relative to the historic average.<sup>1</sup> Table ES-2 groups this vulnerability into 4 categories of expected change, and Figure ES-2 maps the end-of-century vulnerability.

---

<sup>1</sup> The historical averages used here, and elsewhere in this report, are based on the entire range of historical data available for the district-specific analyses. These ranges vary across districts, and are specified within the district-specific technical memoranda.

**Table ES- 1. Projected Changes in Available Supply due to Climate Change**


District		Percentage Change in Supply		
		2020	2050	2100
BK	Minimum	-10%	-10%	-12%
	Maximum	-12%	-16%	-20%
VIS	Minimum	-7%	-8%	-8%
	Maximum	-9%	-10%	-14%
KRV	Minimum	-13%	-16%	-19%
	Maximum	-16%	-21%	-31%
MPS/SSF/BG	Minimum	0%	-2%	-6%
	Maximum	0%	-7%	-15%
LAS	Minimum	-3%	-3%	-10%
	Maximum	-4%	-18%	-28%
CH	Minimum	2%	2%	0%
	Maximum	3%	1%	-3%
ORO	Minimum	0%	8%	5%
	Maximum	0%	-8%	-7%
DOM/HR/PV	Minimum	0%	0%	-1%
	Maximum	0%	-2%	-3%
STK	Minimum	0%	0%	-8%
	Maximum	0%	-14%	-17%
SLN	Minimum	-6%	-6%	-6%
	Maximum	-7%	-7%	-7%

**Table ES- 2. Categories of Projected Supply Vulnerability**

District	Supply Vulnerability		
	2020	2050	2100
KRV	3	4	4
BK	3	3	4
LAS	1	3	4
VIS	2	2	3
STK	1	2	3
SLN	2	2	2
MPS/SSF/BG	1	1	3
DOM/HR/PV	1	1	1
ORO	1	1	1
CH	1	1	1

Districts in Category 1 expect <5% reduction in supply. Category 2 indicates a reduction of 5-10%. Category 3 indicates an expected reduction of 10-15%. Category 4 reductions exceed 15%.

Figure ES- 2. Cal Water 2100 Vulnerability to Climate Change



Vulnerability levels:  
Green = Low  
Yellow = Moderate  
Light Red = High  
Dark Red = Very High

## Estimating Climate Change Impacts on Local Surface Supplies

For those Cal Water districts that obtain a portion of their water supplies from local surface water, projected average annual precipitation in each of three forecast years (2020, 2050, 2100) were compared to historical precipitation to estimate the projected average annual discharge for that forecast year. Table ES-3 shows the estimated percent changes in surface water availability compared to historical averages.

**Table ES- 3. Estimated Impacts on Local Surface Supply Availability**

District		Percent Change in Runoff		
		2020	2050	2100
BK	Minimum Impact	-17%	-18%	-19%
	Maximum Impact	-18%	-19%	-23%
KRV	Minimum Impact	-17%	-18%	-19%
	Maximum Impact	-18%	-19%	-23%
MPS/SSF/BG	Minimum Impact	+3%	+6%	+12%
	Maximum Impact	+3%	+5%	+6%

Of the three districts, the two in the southern San Joaquin Valley are projected to experience significant reductions in their local surface supplies. In contrast, the Bear Gulch district surface supply is forecast to increase.

## Estimating Climate Change Impacts on Local Groundwater Supplies

Climate change impacts on Cal Water’s local groundwater supplies result from changes in projected groundwater recharge. The three groundwater recharge components include:


- Local river sources;
- Direct recharge from precipitation on the groundwater basin; and
- Recharge from agricultural and urban deep percolation.

The analysis first estimated the split of local recharge among these three components using geographic and geologic data, geochemical markers, and previously published reports and other supporting information. The climate change impacts on each component were then estimated, consolidated into overall projections of recharge impacts, and compared to estimated historical recharge rates.

Estimates of impacts on river recharge used the methodology for local surface supply described above. For the purposes of this phase of work, it was assumed that the change in recharge from the river is proportional to the change in total annual discharge. The estimated amount of water that will recharge directly into a groundwater basin from rain (or snow) is based on a balance of evapotranspiration (ET), precipitation rates, and soil

water capacity. Recharge is estimated using both historical and projected precipitation and temperature data. Decadal averages in projected recharge are then used to calculate long-term trends. This is illustrated in Figure ES-3 for Kern River Valley.

**Figure ES- 3. Historic and Projected Decadal Direct-Precipitation Recharge for Kern River Valley**



A quantitative projection of recharge from deep percolation beneath irrigated fields and urban areas is beyond the scope of this phase. Instead, districts for which a significant proportion of recharge is from agricultural and urban water are identified and expected trends under climate change of this water source for those districts are estimated. At-risk service areas with decreasing agricultural and urban water sources can be explored further in future work.

The estimated percentage impacts on each of the recharge components are multiplied by the expected fractions that each component is of total recharge to calculate the range of expected recharge reductions. Table ES-4 shows those results for each district, excluding the impacts of urban/agricultural applied water percolation.

Actual impacts on Cal Water’s ability to pump groundwater may be less than these recharge reductions because the storage volumes in different basins have differing degrees of responsiveness to changes in recharge. The degree to which changes in recharge volumes translate into available groundwater supply is a function of the hydrogeologic attributes of the basin. A detailed understanding of those characteristics would require a level of modeling that is well beyond the scope of this phase of work. Instead, the estimates of basin responsiveness were based on the historical record of how the basin’s water level has varied with recent climate variability. For some districts, the basin appears to be highly responsive, while for others changes in climate do not have much impact.

**Table ES- 4. Projected Changes in Average Annual Groundwater Recharge**

District		Percentage Change in Recharge		
		2020	2050	2100
BK	Minimum	-14%	-15%	-15%
	Maximum	-14%	-15%	-18%
VIS	Minimum	-9%	-10%	-11%
	Maximum	-9%	-10%	-14%
KRV	Minimum	-13.4%	-19%	-23%
	Maximum	-15%	-22%	-35%
MPS/SSF/BG	Minimum	-2%	-4%	-6%
	Maximum	-2%	-6%	-12%
LAS	Minimum	-7%	-8%	-13%
	Maximum	-8%	-18%	-25%
CH	Minimum	6%	4%	1%
	Maximum	6%	2%	-4%
ORO	Minimum	0%	0%	0%
	Maximum	0%	0%	0%
DOM/HR/PV	Minimum	0%	0%	0%
	Maximum	0%	0%	0%
STK	Minimum	-2%	-3%	-6%
	Maximum	-2%	-4%	-7%
SLN	Minimum	-7%	-7%	-7%
	Maximum	-7%	-7%	-7%


The overall risk to Cal Water’s groundwater supplies for each district is based on the expected recharge reductions and the expected responsiveness of basin water level to those reductions. Table ES-5 rates each district’s groundwater supply risk on a 1-5 scale, with 1 indicating little or no risk and 5 indicating high risk. Figure ES-4 is a visual depiction of these ratings.

Generally speaking, the groundwater supply impacts are large for the districts in the southern San Joaquin Valley. The Los Altos District also shows a high impact, largely because a significant portion of its recharge is from imported supplies, which are forecast to decrease significantly. Further north in the Central Valley, groundwater supplies are less affected. The Bay Area and Los Angeles Basin districts also show relatively smaller impacts.

**Table ES- 5. District Groundwater Risk Ratings**

District	Rating
BK	5
KRV	5
LAS	5
VIS	4
SLN	3
CH	2
MPS/SSF/BG	2
STK	2
ORO	1
DOM/HR/PV	1

**Figure ES- 4. Groundwater Risk Ratings**



## Impacts of Climate Change on Imported Water Supplies

About half of Cal Water’s supply is imported water that is purchased from wholesale suppliers. The supply and delivery systems of these suppliers are generally very complex and it is impossible within the confines of this project to independently model the impacts of climate change on those systems. The analysis therefore relied on available data, including the results of any climate change modeling that these suppliers themselves have done and other indicators of climate change impacts.

As a result, the climate change scenarios on which the estimates of impacts on different wholesale supplies are based will differ from one another and from the approach described above for the analysis of local supply impacts. The time frames of the results also differ. However, despite those limitations, important information about potential future climate change impacts on wholesale water supply availability was developed. Table ES-6 compares summary measures of central tendency for the potential district-specific climate change impacts on the availability of imported supplies.

**Table ES- 6. Projected Climate Change Impacts on Imported Supplies**

<b>District</b>	<b>Source</b>	<b>Mid-Century</b>	<b>Late-Century</b>
BK	SWP	-7%	-17%
LAS	SWP, CVP	-9%	-21%
ORO	SWP	-1%	-3%
MPS/SSF/BG	SFPUC	-10%	-20%
DOM/HR/PV	MWD	-1% to -2%	-2% to -5%
STK	USBR	-5%	-10%

## Conclusions and Next Steps

The study results indicate significant risks for some districts. This points to the need for Cal Water to account for these risks in its future water supply planning if it is to minimize the adverse effects on its customers. The sole focus of this effort was to assess the potential climate change impacts on Cal Water’s supplies. That is an important first step in integrating climate change into supply planning, but this study was not designed to:

- Analyze the impacts of these future supply limitations on Cal Water’s ability to serve future customer demands. This is a function of such factors as water rights and contractual arrangements, how future demands are forecast to grow, how water conservation programming will affect those demands, and how Cal Water might modify the manner in which it operates its system.

- Develop mitigation plan to evaluate how potential supply and infrastructure investments and/or acquisition of new supplies might address any adverse impacts on water supply reliability.
- Formally assess alternative approaches to incorporating climate change in Cal Water's supply planning.

Possible next steps for Cal Water include:

- Methodological enhancements to reduce some of the uncertainties in the results reported herein;
- Development and acquisition of better and more complete data;
- Extending this study to other Cal Water districts;
- Developing a plan to mitigate anticipated climate change impacts on supply; and
- Integrating climate change into the Company's ongoing water supply planning.

Despite the study's limitations and uncertainties, three critical messages emerge:

- Cal Water supplies in the 21<sup>st</sup> century are likely to be adversely affected by climate change.
- These impacts will vary considerably across districts, depending on geography and source mix. For some districts, the impacts can be significant; for others, little or no impacts are projected.
- The impacts will generally increase over time. Anticipated late-century impacts are forecast to be significantly higher in some districts than impacts at mid-century. Moreover, during the period that climate change is forecast to increasingly constrain supplies, demands are also generally forecast to increase, further exacerbating the adverse impacts on water supply reliability.



# Climate Change- Water Resource Monitoring and Adaptation Plan – Phase 1

December 17, 2020

California Water Service  
1720 North First Street  
San Jose, CA 95112

Submitted by:  
ICF  
555 W 5th St  
Suite 3100  
Los Angeles, CA 90013

## Executive Summary

Shifts in the frequency and severity of natural hazards resulting from climate change, often referred to as climate hazards, increasingly threaten water resources in California. These relevant climate hazards include reductions to snowpack, greater concentrations of precipitation in both a shorter rain season and isolated atmospheric river events, and more volatility between wet and dry water years.

To identify and prepare for impacts from these hazards, California Water Service (Cal Water) is seeking to identify climate change vulnerabilities to water supplies, operations and facilities, and to develop adaptation strategies to address those vulnerabilities through a Climate Change Water Resources Monitoring and Adaptation Plan. This body of work is intended to provide Cal Water with information to inform decisions on water system/asset management and resource planning to better prepare for and respond to current and projected changes to climate. This work represents a forward-looking approach in addressing climate risks for California utilities, as the large majority of water wholesaler and utilities have not completed climate vulnerability and adaptation plans.

In the first phase of this effort, the ICF team collaborated with Cal Water to conduct a literature and tools review as the foundation for subsequent phases of work. In Phase 2 of this project, the ICF team and Cal Water will undertake a vulnerability assessment of Cal Water's facilities and operations by developing an assessment approach that evaluates climate impacts to Cal Water, identifies asset vulnerabilities, and prioritizes climate risks. Phase 3 will focus on an assessment of climate-driven impacts to water supply resources and demand. This first phase of research and assessment will provide Cal Water with a clear "lay of the land" in understanding available methodologies and lessons learned in conducting vulnerability assessments and developing adaptation plans in the water sector. This work can provide key insights for Cal Water, industry practitioners, and Cal Water customers on best practices and needs in climate vulnerability and adaptation efforts.

This first phase will also act as a foundation for Cal Water to build on in subsequent phases of work. ICF and Cal Water will build on research and findings developed in Phase 1 to define the scope of Phases 2 and 3.

In Phase 1, the ICF team undertook three areas of review:

- 1) Literature and tools related to adaptation planning by water suppliers and other relevant organizations
- 2) Methods and data in Cal Water's 2016 Vulnerability Study "Potential Climate Change Impacts on the Water Supplies of California Water Service"
- 3) Climate change impact assessments and adaptation plans beyond Cal Water (wholesalers, state agencies) that could affect Cal Water's vulnerability or adaptive capacity

In the first part of our assessment, the studies we reviewed conclude that there is high certainty of climate-driven reductions to snowpack, wetter winter months, and more volatility between wet and dry water years. While California water systems are designed to operate under a wide

range of hydrologic conditions, they are not designed to absorb and adapt to the projected levels of change, which could have impacts on historical supplies from reservoir systems and groundwater systems. These studies also revealed a suite of potential approaches to vulnerability assessment and risk assessment that are applicable to Phases 2 and 3.

Key studies that the ICF team referenced include Brown and Caldwell's "Impacts of Climate Change on Honolulu Water Supplies and Planning Strategies for Mitigation", the Water Research Foundation's (WRF)'s "Mapping Climate Exposure and Climate Information Needs to Water Utility Business Functions", the Metropolitan Water District's (MWD)'s "2015 Integrated Water Resources Plan" and "2015 Urban Water Management Plan", and the U.S. Environmental Protection Agency's (EPA's) Climate Resilience Evaluation and Awareness Toolkit (CREAT).

In the second part of our review, we found that Cal Water's 2016 Climate Change Vulnerability Study undertook a high-level investigation of impacts of climate change on water supply, including surface water, groundwater, and imported water throughout Cal Water service areas. However, the study did not use uniform metrics across water suppliers, was unable to apply the currently available downscaled climate projections, and did not consider the full suite of potential climate impacts to Cal Water's systems, including impacts of compounding climate hazards and impacts on Cal Water facilities and operations.

In the third part of this work, the ICF team researched and assessed existing climate vulnerability assessments and adaptation efforts that have an impact on Cal Water's ability to mitigate impacts from climate change. This included efforts by water supply wholesalers connected to Cal Water's system, and state agencies that regulate Cal Water's supplies, operations, and planning efforts. This will allow Cal Water to build on existing actions and avoid recreating adaptation efforts that are planned or have been implemented.

Cal Water has undertaken key steps toward adaptation planning since the 2016 Vulnerability Study, such as this work to provide additional vulnerability analysis, working locally to identify and prepare to meet Sustainable Groundwater Management Act (SGMA) requirements, and coordinating with wholesalers on their identified climate-driven vulnerabilities. Phases 2 and 3 of this work will further frame system vulnerabilities within an adaptation planning context for a flexible and anticipatory response.

The ICF team's literature review focused on identifying approaches for assessing water utility vulnerabilities of assets and water resources, and adaptation planning needs (summarized in Table 1). To identify these priority approaches, the team reviewed a list of publications with input from Cal Water on key sources. We reviewed and analyzed the relevant literature for applicability to Cal Water, the advantages and fit within a robust plan for assessment, and the potential disadvantages. We highlighted those approaches in the sections on key takeaways and the applicability of approaches to Cal Water. Table 1 provides important considerations raised by the ICF team during this process.

Table 1: Advantages and disadvantages of identified approaches

Identified Approach	Advantages	Disadvantages
<p>Integrated resource-level (i.e., top-down) and asset-level (i.e., bottom-up) approaches to vulnerability assessment</p>	<ul style="list-style-type: none"> <li>• Allows for matching available information with appropriate methodologies</li> <li>• Supports evaluation of vulnerabilities in both water supply resources and physical systems: an integrated approach can help to address gaps in either area</li> </ul>	<ul style="list-style-type: none"> <li>• Bottom-up approaches can require extensive historical data and asset-level data</li> <li>• Integration of climate projections into hydrological models can be challenging. For example, data inputs for hydrological models and the outputs from climate projections may be incompatible or require additional data processing</li> </ul>
<p>Robust Decision-Making</p>	<ul style="list-style-type: none"> <li>• Supports identification of decisions for response under a range of potential climate futures</li> <li>• Supports alignment between climate impacts and operating units/business functions</li> <li>• Ensures the scope focuses on critical services, assets, and resources</li> <li>• Supports the development of adaptation pathways and measures</li> <li>• Provides a framework for information that can signal the need for critical decisions on adaptation</li> </ul>	<ul style="list-style-type: none"> <li>• Involves significant investment of time to identify performance metrics, business functions, and key variables</li> <li>• Even with significant time invested on the front end, scope can change and require rescoping later in the effort</li> <li>• Requires a strong understanding of utility decision-making</li> </ul>
<p>Applying climate projections to hydrologic modeling, future demand and planning scenarios</p>	<ul style="list-style-type: none"> <li>• Generates better understanding of impacts of extreme scenarios, snowpack loss, drought, increased temperatures, precipitation whiplash, and other hydrologic changes in water supply resources and downstream demands</li> <li>• Allows for modeling of a range of climate scenarios to better account for uncertainties in resource management and climate outcomes</li> <li>• Integrates climate projections with scaled historical time series data</li> </ul>	<ul style="list-style-type: none"> <li>• Can require substantial data, and may introduce bias (due to selected climate scenarios)</li> <li>• It is necessary to identify performance metrics and thresholds related to available climate variables; these can be difficult to identify and thresholds may not exist</li> <li>• Relies on necessary simplifying assumptions to model complex hydrologic systems</li> </ul>
<p>Stress testing and scenarios</p>	<ul style="list-style-type: none"> <li>• Supports management of uncertainty, especially in the absence of data</li> <li>• Allows for understanding of climate impacts on system performance within a risk framework</li> </ul>	<ul style="list-style-type: none"> <li>• Can require refined climate information (e.g. hydrological variables) and detailed asset information</li> <li>• Can require the integration of climate information into hydrological models, which may require</li> </ul>

Identified Approach	Advantages	Disadvantages
	<ul style="list-style-type: none"> <li>• Supports identification of major performance metrics and their potential for failure</li> <li>• Helps in understanding how the severity of impacts varies for facilities, operations, and water supplies under different climate change conditions.</li> </ul>	<p>significant data processing to be compatible with one another</p> <ul style="list-style-type: none"> <li>• Can result in qualitative or directional findings that don't provide straightforward adaptation responses</li> </ul>
<p>Engaging staff in climate change vulnerability assessments and adaptation plans</p>	<ul style="list-style-type: none"> <li>• Provides perspective for setting study parameters</li> <li>• Provides targeted input and data into assessment</li> <li>• Identifies existing data gaps and actions to address gaps</li> <li>• Supports development of institutional capacity for monitoring impacts, adaptation planning, and implementation</li> </ul>	<ul style="list-style-type: none"> <li>• Can be time-consuming for team members attending workshops and interviews; requires a targeted approach to ensure efficiency and that the right data is captured</li> <li>• Requires cross-team coordination that may be outside of “normal” communication pathways, e.g. between engineers and policy specialists</li> </ul>
<p>Evaluating costs of inaction</p>	<ul style="list-style-type: none"> <li>• Helps to prioritize adaptation planning needs</li> <li>• Creates a better understanding of the risks to Cal Water</li> </ul>	<ul style="list-style-type: none"> <li>• Requires scaling information on past costs without clear data on future impacts, creating uncertainties in estimates</li> </ul>
<p>Use of Flexible Adaptation Pathways</p>	<ul style="list-style-type: none"> <li>• Helps to select appropriate timing (including lead time from planning to implementation) and application of adaptation measures</li> <li>• Considers and compares multiple strategies in adaptation planning</li> <li>• Includes triggers that signal when decision-makers should decide on switching to another pathway</li> <li>• Allows for adaptive decisions under uncertainty by integrating points for re-assessing pathway and actions</li> <li>• Considers alternative external developments over time</li> </ul>	<ul style="list-style-type: none"> <li>• Does not provide a fixed timeline for actions</li> <li>• This approach is relatively new and may require coordination with budget cycles and external policy updates, since actions evolve over time</li> <li>• May push decision burden onto future decision-makers who did not develop original pathway</li> </ul>

Our team synthesized these identified methodologies, findings, and insights into an overarching approach for characterizing climate vulnerabilities and planning for adaptation at both an asset level and water supply planning level to suit Cal Water’s needs in addressing climate change impacts, shown in Figure 1.

Figure 1: Climate Assessment Framework

### 1 Set Objectives and Define Scope

Ask key questions, set objectives, scope and organize, select and characterize relevant assets, operations, and resources.

### 2 Compile Data

Identify appropriate climate projections for assessment and collect data on potentially impacted facilities, assets and operations, water supply resources, and water demand.

### 3 Assess Vulnerability


Understand and define system vulnerabilities, based on exposure, sensitivity and adaptive capacity of the system.

**4 Assess Risks**  
Understand and define risks - consequences from system failures and uncertainty, i.e. likelihood.

**Prioritization**  
based on consequences and likelihood.

### 5 Develop Adaptation Strategies

Develop and plan adaptation strategies, prioritizing strategies based on adaptation pathways and investment considerations.




Source: Silvestrum Climate Associates, October 2020

Based on this review, the ICF team is making the following key recommendations for guiding Cal Water’s efforts in identifying climate vulnerabilities and planning for adaptation:

- **Apply a standard conceptual framework to vulnerability assessment which integrates both top-down analysis and bottom-up analysis (see Figure 1).** The standard conceptual framework for assessing climate vulnerabilities and risks includes understanding exposure, sensitivity, and adaptive capacity, and potential impacts as components of vulnerability, and consequence and likelihood as components of risk. Top-down analysis would begin by applying downscaled Global Climate Model (GCM) projections to assess impacts on water supply resources and the bottom-up analysis would begin by identifying system sensitivities to climate hazards. These analyses are complementary.
- **Use a robust decision making (RDM) framework for vulnerability assessment and adaptation planning** by seeking to identify decisions for response under a range of potential climate futures, mapping impacts on operating units/business functions, and ensuring that the scope focuses on critical services, assets, and resources. A robust decision-making framing will support the development of adaptation pathways and measures by monitoring information that signals the need for critical decisions on adaptation.
- **Engage staff and key stakeholders in the planning process** to gain a holistic planning perspective for setting study parameters, providing targeted input into assessment and plan development, and supporting institutional capacity for adaptation.
- **Build off of the 2016 Cal Water Climate Change Impact study by applying updated climate models and projections for additional hydrologic variables** to hydrologic modeling, future demand and planning scenarios, and scaled historical time series data to better understand impacts of extremes, precipitation whiplash, and other hydrologic changes in water supply resources. We recommend presentation of this with uniform metrics for more actionable findings.
- **Assess climate impact consequence by stress-testing key water system performance metrics.** This includes developing a range of impact scenarios to understand how the severity of impacts varies for facilities, operations, and water supplies under different climate change conditions.
- **Evaluating the order of magnitude cost of inaction.** We recommend communicating consequences in terms of direct costs to Cal Water and customers without adaptation actions to prioritize adaptation response.
- **Follow a step-by-step, iterative process to adaptive management which fully aligns with potential exposure to climate hazards and vulnerabilities,** including:
  - Utilizing Flexible Adaptation Pathways in planning for selecting appropriate timing and application of adaptation measures
  - Planning for monitoring and evaluation
  - Evaluating adaptation investment decisions

During Phases 2 and 3 in which Cal Water and the ICF team will further assess vulnerability, we will frame the study outputs within a decision-making context for compatibility with adaptation planning concepts and eventual investment in adaptation measures.

A scenic landscape photograph of a mountain valley. In the foreground, a calm lake reflects the sky and the surrounding mountains. The shoreline is lined with large, dark grey rocks. The middle ground shows a valley with sparse vegetation and some trees with yellow autumn foliage. In the background, rugged mountains rise, with the right-hand side of the range illuminated by warm, golden light, suggesting a sunset or sunrise. The sky is a clear, pale blue. A dark blue rectangular box is overlaid on the upper portion of the image, containing white text.

**California Water Service**  
**CLIMATE CHANGE RISK**  
**ASSESSMENT &**  
**ADAPTATION FRAMEWORK**

December 2021

# Summary for Decision Makers

## Study Purpose

California Water Service already faces climate risks — wildfire, increasing temperatures, sea level rise, flooding, and drought — and seeks to address these risks by identifying them and taking action. This Study works to (1) identify and prioritize climate-driven risks to Cal Water’s supply reliability, operations, and assets and (2) project and assess changes to the supply of and demand for Cal Water resources. This Study is intended to assist in understanding climate change risk across all Cal Water’s districts, spanning its future supply and demand as well as its key operations and assets. The report identifies primary risks to Cal Water across the districts as well as top risks to individual districts.

Using this study and the proposed adaptation framework, Cal Water can continuously monitor and address the following types of risks:

- Immediate risks given near-term threat and low risk tolerance
- Actions to take when a trigger is reached (e.g., when information becomes available or there is external opportunity for an adaptation strategy)
- District-specific risks requiring targeted management attention
- Risks to disadvantaged and vulnerable communities

## Policy Context for Climate Risk Assessment and Adaptation Planning

Various state agencies are expected to develop requirements on water utilities for incorporating climate change adaptation into their planning and operations including conducting vulnerability assessments as a starting point. These policy frameworks and requirements include:

1. The California Public Utilities Commission (CPUC) [Order Instituting Rulemaking \(OIR\) R.18-04-019 to Consider Strategies and Guidance for Climate Change Adaptation \(2020\)](#). The statutory deadline for finalizing requirements for Phase II, expected to apply to water utilities, has been extended to December 2022.
2. The California Coastal Commission (CCC) Critical Infrastructure at Risk: Sea Level Rise Planning Guidance for California’s Coastal Zone (Draft, November 2021).
3. The California Natural Resources Agency (CNRA) 2021 Climate Adaptation Strategy (Draft, October 2021).
4. The 2020 Water Resilience Portfolio in response to Governor’s Executive Order N-10-19.
5. The State Water Resources Control Board’s 2017 Comprehensive Response to Climate Change.

6. The [Task Force on Climate-Related Financial Disclosures \(TCFD\)](#) from the Financial Stability Board recommend that organizations to describe the climate-related risks and opportunities the organization has identified over the short, medium, and long term. Furthermore, it recommends that asset managers describe how climate-related risks and opportunities are factored into relevant products or investment strategies.

## Summary of Findings of Climate Change Risks

All districts face climate change risks, and all districts face at least 6 of the top identified risks to Cal Water. Factors that affect district vulnerability include groundwater dependency, State Water Project (SWP) dependency, limited supply diversity, and location in coastal or wildfire-prone areas.

### Risks to Supply Reliability

Without action, Cal Water may face significant water supply reliability and operational impacts that will challenge its ability to meet the water needs of its customers by mid-century due to changes to State Water Project deliveries, decreasing groundwater recharge, increasing duration, intensity, and frequency of droughts, and increasing outdoor demands.

**Annual State Water Project (SWP) deliveries are likely to decrease in average years and the driest years may result in no deliveries.** Average climate models project a decrease of 15% while the driest models project an average annual decrease of up to 36%. The Antelope Valley and Livermore districts are at particularly high risk.

**Groundwater recharge is expected to decrease in some basins.** Up to 20% decrease in average annual groundwater recharge is expected due to decreases in average precipitation, streamflow, and/or water available for managed recharge. Decreased recharge could limit sustainable yield from groundwater basins and lead to supply shortages. The King City and Visalia districts show the greatest average groundwater recharge decline.

**Decreased surface water supply availability is expected due to longer, more severe, and more frequent droughts.** The driest climate scenarios include megadroughts of 10 to 20+ years in duration, with districts in Southern California more at risk than districts in Northern California. The driest climate models project dry year precipitation decreases of 45 to 70%, with the Antelope Valley, Los Altos, and Livermore districts at the highest risk of large supply availability decreases during the driest years. Central tendency models project that dry year frequency may increase up to 10%. Decreased local and imported surface water supplies could lead to supply shortages.

**Outdoor demands will increase due to increased evapotranspiration (ET) and longer, more frequent, and more severe droughts.** Increased demands could lead to shortages and/or

challenges to operations. The Antelope Valley, Bear Gulch, Chico-Hamilton, and Visalia districts are at particularly high risk of increased demands.

### Risks to Operations

Without action, major risks to operations include surface water quality from increasing temperatures and wildfire could further limit the ability to deliver water to customers and significantly increase treatment costs. Wildfire will also continue to threaten Cal Water workforce and operations throughout the century, including disruption of operations due to smoke.

**Water quality will decrease due to high temperatures and low rainfall.** A 24–36% increase in number of hot days with no precipitation could increase algal blooms, cyanotoxins, sediments, and eutrophication. This may increase water treatment costs and potentially impact supply availability. Multiple districts are at high risk. By mid-century Antelope Valley, Redwood Valley, and Stockton, could experience high impacts.

**Water quality will also decrease due to increased wildfire risk and frequency of intense rainfall.** Based on downscaled wildfire projections, districts may see an increase of 4–122% over historical averages of annual area burned by wildfire. An increase of 10–12% in extreme precipitation events could alter vegetation cover and infiltration rates, resulting in greater quantities of debris and pollutants that enter waterways after fire events. Post-fire debris flows may also disrupt operations, increase water treatment costs, and reduce water available for distribution. Multiple districts are at particularly high risk. Some districts, such as Oroville, may face higher consequences due to limited supply alternatives.

**Worker health and safety will be endangered due to wildfire.** A 4–122% increase in wildfire risk could increase the amount of smoke, threatening the safety of outdoor workers. All districts are likely to experience an increase in wildfire risk and are highly vulnerable to experiencing impacts to worker health and safety, including from wildfire smoke.

**Natural snowpack storage may decrease due to declining snowpack due to temperature increases.** A 17–57% decrease in April 1<sup>st</sup> snowpack is projected for the watersheds that provide surface water supplies for Cal Water’s districts. This decrease in snowpack storage could lead to overall reduced supply and force Cal Water (or reservoir managers) to adjust reservoir storage facilities and operations to adapt to decreased surface flows. All districts are at high risk except those with supply not influenced by snowpack.

### Risks to Assets

Without action, riverine and urban flooding poses a serious threat to Cal Water’s assets, including pumps and treatment facilities. Rising groundwater and sea level rise present a risk to coastal assets, especially pressurized mains. Wildfire will continue to threaten assets, with an increase in areas burned in some districts and surrounding areas.

**More frequent and severe riverine and urban flooding can result in service disruption and infrastructure damage** due to loss of access to assets, damage to electrical components, long recovery time from disruption, and difficulty in moving or replacing fixed assets. Flooding could also occur from urban stormwater runoff. The most vulnerable assets are pumps, intakes, valves, wells, treatment facilities and radio sites. About half of all districts are vulnerable, particularly Chico-Hamilton.


**Sea level rise can result in permanent inundation of several asset types, especially pressurized mains.** Assets located along low-lying coastal shorelines are most vulnerable to sea level rise. South San Francisco and Hermosa Redondo districts are at particularly high risk.

**Rising groundwater due to sea level rise may affect wells and treatment facilities.** Sea level rise can flood wells and treatment facilities or cause saltwater intrusion in wells, affecting operations, water quality, or preventing access to facilities. Portions of Redwood Valley, Salinas, South San Francisco, Hermosa Redondo, and Dominguez districts are at particularly high risk.

**Increased wildfire risk could affect all of Cal Water's asset types.** Cal Water's most vulnerable assets include pressurized mains, radio sites, and treatment facilities, which may see elevated impacts. All districts have assets in CALFIRE threat areas of High and above.

Figure 1 below summarizes climate-related risks over the short, medium, and long term. Across all Cal Water districts, many of these risks are already present, though severity of the risk will differ district by district. District profiles accompanying this report identify those risks by district.

**Figure 1: Summary of climate-related risks to Cal Water over the short, medium, and long term. Timing of risks will differ by district.**




## Addressing Priority Risks

An adaptation framework is provided to assist Cal Water in incorporating the outcomes of this study into further analysis of investment decision making over time.

The primary steps of the adaptation framework are summarized below in Figure 2.

Figure 2: The Adaptation Framework follows 8 steps and is an iterative process for adaptation planning



The departments primarily affected by climate risks include Water Resource Sustainability; Water Quality; Operations; and Engineering. District Management will be affected by vulnerabilities in those districts (see Climate District Profiles available for each district).


Cal Water will need to address vulnerabilities exacerbated by climate change to prepare its systems for continued operation and to continue to meet established level of service goals. Changing climate conditions may change the historical balance between supply and demand and increase management requirements of assets and operations. Adaptation options should be developed and evaluated for major identified risks. Given that supply availability is dictated by many factors outside of Cal Water’s control, it may be important for Cal Water to seek adaptation measures in collaboration with wholesalers and local and federal water management agencies.

## Appendix G: Water Shortage Contingency Plan



# Water Shortage Contingency Plan 2025 Update

**Dixon District**  
June 2026





## Chapter 1 Introduction

### **CWC § 10640**

*(a) Every urban water supplier required to prepare a plan pursuant to this part shall prepare its plan pursuant to Article 2 (commencing with Section 10630). The supplier shall likewise periodically review the plan as required by Section 10621, and any amendments or changes required as a result of that review shall be adopted pursuant to this article.*

*(b) Every urban water supplier required to prepare a water shortage contingency plan shall prepare a water shortage contingency plan pursuant to Section 10632. The supplier shall likewise periodically review the water shortage contingency plan as required by paragraph (10) of subdivision (a) of Section 10632 and any amendments or changes required as a result of that review shall be adopted pursuant to this article.*

### **CWC § 10632.3**

*It is the intent of the Legislature that, upon proclamation by the Governor of a state of emergency under the California Emergency Services Act (Chapter 7 (commencing with Section 8550) of Division 1 of Title 2 of the Government Code) based on drought conditions, the board defer to implementation of locally adopted water shortage contingency plans to the extent practicable.*

This document describes the Water Shortage Contingency Plan (WSCP) for the California Water Service (Cal Water) Dixon District (also referred to herein as the “District”). The WSCP includes the levels of response to a water shortage caused by drought or by supply interruptions caused by infrastructure failure, regulatory mandate, or catastrophic human-caused or natural events. The primary objective of the WSCP is to ensure that the District has in place the necessary resources and management responses needed to protect health and human safety, minimize economic disruption, and preserve environmental and community assets during water supply shortages and interruptions.

Specifically, this WSCP includes the following chapters:

Chapter 1 - Introduction

Chapter 2 - Water Supply Reliability Analysis

Chapter 3 - Annual Water Supply and Demand Assessment Procedures

Chapter 4 - Water Shortage Levels

Chapter 5 - Shortage Response Actions

Chapter 6 - Communication Protocols

Chapter 7 - Compliance and Enforcement

Chapter 8 - Legal Authorities

Chapter 9 - Financial Consequences of WSCP

Chapter 10 - Monitoring and Reporting

Chapter 11 - WSCP Refinement Procedures

Chapter 12 - Plan Adoption, Submittal, and Availability

## Chapter 2

### Water Supply Reliability Analysis

**CWC § 10632 (a) (1)** *The analysis of water supply reliability conducted pursuant to Section 10635.*

As described in Chapter 6 of the Dixon District’s 2025 Urban Water Management Plan (UWMP or Plan), the sole water supply for the District is groundwater pumped from the Solano Subbasin (also referred to herein as the “Basin”) of the Sacramento Valley Basin (California Department of Water Resources [DWR] Basin No. 5-021.66). The Basin is not adjudicated and, in its recent evaluation of California groundwater basins, DWR determined that the Basin is not in a condition of critical overdraft.<sup>1</sup>

Chapter 7 of the District’s 2025 UWMP demonstrates that the groundwater supplies available to the District are considered highly reliable in extended drought conditions, and are expected to continue to be sufficient to meet projected District demands in all hydrologic conditions evaluated, including an extended five-year drought period. Although water shortage conditions are not expected to arise due to drought, this WSCP addresses potential water shortage conditions resulting from any cause (e.g., droughts, impacted distribution system infrastructure, regulatory-imposed shortage restrictions, catastrophic events, etc.).

Under the Sustainable Groundwater management Act (SGMA), Groundwater Sustainability Agencies (GSAs) have the authority to implement projects and management actions (P/MAs) that help basins reach their sustainability goal. Collectively the five Basin GSAs (i.e., Solano GSA, City of Vacaville GSA, Sacramento County GSA, Solano Irrigation District GSA, and the Northern Delta GSA) formed the Solano Collaborative to develop a single GSP for the Basin, which includes various P/MAs.<sup>2</sup> These P/MAs do not include any immediately planned groundwater pumping allocations, pumping fees, or other provisions which would be expected to impact the availability of groundwater supply to the District. If such actions are adopted in the future, Cal Water will consider them as a part of its future supply planning efforts. As described in Chapter 6 of the District’s 2025 UWMP, the District falls under the jurisdiction of the Solano Subbasin GSA.

---

<sup>1</sup> DWR, 2019. Sustainable Groundwater Management Act 2018 Basin Prioritization, State of California, dated January 2019.

<sup>2</sup> Solano Collaborative, 2021. *Solano Subbasin Groundwater Sustainability Plan*. Accessed From: <https://sgma.water.ca.gov/portal/gsp/preview/117>.

## Chapter 3

### Annual Water Supply and Demand Assessment Procedures

#### **CWC § 10632 (a) (2)**

*The procedures used in conducting an annual water supply and demand assessment that include, at a minimum, both of the following:*

*(A) The written decision-making process that an urban water supplier will use each year to determine its water supply reliability.*

*(B) The key data inputs and assessment methodology used to evaluate the urban water supplier's water supply reliability for the current year and one dry year, including all of the following:*

*(i) Current year unconstrained demand, considering weather, growth, and other influencing factors, such as policies to manage current supplies to meet demand objectives in future years, as applicable.*

*(ii) Current year available supply, considering hydrological and regulatory conditions in the current year and one dry year. The annual supply and demand assessment may consider more than one dry year solely at the discretion of the urban water supplier.*

*(iii) Existing infrastructure capabilities and plausible constraints.*

*(iv) A defined set of locally applicable evaluation criteria that are consistently relied upon for each annual water supply and demand assessment.*

*(v) A description and quantification of each source of water supply.*

#### **CWC § 10632.1**

*An urban water supplier shall conduct an annual water supply and demand assessment pursuant to subdivision (a) of Section 10632 and, on or before July 1 of each year, submit an annual water shortage assessment report to the department with information for anticipated shortage, triggered shortage response actions, compliance and enforcement actions, and communication actions consistent with the supplier's water shortage contingency plan. An urban water supplier that relies on imported water from the State Water Project or the Bureau of Reclamation shall submit its annual water supply and demand assessment within 14 days of receiving its final allocations, or by July 1 of each year, whichever is later.*

#### **CWC § 10632.2**

*An urban water supplier shall follow, where feasible and appropriate, the prescribed procedures and implement determined shortage response actions in its water shortage contingency plan, as identified in subdivision (a) of Section 10632, or reasonable alternative actions, provided that descriptions of the alternative actions are submitted with the annual water shortage assessment report pursuant to Section 10632.1. Nothing in this section prohibits an urban water supplier from taking actions not specified in its water shortage contingency plan, if needed, without having to formally amend its urban water management plan or water shortage contingency plan.*

On an annual basis, the District will conduct an Annual Water Supply and Demand Assessment (AWSDA) to identify whether there is likely to be a water shortage condition in the coming year, assuming it is dry. Each element of the AWSDA is described below.

## 1. Evaluation Criteria

The Evaluation Criteria that will be used to identify whether the District is likely to experience a water shortage in the coming year include:

- a. **Supply Well Operational Constraints** - A comparison of groundwater level elevations to well operational depths to identify the need to (1) lower pump depths or (2) site and drill additional supply wells.
- b. **Treatment and Distribution System Constraints** - An assessment of the probabilities of facility and infrastructure outages and the degree to which they could limit Cal Water's ability to access, convey, or treat adequate supplies, including any planned maintenance or capital improvements over the next year that could affect its ability to provide sufficient supply to meet demands.
- c. **Local Regulatory Conditions** - Evaluation of (1) any new GSA policies (e.g., pumping allocations) or sustainability criteria that could trigger a change in groundwater volume available for pumping, and (2) any new limitations on well permitting that could limit the ability to deepen existing supply wells or drill new supply wells.
- d. **State Regulatory Conditions** - Evaluation of any state-mandated drought or water use restrictions.

In the Spring prior to the submittal date, these Evaluation Criteria will be assessed by Cal Water staff, including District staff with detailed knowledge of District operations, well conditions, and local GSA activities. The data used to support the AWSDA may include, but are not limited to, supply capacity, supply and pump capacity, firm capacities, tank storage capacity, groundwater level measurements, water quality, system demand, and zone demand.

## 2. Water Supply

As described above, the District obtains its supplies from the underlying Basin. As discussed in Chapter 7 of the District's 2025 UWMP, these supplies are projected to be sufficient to serve future demands. The only identified potential constraints on water supply are the operational limitations and/or potential local regulatory conditions identified in the Evaluation Criteria above.

### 3. Unconstrained Customer Demand

The demand forecast described in Chapter 4 of the District's 2025 UWMP yields the anticipated annual unconstrained water demand, (i.e., the expected water use in the absence of shortage-caused reductions in water use) to support the AWSDA. During a drought cycle, unconstrained demand typically increases due to higher-than-normal air temperatures and lower-than-normal precipitation. The supply reliability analysis and Drought Risk Assessment presented in Chapter 7 of the District's 2025 UWMP accounts for this anticipated shift in unconstrained water demand, and as discussed above, even with these increases in demand, the available groundwater supply is expected to be sufficient to meet these demands.

### 4. Planned Water Use for Current Year Considering Dry Subsequent Year

Cal Water will evaluate the anticipated supplies for the current year, assuming that the following year will be dry, as defined above, using the identified Evaluation Criteria. Barring changes in supply availability per the Evaluation Criteria, the assumed dry subsequent year is not expected to affect the manner in which Cal Water will utilize its available supplies in the current year, and the planned water use for the current year will equal the unconstrained demand.

### 5. Infrastructure Considerations

As part of its triennial General Rate Case applications to the California Public Utilities Commission (CPUC), Cal Water prepares a Supply-Demand Analysis (CPUC SD Analysis) for each of its districts. The CPUC SD Analysis is an inventory of water production and pump assets that provide direct and indirect sources of supply to meet customer demands in accordance with CPUC General Order 103-A and California Code of Regulations (CCR) Title 22 Waterworks Standards. This CPUC SD Analysis is based on a combination of regulatory requirements, professional consultant recommendations, and industry standard practices, including those from the American Water Works Association (AWWA) and American Society of Civil Engineers (ASCE). It identifies specific vulnerabilities in different pressure zones within the system and evaluates the system against performance criteria that meet regulatory requirements and ensure operationally adequate levels of service.

This analysis will guide Cal Water's evaluation of operational treatment/distribution constraints that could potentially limit the availability of supplies. This evaluation of supply well operational constraints and treatment and distribution constraints will assess potential impacts on supply availability or related factors (e.g., mandated demand reductions). If such constraints are identified, Cal Water will develop a plan to address

these constraints, mitigate potential effects, and implement the appropriate water Shortage Level of action per Chapter 5, below.

6. Other Factors

As identified under the Evaluation Criteria above, local regulatory conditions could potentially limit the availability of supplies. Therefore, Cal Water will evaluate the development of new regulatory constraints in the Spring of each year and assess their potential impacts on supply availability or related factors (e.g., mandated demand reductions). If such constraints are identified, Cal Water will develop a plan to address these constraints and mitigate potential effects and implement the appropriate water shortage level of action per Chapter 5, below.

Consistent with California Water Code (CWC) § 10632.1, Cal Water will complete and submit an AWSDA to DWR by July 1<sup>st</sup> of each year.

## Chapter 4 Water Shortage Levels

**CWC § 10632 (a) (3)**

(A) Six standard water shortage levels corresponding to progressive ranges of up to 10, 20, 30, 40, and 50 percent shortages and greater than 50 percent shortage. Urban water suppliers shall define these shortage levels based on the suppliers’ water supply conditions, including percentage reductions in water supply, changes in groundwater levels, changes in surface elevation or level of subsidence, or other changes in hydrological or other local conditions indicative of the water supply available for use. Shortage levels shall also apply to catastrophic interruption of water supplies, including, but not limited to, a regional power outage, an earthquake, and other potential emergency events.

(B) An urban water supplier with an existing water shortage contingency plan that uses different water shortage levels may comply with the requirement in subparagraph (A) by developing and including a cross-reference relating its existing categories to the six standard water shortage levels.

Consistent with the requirements of CWC § 10632(a)(3), the WSCP is based on the six water Shortage Levels shown in **Table 4-1**. These Shortage Levels are intended to address shortages caused by any condition, including the catastrophic interruption of water supplies.

**Table 4-1. Water Shortage Contingency Plan Levels (DWR Table 8-1)**

<input checked="" type="checkbox"/>	Check the box if the Supplier uses the Standard six levels of water shortage.		
Standard Shortage Levels	Percent Shortage Range	Suppliers Shortage Levels	Percent Shortage Range
1	Up to 10%		
2	Up to 20%		
3	Up to 30%		
4	Up to 40%		
5	Up to 50%		
6	>50%		
<b>Notes:</b>			

Shortage response actions for each of these Shortage Levels are identified and discussed in Chapter 5.

## Chapter 5

### Shortage Response Actions

#### **CWC § 10632 (a) (4)**

*Shortage response actions that align with the defined shortage levels and include, at a minimum, all of the following:*

*(A) Locally appropriate supply augmentation actions.*

*(B) Locally appropriate demand reduction actions to adequately respond to shortages.*

*(C) Locally appropriate operational changes.*

*(D) Additional, mandatory prohibitions against specific water use practices that are in addition to state-mandated prohibitions and appropriate to the local conditions.*

*(E) For each action, an estimate of the extent to which the gap between supplies and demand will be reduced by implementation of the action.*

This chapter describes the response actions Cal Water will take to deal with the shortages associated with each of the six Shortage Levels enumerated in Chapter 4. As discussed above, the existing District supplies are expected to be able to serve 100% of future demands under all hydrologic conditions evaluated. However, inasmuch as Cal Water may have to implement shortage response actions to comply with state mandates, local regulatory changes, or respond to catastrophic events, it is important to carefully identify and describe the anticipated necessary actions.

#### 5.1 Demand Reduction

The combinations of demand-reduction actions required to resolve the shortages associated with each of the six Shortage Levels are based on Cal Water's experience in dealing with past drought-related shortages and also include other actions deemed appropriate to achieve the required demand reductions. In order to evaluate and ensure that appropriate actions would be implemented with the proper level of intensity, Cal Water employed the Drought Response Tool (DRT), an Excel spreadsheet model developed by EKI Environment and Water, Inc (EKI).

The DRT provides a quantitative framework that allows Cal Water to systematically estimate the monthly and cumulative annual demand reductions expected to result from particular combinations of drought response actions and associated implementation rates. Data inputs to the DRT include total production, sector-specific water use, population, and assumptions regarding the split between indoor and outdoor water use for each customer sector (class).

For each drought response action, the user specifies:

- The customer class(es) and end use(s) that are affected;

- The percent savings for those end use(s) for each account that implements the action based on evaluations reported in the literature, or where such studies are not available, on best estimates based on Cal Water experience; and
- The percentage of accounts assumed to implement the action, which is presumed to be the result of the intensity level of Cal Water program implementation, including but not limited to marketing and enforcement activities.

Based on the foregoing inputs, the DRT calculates the resulting monthly savings. Cal Water adjusted the combination of actions and implementation levels to achieve the targeted savings levels at each of the six Shortage Levels.

In order to evaluate the robustness of the DRT, Cal Water modeled the actions implemented during the height of the last drought for a subset of its districts, and found that the modeled water shortage reductions were generally consistent with the observed responses. In short, the DRT is a robust, transparent tool that can be used to tie a particular set of shortage-response actions to an expected reduction in demand.

For each of the six Shortage Levels, the modeling targeted the maximum demand reduction, ergo:

- 10% for Shortage Level 1,
- 20% for Shortage Level 2,
- 30% for Shortage Level 3,
- 40% for Shortage Level 4,
- 50% for Shortage Level 5, and
- 60% for Shortage Level 6.

The key DRT inputs and outputs for each of the Shortage Levels are reproduced in **Attachment A**.

**Table 5-1** shows the water shortage reduction actions, savings assumptions, and implementation rates that are required for the District to achieve the targeted annual demand reductions for each of the Shortage Levels. At each Shortage Level, there are two types of demand-reduction actions identified:

- Restrictions on customer water usage; and,
- Consumption reduction actions by Cal Water to encourage decreased water usage.

The total demand reductions are governed by a set of user-specified constraints to ensure that usage levels do not endanger health and safety or result in unacceptable economic impacts. The DRT will not permit estimated usage reductions to violate these constraints, regardless of the demand reduction actions selected. For most districts, including the Dixon District, the following default constraints are used:

- A minimum residential indoor per capita daily usage of 25 gallons,
- A maximum residential outdoor usage reduction of 100%,

- A maximum Commercial, industrial, and institutional (CII) indoor usage reduction of 30%, and
- A maximum CII outdoor usage reduction of 100%.

Many actions are implemented across a number of Shortage Levels, some at increasing implementation levels. Therefore, the actions are listed as a row under the first Shortage Level at which they are implemented, and the implementation rate is shown under each Shortage Level column heading at the right. The unit savings represent a percentage savings of the end uses indicated in the table.

Because of the DRT logic described above, the format of **Table 5-1** differs from that of the default DWR table.

#### 5.1.1 Defining Water Features

##### **CWC § 10632 (b)**

*For purposes of developing the water shortage contingency plan pursuant to subdivision (a), an urban water supplier shall analyze and define water features that are artificially supplied with water, including ponds, lakes, waterfalls, and fountains, separately from swimming pools and spas, as defined in subdivision (a) of Section 115921 of the Health and Safety Code.*

As required by CWC §10632, Cal Water distinguishes between “decorative water features” such as ponds, lakes, and fountains that are artificially supplied with water and “recreational water features” such as swimming pools and spas. Prohibitions on water use for decorative water features are listed separately from those for recreational water features (see **Table 5-1**).

**Table 5-1. Demand Reduction Actions to Achieve Required Savings (DWR Table 8-3)**

Water Shortage Response Action	End Use(s)	End Use Savings	Implementation by Shortage Level						Penalty, Charge, or Other Enforcement?
			1	2	3	4	5	6	
<b>Shortage Level 1: Minimal Shortage</b>									
<b>Water Use Restriction (a)</b>									
Landscape - Limit landscape irrigation to specific times	Irrigation	10%	85%						Yes
Other - Customers must repair leaks, breaks, and malfunctions in a timely manner	Leaks	100%	30%	75%	75%	75%	75%	75%	Yes
Landscape - Restrict or prohibit runoff from landscape irrigation	Irrigation	3%	60%	75%	75%	75%	75%	75%	Yes
Prohibit application of potable water to outdoor landscapes within 48 hours of measurable rainfall <i>(Landscape - Other landscape restriction or prohibition)</i>	Irrigation	20%	60%	85%	85%	85%	100%		Yes
Other - Prohibit use of potable water for washing hard surfaces	Misc. Outdoor	17%	60%	75%	75%	75%	75%	75%	Yes
Other - Require automatic shut-off hoses <i>(Other - Require automatic shut of hoses)</i>	Misc. Outdoor	17%	50%	75%	75%	75%	75%	75%	Yes
CII - Lodging establishments must offer opt out of linen service	Fixtures & Appliances	0.5%	50%	75%	75%	75%	75%	75%	Yes
CII - Restaurants may only serve water upon request	Fixtures & Appliances	0.5%	75%	75%	75%	75%	75%	75%	Yes

Water Shortage Response Action	End Use(s)	End Use Savings	Implementation by Shortage Level						Penalty, Charge, or Other Enforcement?
			1	2	3	4	5	6	
No watering of landscape of newly constructed homes and buildings in a manner inconsistent with regulations or other requirements established by the California Building Standards Commission, the Department of Housing and Community Development, or other State agency <i>(Landscape - Other landscape restriction or prohibition)</i>	Irrigation	50%	0.2%	0.2%	0.2%	0.2%	0.2%		Yes
Prohibit Potable Water Use for Decorative Water Features that do not Recirculate Water <i>(Water Features - Restrict water use for decorative water features, such as fountains)</i>	Misc. Outdoor	50%	50%	75%	75%	75%	75%	75%	Yes
<b>Consumption Reduction</b>									
Expand Public Information Campaign	All	0.5%	50%	50%	50%	50%	75%	75%	No
Water Bill Inserts <i>(Improve Customer Billing)</i>	All	0.5%	100%	100%	100%	100%	100%	100%	No
Promote online water waste reporting <i>(Expand Public Information Campaign)</i>	All	10%	0.1%	0.2%	0.2%	0.3%	0.5%	0.5%	No
Expand Rebates or Giveaways of Plumbing Fixtures and Devices <i>(Provide Rebates or Giveaways of Plumbing Fixtures and Devices)</i>	All	10%	1%	4%	4%	4%	5%	5%	No
Expand Rebates for Landscape Irrigation Efficiency <i>(Provide Rebates for Landscape Irrigation Efficiency)</i>	All	10%	1%	4%	4%	4%	5%	5%	No

Water Shortage Response Action	End Use(s)	End Use Savings	Implementation by Shortage Level						Penalty, Charge, or Other Enforcement?
			1	2	3	4	5	6	
Offer CII Water Use Surveys <i>(Offer Water Use Surveys)</i>	All CII uses	5%	1%	2%	2%	2%	2%	4%	No
Offer Res Water Use Surveys <i>(Offer Water Use Surveys)</i>	All Residential Uses	5%	1%	2%	2%	2%	2%	4%	No
<b>Shortage Level 2: Moderate Shortage</b>									
<b>Restrictions</b>									
Landscape - Limit landscape irrigation to specific days	Irrigation	15%-79% <sup>(b)</sup>		100%	20%	55%	65%		Yes
Prohibit the use of non-recirculating systems in all new conveyer car wash and commercial laundry systems <i>(Other)</i>	Fixtures & Appliances	50%		See note (c)	See note (c)	See note (c)	See note (c)	See note (c)	Yes
<b>Consumption Reduction</b>									
Water Efficiency Workshops, Public Events <i>(Other)</i>	All Residential Uses	5%		50%	50%	50%	50%	75%	No
<b>Shortage Level 3: Severe Shortage</b>									
<b>Restrictions</b>									
Other - Prohibit use of potable water for construction and dust control	Misc. Outdoor	100%			1%	1%	1%	1%	Yes
Prohibit use of potable water for street washing <i>(Other - Prohibit use of potable water for washing hard surfaces)</i>	Misc. Outdoor	100%			1%	1%	1%	1%	Yes

Water Shortage Response Action	End Use(s)	End Use Savings	Implementation by Shortage Level						Penalty, Charge, or Other Enforcement?
			1	2	3	4	5	6	
Prohibit Filling Ornamental Lakes or Ponds <i>(Water Features - Restrict water use for decorative water features, such as fountains)</i> <i>(Other water feature or swimming pool restriction)</i>	Misc. Outdoor	100%			1%	1%	1%	1%	Yes
<b>Consumption Reduction</b>									
Home or Mobile Water Use Reports <i>(Expand Public Information Campaign)</i>	All	5%			15%	50%	50%	50%	No
Decrease Frequency and Length of Line Flushing <i>(Decrease Line Flushing)</i>	Non Revenue Water	25%			50%	50%	50%	50%	No
Reduce System Water Loss	Non Revenue Water	100%			10%	10%	10%	30%	No
Increase Water Waste Patrols/Enforcement <i>(Increase Water Waste Patrols)</i>	All	10%			1%	2%	4%	5%	No
Implement Drought Rate Structure and Customer Water Budgets (Res) <i>(Implement or Modify Drought Rate Structure or Surcharge)</i>	All Residential Uses	30%-60% <sup>(c)</sup>			30%	40%	40%	55%	Yes
Implement Drought Rate Structure and Customer Water Budgets (CII) <i>(Implement or Modify Drought Rate Structure or Surcharge)</i>	All CII uses	10%-30% <sup>(d)</sup>			30%	40%	40%	55%	Yes

Water Shortage Response Action	End Use(s)	End Use Savings	Implementation by Shortage Level						Penalty, Charge, or Other Enforcement?
			1	2	3	4	5	6	
<b>Shortage Level 4: Critical Shortage</b>									
<b>Water Use Restrictions</b>									
Prohibit vehicle washing except with recirculated water or low-volume systems <i>(Other - Prohibit vehicle washing except at facilities using recycled or recirculating water)</i>	Misc. Outdoor	10%				50%	50%	50%	Yes
Prohibit use of water for recreational purposes such as water parks and the filling of pools <i>(Other water feature or swimming pool restriction)</i>	Misc. Outdoor	100%				1%	1%	1%	Yes
<b>Shortage Level 5: Emergency Shortage</b>									
<b>Water Use Restrictions</b>									
Require net zero demand increase on new water service connections <i>(Moratorium or Net Zero Demand Increase on New Connections)</i>	All	100%					0.2%	0.2%	Yes
Prohibit single-pass cooling systems <i>(Other)</i>	Cooling	50%					20%	20%	Yes
<b>Consumption Reduction Actions</b>									
Require Pool Covers <i>(Pools and Spas - Require covers for pools and spas)</i>	Misc. Outdoor	28%					10%	10%	Yes

Water Shortage Response Action	End Use(s)	End Use Savings	Implementation by Shortage Level						Penalty, Charge, or Other Enforcement?
			1	2	3	4	5	6	
<b>Shortage Level 6: Extreme Shortage</b>									
<b>Water Use Restrictions</b>									
Moratorium on new water service connections <i>(Moratorium or Net Zero Demand Increase on New Connections)</i>	All	100%					0.2%	Yes	
Landscape - Prohibit all landscape irrigation	Irrigation	100%					50%	Yes	
<b>Cumulative Annual Savings</b>			<b>10%</b>	<b>20%</b>	<b>30%</b>	<b>40%</b>	<b>50%</b>	<b>60%</b>	
<p><b>Notes:</b></p> <p>(a) In certain cases water use restrictions and consumption reduction actions implemented by Cal Water are not specifically called out in DWR’s provided demand reduction actions list. The appropriate DWR provided demand reduction action is included in italics in parenthesis.</p> <p>(b) Watering restricted to no more than 3 days/week in Shortage Level 2 and Shortage Level 3; no more than 2 days/week in Shortage Level 4; no more than 1 day/week in Shortage Level 5.</p> <p>(c) Implementation rates are not currently well understood and are therefore not presented. These rates will be evaluated through additional study of this water use restriction.</p> <p>(d) Residential water budgets of up to 30% for Shortage Level 3, up to 40% for Shortage Level 4, up to 50% for Shortage Level 5, up to 60% for Shortage Level 6.</p> <p>(e) CII water budgets of up to 10% for Shortage Level 3, up to 20% for Shortage Level 4, up to 30% for Shortage Levels 5 and 6.</p>									

## 5.2 Supply Augmentation

As indicated in **Table 5-2**, Cal Water has not identified any specific supply augmentation actions to assist in resolving future District water shortages but are currently assessing potential options. As identified in Chapter 3, Cal Water may consider drilling new wells if necessary due to declining groundwater levels. However, Cal Water considers these actions to be operational changes (described in Section 5.3), rather than accessing a new supply source.

**Table 5-2. Supply Augmentation and Other Actions (DWR Table 8-3)**

☒ Is the Supplier completing this table using the standard six levels? (yes/no)				
Shortage Level	Supply Augmentation Methods and Other Actions by Water Supplier	How much is this going to reduce the shortage gap?		Additional Explanation or Reference (OPTIONAL)
		Volume or Percentage	Shortage Gap Reduction Value	
See note (a)	See note (a)	See note (a)	AF	See note (a)
<p><b>Notes:</b> (a) Cal Water evaluates water supply augmentation projects on an on-going basis. At this time, Cal Water does not have supply augmentation projects planned specifically to address water shortage conditions.</p>				

## 5.3 Operational Changes

As discussed above in Chapter 3, the primary operational change that Cal Water will consider in the District is extracting groundwater from new wells following identification of this need as part of the AWSDA or related processes. As identified in **Table 5-1**, the District will also decrease the frequency and length of line flushing under Shortage Level 3 and beyond. The District will also evaluate the potential benefits of altering other maintenance cycles and expediting infrastructure repairs to improve system efficiency, to the extent feasible.

In addition, Cal Water is actively participating in the implementation of the Basin GSP and will make operational changes as necessary to support SGMA compliance.

## 5.4 Mandatory Restrictions

The water shortage response actions included in **Table 5-1** include a variety of mandatory customer water use restrictions that will be necessary to achieve the targeted demand reductions for the different Shortage Levels. The types of restrictions and the manner and degree of enforcement for these restrictions vary by Shortage Level and are discussed in Chapter 7.

## 5.5 Emergency Response Plan

Cal Water has an Emergency Response Plan (ERP) in place that coordinates the overall response to a disaster within the District.

The ERP addresses Cal Water’s responsibilities in emergencies associated with natural disaster, human-caused emergencies, and technological incidents. It provides a framework for coordination of response and recovery efforts within Cal Water in cooperation with local, state, and federal agencies, as well as other public and private organizations. The ERP establishes an emergency organization to direct and control operations during a period of emergency by assigning responsibilities to specific personnel.

The ERP does the following:

- It conforms to the State mandated Standardized Emergency Management System (SEMS) and the National Incident Management System (NIMS), and it effectively structures emergency response at all levels in compliance with the Incident Command System (ICS).
- It establishes response policies and procedures, while providing Cal Water clear guidance related to emergency planning.
- It describes and details procedural steps necessary to protect lives and property.
- It outlines coordination requirements.
- It provides a basis for unified training and response exercises to ensure compliance.

The District has installed backup power generators at many of its well sites, booster sites, and pump storage sites that can be operated in the event of a system wide power outage. A complete loss of power has never been experienced, but the generators have been used in the past to overcome localized outages.

Cal Water currently has interconnections with the City of Dixon, as discussed in Section 6.7.3 of the District’s 2025 UWMP.

## 5.6 Seismic Risk Assessment and Mitigation Plan

### **CWC § 10632.5**

*(a) In addition to the requirements of paragraph (3) of subdivision (a) of Section 10632, beginning January 1, 2020, the plan shall include a seismic risk assessment and mitigation plan to assess the vulnerability of each of the various facilities of a water system and mitigate those vulnerabilities.*

*(b) An urban water supplier shall update the seismic risk assessment and mitigation plan when updating its urban water management plan as required by Section 10621.*

*(c) An urban water supplier may comply with this section by submitting, pursuant to Section 10644, a copy of the most recent adopted local hazard mitigation plan or multihazard mitigation plan under the federal Disaster Mitigation Act of 2000 (Public Law 106-390) if the local hazard mitigation plan or multihazard mitigation plan addresses seismic risk.*

Cal Water's ERP includes information on various hazards and a related fault map overlying the District. The Solano County Emergency Operations Plan, which includes additional discussion of area earthquake risk and mitigation, can be found at:

[https://www.solanocounty.com/depts/oes/emergency\\_plans.asp](https://www.solanocounty.com/depts/oes/emergency_plans.asp).

## 5.7 Shortage Response Action Effectiveness

**Table 5-1** above shows the effectiveness of the specific demand-reduction actions and implementation levels necessary for the District to achieve the targeted savings for each water Shortage Level. The bottom row indicates the total annual cumulative savings expected to be reached at each Shortage Level. Additional details, including anticipated savings on a month-by-month basis are provided in the DRT inputs and outputs included in **Attachment A**.

## Chapter 6

### Communication Protocols

**CWC § 10632 (a) (5)**

*Communication protocols and procedures to inform customers, the public, interested parties, and local, regional, and state governments, regarding, at a minimum, all of the following:*

*(A) Any current or predicted shortages as determined by the annual water supply and demand assessment described pursuant to Section 10632.1.*

*(B) Any shortage response actions triggered or anticipated to be triggered by the annual water supply and demand assessment described pursuant to Section 10632.1.*

*(C) Any other relevant communications.*

Cal Water intends to escalate communication to customers and stakeholders, as needed, throughout any water shortage situation to help ensure they are aware of current conditions, any water use restrictions that are in effect, and the many ways Cal Water can help them reduce their water use. Cal Water's outreach efforts may include multiple channels, including bill messages, bill inserts, direct mail, email, letters, social media, print, radio, music streaming services, TV, over-the-top media, movie theatre advertising, and group presentations.

These efforts will expand on current Cal Water outreach efforts and will be customized to the needs at the time of the shortage to ensure a proper channel mix so that the maximum audience is reached as efficiently as possible.

## Chapter 7

### Compliance and Enforcement

☑ **CWC § 10632 (a) (6)** For an urban retail water supplier, customer compliance, enforcement, appeal, and exemption procedures for triggered shortage response actions as determined pursuant to Section 10632.2.

Schedule 14.1 includes specific Enforcement provisions that take effect upon activation. When Schedule 14.1 is activated, its Enforcement section supersedes the Enforcement provisions in Rule 14.1, and enforcement of the applicable requirements will be administered in accordance with the enforcement procedures described in Schedule 14.1 for the period it remains in effect.

#### 7.1 Water Use Restrictions

In accordance with Rule 14.1, Cal Water is currently authorized to take the following actions to enforce the water use restrictions:

**First Violation:** Cal Water shall provide the customer with a written notice of violation. In addition, Cal Water is authorized to take the following actions:

- a) If the customer currently receives service through a metered connection, install a real-time water measurement device on the customer's service line and provide the customer with access to information from the device. The cost of the device, including installation and on-going operating costs, may be billed to the customer, and nonpayment may result in discontinuation of service.
- b) If the customer does not currently receive service through a metered connection, install a water meter on the customer's service line, charge the customer for water use pursuant to Cal Water's metered service tariffs and rules, and install a real-time water measurement device on the customer's service line and provide the customer with access to information from the device. The cost of the device, including installation and ongoing operating costs, may be billed to the customer, and nonpayment may result in discontinuance of service.

**Second Violation:** If Cal Water verifies that the customer has used potable water for non-essential, wasteful uses after having been notified of the first violation, Cal Water shall provide the customer with a second written notice of violation and is authorized to install a flow-restricting device on the customer's service line. Cal Water shall not be held liable for any injuries, damages, and/or consequences arising from the installation of a flow-restricting device.

In June 2021, Cal Water submitted an update to Rule 14.1 and Schedule 14.1 to the CPUC for approval, to align with the restrictions identified in this WSCP. Rule 14.1 and Schedule 14.1 were

approved by the CPUC in July 2021. Rule 14.1 and Schedule 14.1 are discussed in more detail in Chapter 8. The current versions of Rule 14.1 and Schedule 14.1 can be found on the Cal Water website.

The passage of Assembly Bill 1572 includes both regulatory responsibilities and customer-facing obligations relating to the prohibition of potable water for irrigating non-functional turf. Cal Water plans to submit a revised Rule 14.1 and Schedule 14.1 to the CPUC for approval prior to January 1, 2027, to be in compliance with the regulatory requirements and is developing communication materials and an outreach plan to be in compliance with the customer-facing obligations.

## 7.2 Non-Essential, Wasteful Uses

In the event that more stringent measures are needed, implementation of Schedule 14.1 would be requested from the CPUC. If implemented, Cal Water is currently authorized to take the following actions when its personnel verify a customer is using potable water for non-essential, wasteful uses.

**First Violation:** Cal Water shall provide the customer with a written notice of violation. In addition, Cal Water is authorized to take the following actions:

- A. If the customer currently receives service through a metered connection, install a real-time water measurement device on the customer's service line and provide the customer with access to information from the device. The cost of the device, including installation and ongoing operating costs, may be billed to the customer, and nonpayment may result in discontinuance of service.
- B. If the customer does not currently receive service through a metered connection, install a water meter on the customer's service line, charge the customer for water use pursuant to Cal Water's metered service tariffs and rules, and install a real-time water measurement device on the customer's service line and provide the customer with access to information from the device. The cost of the device, including installation and ongoing operating costs, may be billed to the customer, and nonpayment may result in discontinuance of service.

**Second Violation:** If Cal Water verifies that the customer has used potable water for non-essential, wasteful uses after having been notified of the first violation, Cal Water shall provide the customer with a second written notice of violation. In addition to the actions prescribed under the first violation above, Cal Water is authorized to take the following actions:

- A. Apply the following waste of water penalties, which are in addition to any other charges authorized by this Schedule or other Cal Water tariffs.

- i. If Shortage Level 1 is in effect, \$25
  - ii. If Shortage Level 2 is in effect, \$50
  - iii. If Shortage Level 3 is in effect, \$100
  - iv. If Shortage Level 4 is in effect, \$200
  - v. If Shortage Level 5 is in effect, \$400
  - vi. If Shortage Level 6 is in effect, \$800
- B. At its sole discretion, waive the waste of water penalty if the customer participates in a water use evaluation provided by Cal Water and/or provides documentation to Cal Water proving that a drip irrigation system, micro spray irrigation system, high-efficiency sprinkler system, or properly programmed smart irrigation controller has been installed, after a notice of violation was delivered, and is in use at the customer's service address.

**Third Violation:** If Cal Water verifies that the customer has used potable water for non-essential, wasteful uses after having been notified of the second violation, Cal Water shall provide the first and second violations above, Cal Water is authorized to take the following actions:

- A. Apply the following waste of water penalties, which are in addition to any other charges authorized by this Schedule or other Cal Water tariffs.
- i. If Shortage Level 1 is in effect, \$50
  - ii. If Shortage Level 2 is in effect, \$100
  - iii. If Shortage Level 3 is in effect, \$200
  - iv. If Shortage Level 4 is in effect, \$400
  - v. If Shortage Level 5 is in effect, \$800
  - vi. If Shortage Level 6 is in effect, \$1,600
- B. At its sole discretion, waive the waste of water surcharge if the customer participates in a water use evaluation provided by Cal Water and/or provides documentation to Cal Water proving that a drip irrigation system, micro spray irrigation system, high- efficiency sprinkler system, or properly programmed smart irrigation controller has been installed, after notice of violations have been delivered, and is in use at the customer's service address.

**Fourth Violation:** If Cal Water verifies that the customer has used potable water for non-essential, wasteful uses after having been notified of the third violation, Cal Water shall provide the customer with a fourth written notice of violation. In addition to actions set

forth in previous violations prescribed above, Cal Water is authorized to install a flow-restricting device on the customer's service line.

**Egregious Violations:** Notwithstanding the foregoing framework for penalties, customers who Cal Water has verified are egregiously using potable water for non-essential, wasteful uses are subject to having a flow-restricting device installed on their service line. After providing the customer with one notice of egregious violation, either by direct mail or door hanger, which documents the egregious use of potable water for non-essential, wasteful uses and explains that failure to correct the violation may result in the installation of a flow-restricting device on the customer's service line, Cal Water is authorized to install a flow-restricting device on the customer's service line.

### 7.3 Drought Surcharges

Water budgets and associated drought surcharges are included as actions in **Table 5-1**. Cal Water may implement such actions through the implementation of Schedule 14.1.

## Chapter 8

### Legal Authorities

**CWC § 10632 (a) (7)**

*(A) A description of the legal authorities that empower the urban water supplier to implement and enforce its shortage response actions specified in paragraph (4) that may include, but are not limited to, statutory authorities, ordinances, resolutions, and contract provisions.*

*(B) A statement that an urban water supplier shall declare a water shortage emergency in accordance with Chapter 3 (commencing with Section 350) of Division 1.*

*(C) A statement that an urban water supplier shall coordinate with any city or county within which it provides water supply services for the possible proclamation of a local emergency, as defined in Section 8558 of the Government Code.*

Cal Water is a public water utility that is regulated by the CPUC. As such, it does not have the authority to adopt resolutions or ordinances. Rule 14.1, as filed with the CPUC, serves as Cal Water's restrictions on non-essential, wasteful uses of potable water. In the event that more stringent measures are required, Cal Water may request the addition of Schedule 14.1 which serves as Cal Water's WSCP and includes leveled mandatory reductions and drought surcharges. Cal Water shall coordinate with any city or county within which it provides water supply services for the possible proclamation of a local emergency as defined in Section 8558 of the Government Code and to ensure consistency with local resolutions and ordinances.

On June 14, 2021, Cal Water filed its current Schedule 14.1 with the CPUC which became effective on July 14, 2021.<sup>3</sup> The Schedule 14.1 lays out the leveled mandatory reductions and drought surcharges associated with Cal Water's WSCP. This filing is consistent with Resolution W-5034, adopted by the Commission on April 9, 2015, ordering compliance with requirements of the State Water Resources Control Board (SWRCB).

Schedule 14.1 is an extension of Rule 14.1. The compliance and enforcement information presented in Chapter 7 is based on the current versions of both Rule 14.1 and Schedule 14.1.

In the event of a determination of a water shortage Cal Water shall declare a water shortage emergency in accordance with the Water Code Chapter 3 (commencing with Section 350) of Division 1 and implement the WSCP at the appropriate Shortage Level.

---

<sup>3</sup> For reference, the current version of Rule 14.1 and Schedule 14.1 are included as **Attachment B**.

## Chapter 9

### Financial Consequences of WSCP

**CWC § 10632 (a) (8)**

*A description of the financial consequences of, and responses for, drought conditions, including, but not limited to, all of the following:*

*(A) A description of potential revenue reductions and expense increases associated with activated shortage response actions described in paragraph (4).*

*(B) A description of mitigation actions needed to address revenue reductions and expense increases associated with activated shortage response actions described in paragraph (4).*

*(C) A description of the cost of compliance with Chapter 3.3 (commencing with Section 365) of Division 1.*

In 2008, the CPUC approved the creation of a Water Revenue Adjustment Mechanism (WRAM) and Modified Cost Balancing Accounts (MCBA). The goals of the WRAM and MCBA are to sever the relationship between sales and revenue to remove the disincentive to reduce water use. The WRAM and MCBA are designed to be revenue neutral in order to ensure that both the utility and ratepayers are neither harmed nor benefitted.

In 2020, the CPUC ordered that regulated water utilities may not include the continuation of the WRAM and MCBA in their next general rate case filing but may propose the use of a Monterey-Style Revenue Adjustment Mechanism and Incremental Cost Balancing Account. As such, as of 2023 the WRAM and MCBA are no longer in place for Cal Water.

During a water shortage, Cal Water will file for a Drought Memorandum Account, or similar, to track incremental shortage-related expenses to be reviewed by the CPUC for future recovery in rates. Cal Water will also file for a Drought Lost Revenue Memorandum Account, or similar, to track reduced sales to be reviewed by the CPUC for future recovery in rates.

Both the Drought Memorandum Account and Drought Lost Revenue Memorandum Account are mechanisms that have been approved by the CPUC in previous droughts.

## Chapter 10

### Monitoring and Reporting

**CWC § 10632 (a) (9)** *For an urban retail water supplier, monitoring and reporting requirements and procedures that ensure appropriate data is collected, tracked, and analyzed for purposes of monitoring customer compliance and to meet state reporting requirements.*

During the period 2014-16, in order to effectively respond to the drought, Cal Water realigned its organizational structure to ensure sufficient resources were available to implement its WSCP. The day-to-day implementation was overseen by the Director of Drought Management & Conservation, with the assistance of the Drought Response Project Manager. The Director of Drought Management & Conservation reported to a team of Cal Water's Officers (Steering Committee), including the President & CEO, the Vice President of Corporate Communications & Community Affairs, the Vice President of Customer Service & Information Technology, the Vice President of Operations, and the Vice President of Continuous Improvement.

Reporting to the Director of Drought Management & Conservation was a team of functional leads, each responsible for managing individual portions of Cal Water's Plan. This team included the Director of Customer Service, the Water Conservation Manager, the Manager of Corporate Communications, the Water Supply Manager, and the Government & Community Relations Manager.

Cal Water will implement a similar structure to effectively manage future water shortages which will be overseen by the Vice President, Water Resources Planning and Sustainability.

This structure includes regular meetings with reporting on items such as:

- Aggregate customer demands,
- Customer compliance with water use restrictions,
- Current and projected water supply conditions,
- Customer outreach activities,
- Customer service inquiries, and
- Operations activities (e.g., water flushing activities, leak repairs, etc.).

## Chapter 11

### WSCP Refinement Procedures

**CWC § 10632 (a) (10)** *Reevaluation and improvement procedures for systematically monitoring and evaluating the functionality of the water shortage contingency plan in order to ensure shortage risk tolerance is adequate and appropriate water shortage mitigation strategies are implemented as needed.*

Cal Water's Drought Steering Committee utilizes an adaptive management process to regularly assess and determine adjustments and changes to the implementation of the WSCP. These refinements are overseen by the Vice President, Water Resources Planning and Sustainability through the team of functional leads.

## Chapter 12

### Plan Adoption, Submittal, and Availability

**CWC § 10632 (c)** *The urban water supplier shall make available the water shortage contingency plan prepared pursuant to this article to its customers and any city or county within which it provides water supplies no later than 30 days after adoption of the water shortage contingency plan.*

The deadline for public comments on the WSCP was May 23, 2026, three days after the public hearing. The final WSCP was formally adopted by Cal Water’s Vice President, Water Resources Planning and Sustainability on June 26, 2026. The District’s 2025 UWMP includes a copy of the signed Resolution of Plan Adoption and contains the following:

- Letters sent to and received from various agencies regarding the UWMP and WSCP; and,
- Correspondence between Cal Water and participating agencies.

The District’s 2025 UWMP and WSCP were submitted to DWR within 30 days of adoption and by the July 1, 2026 deadline. The submittal was done electronically through DWR’s Water Use Efficiency Data Portal, an online submittal tool. The adopted WSCP was also sent to the California State Library and to the cities and counties listed in Table 10-1 of the District’s 2025 UWMP.

On April 20, 2026, electronic versions of the draft 2025 UWMP and WSCP were made available for review on Cal Water’s website:

<https://www.calwater.com/conservation/uwmp2025>

**Attachment A**

Key Drought Response Tool Tables and Chart



# Drought Response Tool

Home    Input Baseline Year Water Use    Baseline Year Water Use Profile    Drought Response Actions    Estimated Water Savings    Drought Response Tracking

## 1 - Home

California Water Service - Dixon

Enter Agency Information	
Agency Name	Dixon
Total Population Served	9,468
Conservation Goal (%)	10%
Drought Shortage Level	Shortage Level 1
Number of Residential Accounts	2,877
Number of Commercial, Industrial, and Institutional (CII) Accounts	190
Number of Dedicated Irrigation Accounts	1
Baseline Year(s)	2024
Percentage of Residential Indoor Use During Minimum Month (%)	99%
Percentage of CII Indoor Use During Minimum Month (%)	92%
Comments	

Navigation	
<b>USER'S GUIDE</b>	Download and read the guide before using this Tool
<b>1 - HOME</b>	Enter agency information
<b>2 - INPUT BASELINE YEAR WATER USE</b>	Enter Baseline Year production and use
<b>3 - BASELINE YEAR WATER USE</b>	Review and confirm entered information
<b>4 - DROUGHT RESPONSE ACTIONS</b>	Select Drought Response Actions and input estimated water savings and implementation rates.
<b>5 - ESTIMATED WATER SAVINGS</b>	Review estimated water production and compare estimated savings to conservation target.
<b>6 - DROUGHT RESPONSE TRACKING</b>	Track production and water savings against the conservation target.



# Drought Response Tool

Home

Input Baseline  
Year Water Use

Baseline Year  
Water Use  
Profile

Drought  
Response  
Actions

Estimated  
Water Savings

Drought  
Response  
Tracking

## 1 - Home

California Water Service - Dixon

For questions about this tool or for additional information, contact:

**Anona Dutton, P.G., C.Hg.**  
[adutton@ekiconsult.com](mailto:adutton@ekiconsult.com)  
**(650) 292-9100**




**Disclaimer:** This electronic file is being provided by EKI Environment & Water Inc. (EKI; formerly Erler & Kalinowski, Inc.) at the request of (CLIENT). The Drought Response Tool was transmitted to CLIENT in electronic format, on a CD dated [DATE] (Original Document). Only the Original Document, provided to, and for the sole benefit of, CLIENT constitutes EKI's professional work product. An electronic copy of the Drought Response Tool is provided to CLIENT's Customer Agencies, for use only by CLIENT-designated Customer Agencies. The Drought Response Tool is copyrighted by EKI. All rights are reserved by EKI, and content may not be reproduced, downloaded, disseminated, published, or transferred in any form or by any means, except with the prior written permission of EKI. Customer Agencies may use the Drought Response Tool for reviewing potential drought response alternatives. The delivery to, or use by, Customer Agencies of the Drought Response Tool does not provide rights of reliance by Client Agencies or other third parties without the express written consent of EKI and subject to the execution of an agreement between such Customer Agency or other third party and EKI. EKI makes no warranties, either express or implied, of the electronic media or regarding its merchantability, applicability, compatibility with the recipients' computer equipment or software; of the fitness for any particular purpose; or that the electronic media contains no defect or is virus free. Use of EKI's Drought Response Tool, other electronic media, or other work product by Client Agency or others shall be at the party's sole risk. Further, by use of this electronic media, the user agrees, to the fullest extent permitted by law, to defend, indemnify and hold harmless EKI, CLIENT, and their officers, directors, employees, and subconsultants against all damages, liabilities or costs, including reasonable attorneys' fees and defense costs, arising from any use, modification or changes made to the electronic files by anyone other than EKI or from any unauthorized distribution or reuse of the electronic files without the prior written consent of EKI.

© 2015 Erler & Kalinowski, Inc.


### 3 - Baseline Year (2024) Water Use Profile Dixon

Baseline Year (2024) Annual Water Use Summary						
Units: <input type="text" value="(af)"/>						
<i>A summary of your Baseline Year water use by sector and major end use category is shown below. Select the units in which your production and use data are displayed.</i>						
Water Use	Total Production (af)	Water Use (af)				Comments
		Residential	CII	Dedicated Irrigation	Non-Revenue	
<b>Total</b>	1,337	829	106	0	402	
<b>Total Indoor</b>	571	516	55	--	--	
<b>Total Outdoor</b>	364	313	51	0	--	
<b>Total Non-Revenue</b>	402	--	--	--	402	
<b>Total Indoor %</b>	43%	62%	52%	0%	--	
<b>Total Outdoor %</b>	27%	38%	48%	100%	--	
<b>Total Non-Revenue %</b>	30%	--	--	--	100%	

**Baseline Year (2024) Percent Annual Water Use by Sector**





**Baseline Year (2024) Annual Water Use by Sector and End Use**



**Baseline Year (2024) Monthly Total Water Use by Sector**





### 3 - Baseline Year (2024) Water Use Profile Dixon



## 5 - Estimated Water Savings - Shortage Level 1 Dixon

Estimated Monthly Water Use and Savings Summary						
Units: <input type="text" value="(af)"/>						
<i>This provides a summary of the estimated production relative to Baseline Year production and potential water savings, assuming implementation of selected actions at the water savings and implementation rates indicated in the Drought Response Actions worksheet. Select the units that your production data are displayed in.</i>						
Month	Baseline Year (2024) Production (af)	Estimated Drought Year Production (af)	Estimated Potential Monthly Savings	Potential Cumulative Savings	Conservation Goal	Comments
January	79	74	6%	6%	10%	
February	70	66	6%	6%	10%	
March	71	67	5%	6%	10%	
April	75	70	6%	6%	10%	
May	101	92	9%	7%	10%	
June	145	128	12%	8%	10%	
July	169	147	13%	9%	10%	
August	148	130	12%	10%	10%	
September	153	134	12%	10%	10%	
October	127	113	11%	10%	10%	
November	113	101	10%	10%	10%	
December	86	80	7%	10%	10%	





# Drought Response Tool

Home    Input Baseline Year Water Use    Baseline Year Water Use Profile    Drought Response Actions    Estimated Water Savings    Drought Response Tracking

## 1 - Home



California Water Service - Dixon

Enter Agency Information	
Agency Name	Dixon
Total Population Served	9,468
Conservation Goal (%)	20%
Drought Shortage Level	Shortage Level 2
Number of Residential Accounts	2,877
Number of Commercial, Industrial, and Institutional (CII) Accounts	190
Number of Dedicated Irrigation Accounts	1
Baseline Year(s)	2024
Percentage of Residential Indoor Use During Minimum Month (%)	99%
Percentage of CII Indoor Use During Minimum Month (%)	92%
Comments	

Navigation	
<b>USER'S GUIDE</b>	Download and read the guide before using this Tool
<b>1 - HOME</b>	Enter agency information
<b>2 - INPUT BASELINE YEAR WATER USE</b>	Enter Baseline Year production and use
<b>3 - BASELINE YEAR WATER USE</b>	Review and confirm entered information
<b>4 - DROUGHT RESPONSE ACTIONS</b>	Select Drought Response Actions and input estimated water savings and implementation rates.
<b>5 - ESTIMATED WATER SAVINGS</b>	Review estimated water production and compare estimated savings to conservation target.
<b>6 - DROUGHT RESPONSE TRACKING</b>	Track production and water savings against the conservation target.

## 5 - Estimated Water Savings - Shortage Level 2 Dixon

Estimated Monthly Water Use and Savings Summary						
Units: <input type="text" value="(af)"/>						
<i>This provides a summary of the estimated production relative to Baseline Year production and potential water savings, assuming implementation of selected actions at the water savings and implementation rates indicated in the Drought Response Actions worksheet. Select the units that your production data are displayed in.</i>						
Month	Baseline Year (2024) Production (af)	Estimated Drought Year Production (af)	Estimated Potential Monthly Savings	Potential Cumulative Savings	Conservation Goal	Comments
January	79	67	15%	15%	20%	
February	70	60	15%	15%	20%	
March	71	61	13%	15%	20%	
April	75	64	15%	15%	20%	
May	101	82	19%	16%	20%	
June	145	113	22%	17%	20%	
July	169	129	23%	19%	20%	
August	148	115	22%	19%	20%	
September	153	118	23%	20%	20%	
October	127	101	21%	20%	20%	
November	113	90	20%	20%	20%	
December	86	72	16%	20%	20%	





# Drought Response Tool

Home    Input Baseline Year Water Use    Baseline Year Water Use Profile    Drought Response Actions    Estimated Water Savings    Drought Response Tracking

## 1 - Home



California Water Service - Dixon

Enter Agency Information	
Agency Name	Dixon
Total Population Served	9,468
Conservation Goal (%)	30%
Drought Shortage Level	Shortage Level 3
Number of Residential Accounts	2,877
Number of Commercial, Industrial, and Institutional (CII) Accounts	190
Number of Dedicated Irrigation Accounts	1
Baseline Year(s)	2024
Percentage of Residential Indoor Use During Minimum Month (%)	99%
Percentage of CII Indoor Use During Minimum Month (%)	92%
Comments	

Navigation	
<b>USER'S GUIDE</b>	Download and read the guide before using this Tool
<b>1 - HOME</b>	Enter agency information
<b>2 - INPUT BASELINE YEAR WATER USE</b>	Enter Baseline Year production and use
<b>3 - BASELINE YEAR WATER USE</b>	Review and confirm entered information
<b>4 - DROUGHT RESPONSE ACTIONS</b>	Select Drought Response Actions and input estimated water savings and implementation rates.
<b>5 - ESTIMATED WATER SAVINGS</b>	Review estimated water production and compare estimated savings to conservation target.
<b>6 - DROUGHT RESPONSE TRACKING</b>	Track production and water savings against the conservation target.

## 5 - Estimated Water Savings - Shortage Level 3 Dixon

Estimated Monthly Water Use and Savings Summary						
Units: <input type="text" value="(af)"/>						
<i>This provides a summary of the estimated production relative to Baseline Year production and potential water savings, assuming implementation of selected actions at the water savings and implementation rates indicated in the Drought Response Actions worksheet. Select the units that your production data are displayed in.</i>						
Month	Baseline Year (2024) Production (af)	Estimated Drought Year Production (af)	Estimated Potential Monthly Savings	Potential Cumulative Savings	Conservation Goal	Comments
January	79	57	28%	28%	30%	
February	70	51	27%	27%	30%	
March	71	52	27%	27%	30%	
April	75	54	27%	27%	30%	
May	101	71	30%	28%	30%	
June	145	99	32%	29%	30%	
July	169	114	32%	30%	30%	
August	148	101	32%	30%	30%	
September	153	104	32%	30%	30%	
October	127	88	31%	30%	30%	
November	113	78	30%	30%	30%	
December	86	62	28%	30%	30%	





# Drought Response Tool

Home    Input Baseline Year Water Use    Baseline Year Water Use Profile    Drought Response Actions    Estimated Water Savings    Drought Response Tracking

## 1 - Home



California Water Service - Dixon

Enter Agency Information	
Agency Name	Dixon
Total Population Served	9,468
Conservation Goal (%)	40%
Drought Shortage Level	Shortage Level 4
Number of Residential Accounts	2,877
Number of Commercial, Industrial, and Institutional (CII) Accounts	190
Number of Dedicated Irrigation Accounts	1
Baseline Year(s)	2024
Percentage of Residential Indoor Use During Minimum Month (%)	99%
Percentage of CII Indoor Use During Minimum Month (%)	92%
Comments	

Navigation	
<b>USER'S GUIDE</b>	Download and read the guide before using this Tool
<b>1 - HOME</b>	Enter agency information
<b>2 - INPUT BASELINE YEAR WATER USE</b>	Enter Baseline Year production and use
<b>3 - BASELINE YEAR WATER USE</b>	Review and confirm entered information
<b>4 - DROUGHT RESPONSE ACTIONS</b>	Select Drought Response Actions and input estimated water savings and implementation rates.
<b>5 - ESTIMATED WATER SAVINGS</b>	Review estimated water production and compare estimated savings to conservation target.
<b>6 - DROUGHT RESPONSE TRACKING</b>	Track production and water savings against the conservation target.

## 5 - Estimated Water Savings - Shortage Level 4 Dixon

Estimated Monthly Water Use and Savings Summary						
Units: <input type="text" value="(af)"/>						
<i>This provides a summary of the estimated production relative to Baseline Year production and potential water savings, assuming implementation of selected actions at the water savings and implementation rates indicated in the Drought Response Actions worksheet. Select the units that your production data are displayed in.</i>						
Month	Baseline Year (2024) Production (af)	Estimated Drought Year Production (af)	Estimated Potential Monthly Savings	Potential Cumulative Savings	Conservation Goal	Comments
January	79	52	33%	33%	40%	
February	70	47	33%	33%	40%	
March	71	49	31%	33%	40%	
April	75	50	33%	33%	40%	
May	101	62	38%	34%	40%	
June	145	82	44%	37%	40%	
July	169	93	45%	39%	40%	
August	148	84	43%	39%	40%	
September	153	86	44%	40%	40%	
October	127	75	41%	40%	40%	
November	113	67	40%	40%	40%	
December	86	56	35%	40%	40%	





# Drought Response Tool

Home    Input Baseline Year Water Use    Baseline Year Water Use Profile    Drought Response Actions    Estimated Water Savings    Drought Response Tracking

## 1 - Home



California Water Service - Dixon

Enter Agency Information	
Agency Name	Dixon
Total Population Served	9,468
Conservation Goal (%)	50%
Drought Shortage Level	Shortage Level 5
Number of Residential Accounts	2,877
Number of Commercial, Industrial, and Institutional (CII) Accounts	190
Number of Dedicated Irrigation Accounts	1
Baseline Year(s)	2024
Percentage of Residential Indoor Use During Minimum Month (%)	99%
Percentage of CII Indoor Use During Minimum Month (%)	92%
Comments	

Navigation	
<b>USER'S GUIDE</b>	Download and read the guide before using this Tool
<b>1 - HOME</b>	Enter agency information
<b>2 - INPUT BASELINE YEAR WATER USE</b>	Enter Baseline Year production and use
<b>3 - BASELINE YEAR WATER USE</b>	Review and confirm entered information
<b>4 - DROUGHT RESPONSE ACTIONS</b>	Select Drought Response Actions and input estimated water savings and implementation rates.
<b>5 - ESTIMATED WATER SAVINGS</b>	Review estimated water production and compare estimated savings to conservation target.
<b>6 - DROUGHT RESPONSE TRACKING</b>	Track production and water savings against the conservation target.

## 5 - Estimated Water Savings - Shortage Level 5 Dixon

Estimated Monthly Water Use and Savings Summary						
Units: <input type="text" value="(af)"/>						
<i>This provides a summary of the estimated production relative to Baseline Year production and potential water savings, assuming implementation of selected actions at the water savings and implementation rates indicated in the Drought Response Actions worksheet. Select the units that your production data are displayed in.</i>						
Month	Baseline Year (2024) Production (af)	Estimated Drought Year Production (af)	Estimated Potential Monthly Savings	Potential Cumulative Savings	Conservation Goal	Comments
January	79	48	39%	39%	50%	
February	70	44	38%	38%	50%	
March	71	46	35%	37%	50%	
April	75	46	38%	37%	50%	
May	101	54	47%	40%	50%	
June	145	64	56%	44%	50%	
July	169	71	58%	47%	50%	
August	148	66	55%	49%	50%	
September	153	67	56%	50%	50%	
October	127	61	52%	50%	50%	
November	113	56	50%	50%	50%	
December	86	50	41%	49%	50%	





# Drought Response Tool

Home    Input Baseline Year Water Use    Baseline Year Water Use Profile    Drought Response Actions    Estimated Water Savings    Drought Response Tracking

## 1 - Home



California Water Service - Dixon

Enter Agency Information	
Agency Name	Dixon
Total Population Served	9,468
Conservation Goal (%)	60%
Drought Shortage Level	Shortage Level 6
Number of Residential Accounts	2,877
Number of Commercial, Industrial, and Institutional (CII) Accounts	190
Number of Dedicated Irrigation Accounts	1
Baseline Year(s)	2024
Percentage of Residential Indoor Use During Minimum Month (%)	99%
Percentage of CII Indoor Use During Minimum Month (%)	92%
Comments	

Navigation	
<b>USER'S GUIDE</b>	Download and read the guide before using this Tool
<b>1 - HOME</b>	Enter agency information
<b>2 - INPUT BASELINE YEAR WATER USE</b>	Enter Baseline Year production and use
<b>3 - BASELINE YEAR WATER USE</b>	Review and confirm entered information
<b>4 - DROUGHT RESPONSE ACTIONS</b>	Select Drought Response Actions and input estimated water savings and implementation rates.
<b>5 - ESTIMATED WATER SAVINGS</b>	Review estimated water production and compare estimated savings to conservation target.
<b>6 - DROUGHT RESPONSE TRACKING</b>	Track production and water savings against the conservation target.

## 5 - Estimated Water Savings - Shortage Level 6 Dixon

Estimated Monthly Water Use and Savings Summary						
Units: <input type="text" value="(af)"/>						
<i>This provides a summary of the estimated production relative to Baseline Year production and potential water savings, assuming implementation of selected actions at the water savings and implementation rates indicated in the Drought Response Actions worksheet. Select the units that your production data are displayed in.</i>						
Month	Baseline Year (2024) Production (af)	Estimated Drought Year Production (af)	Estimated Potential Monthly Savings	Potential Cumulative Savings	Conservation Goal	Comments
January	79	39	50%	50%	60%	
February	70	36	49%	50%	60%	
March	71	38	46%	49%	60%	
April	75	38	49%	49%	60%	
May	101	43	57%	51%	60%	
June	145	50	65%	55%	60%	
July	169	55	67%	58%	60%	
August	148	52	65%	59%	60%	
September	153	52	66%	60%	60%	
October	127	48	62%	60%	60%	
November	113	45	60%	60%	60%	
December	86	41	52%	60%	60%	



**Attachment B**  
CPUC Rule and Schedule 14.1

Rule No. 14.1

**NON-ESSENTIAL, WASTEFUL USES OF POTABLE WATER**

(C)

**A) APPLICABILITY**

- 1. This rule applies to all of California Water Service’s regulated ratemaking areas in California, as well as Grand Oaks Water.

(C)  
(L)

**B) GENERAL INFORMATION**

- 1. All expenses incurred by California Water Service to implement Rule 14.1, and Schedule 14.1, that have not been considered in a General Rate Case or other proceeding shall be accumulated by Cal Water in a separate memorandum account, authorized by the Commission, for disposition as directed or authorized from time to time by the Commission.

(T)  
|  
(T)  
(D)

**C) DEFINITIONS**

For the purposes of this Rule, the following terms have the meanings set forth in this section.

- 1. “Commercial nursery” means the use of land, buildings or structures for the growing and/or storing of flowers, fruit, trees, ornamental trees, vegetable plants, shrubs, trees and similar vegetation for the purpose of transplanting, for use as stock or grafting, and includes the retail sale or wholesale distribution of such items directly from the premises/lot.
- 2. “Drip irrigation system” means a non-spray, low-pressure, and low volume irrigation system utilizing emission devices with a precipitation or flow rate measured in gallons per hour (GPH), designed to slowly apply small volumes of water at or near the root zone of plants or other landscaping.
- 3. “Flow rate” means the rate at which water flows through pipes, valves, and emission devices, measured in gallons per minute (GPM), gallons per hour (GPH), inches per hour (IPH), hundred cubic feet (Ccf), or cubic feet per second (CFS).
- 4. “Flow-restricting device” means valves, orifices, or other devices that reduce the flow of potable water through a service line, which are capable of providing the premise with a minimum flow rate of 0.5 gallons per minute.
- 5. “High-efficiency sprinkler systems” means an irrigation system with emission devices, such as sprinkler heads or nozzles, with a precipitation or flow rate no greater than on IPH.
- 6. “Irrigation” means the application of potable water by artificial means to landscape.

(C)  
(C)

(L)

(Continued)

(To be inserted by utility)	Issued By	(To be inserted by CPUC)
Advice Letter <u>2412</u>	<u>Greg A. Milleman</u>	Date Filed <u>06/14/2021</u>
Decision	<u>Vice President</u>	Effective <u>07/14/2021</u>
		Resolution _____

Rule No. 14.1

**NON-ESSENTIAL, WASTEFUL USES OF POTABLE WATER**

(C)

**C) DEFINITIONS (continued)**

(L)

- 7. "Irrigation system" means the components of a system meant to apply water to an area for the purpose of irrigation, including, but not limited to, piping, fittings, sprinkler heads or nozzles, drip tubing, valves, and control wiring.
- 8. "Landscape" means all of the outdoor planting areas, turf areas, and water features at a particular location.
- 9. "Measurable rainfall" means any amount of precipitation of more than one-quarter of an inch (0.25").
- 10. "Micro spray irrigation system" means a low-pressure, low-volume irrigation system utilizing emission devices that spray, mist, sprinkle, or drip with a precipitation or flow rate measured in GPH, designed to slowly apply small volumes of water to a specific area.
- 11. "Ornamental landscape" means shrubs, bushes, flowers, ground cover, turf, lawns, and grass planted for the purpose of improving the aesthetic appearance of property, but does not include crops or other agricultural products or special landscape areas.
- 12. "Ornamental turf" means a ground cover surface of grass that can be mowed and is planted for the purpose of improving the aesthetic appearance of the property, but does not include crops or other agricultural products or special landscape areas.
- 13. "Plumbing fixture" means a receptacle or device that is connected to a water supply system, including, but not limited to, pipes, toilets, urinals, showerheads, faucets, washing machines, water heaters, tubs, and dishwashers.
- 14. "Potable water" means water supplied by Cal Water which conforms to the federal and state standards for human consumption.
- 15. "Properly programmed" means a smart irrigation controller that has been programmed according to the manufacturer's instructions and site-specific conditions.
- 16. "Real-time water measurement device" means a device or system that provides regularly updated electronic information regarding the customer's water use.
- 17. "Runoff" means water which is not absorbed by the soil or landscape to which it is applied and flows from the landscape onto other areas.
- 18. "Smart irrigation controller" means an automatic device used to remotely control valves that operate an irrigation that has been tested by an American National Standards Institute accredited third-party certifying body or laboratory in accordance with the Environmental Protection Agency's WaterSense program (or an analogous successor program), and certified by such body or laboratory as meeting the performance and efficiency requirements of such program, or the more stringent performance and efficiency requirements of another similar program.

(C)  
(C)

(L)

(Continued)

(To be inserted by utility)	Issued By	(To be inserted by CPUC)
Advice Letter <u>2412</u>	<u>Greg A. Milleman</u>	Date Filed <u>06/14/2021</u>
Decision	<u>Vice President</u>	Effective <u>07/14/2021</u>
		Resolution _____

Rule No. 14.1

**NON-ESSENTIAL, WASTEFUL USES OF POTABLE WATER**

(C)

**C) DEFINITIONS (continued)**

(L)

- 19. "Special landscape area" means an area of landscape dedicated solely to edible plants and areas dedicated to active play such as parks, sports fields, golf courses, and where turf provides a playing surface.
- 20. "Turf" means a ground cover surface of grass that can be mowed.
- 21. "Water feature" means a design element where open, artificially supplied water performs an aesthetic or recreation feature, including, but not limited to, ponds, lakes, waterfalls, fountains, and streams.
- 22. "Water use evaluation" means an evaluation of the efficiency of indoor water-using devices, including, but not limited to, measurement of flow rates for all existing showerheads, faucets, and toilets, inspection for leaks, and providing written recommendations to improve the efficiency of the indoor water-using fixtures and devices and/or an evaluation of the performance of an irrigation system, including, but not limited to, inspection for leaks, reporting of overspray or runoff, and providing written recommendations to improve the performance of the irrigation system.

**D) ENFORCEMENT**

This Rule establishes certain restrictions on the use of potable water. Violating the restrictions set forth is declared a non-essential, wasteful use of potable water. Cal Water is authorized to take the following actions when its personnel verify a customer is using potable water for non-essential, wasteful uses. No person shall have any right or claim in law or in equity against Cal Water because of, or as a result of, any matter or thing done or threatened to be done pursuant to the restrictions on using potable water for non-essential, wasteful uses.

(T)  
(T)  
(C)

**1. FIRST VIOLATION**

Cal Water shall provide the customer with a written notice of violation. In addition, Cal Water is authorized to take the following actions:

- a) If the customer currently receives service through a metered connection, install a real-time water measurement device on the customer's service line and provide the customer with access to information from the device. The cost of the device, including installation and on-going operating costs, may be billed to the customer, and nonpayment may result in discontinuation of service.
- b)

(N)

(L)(N)

(Continued)

(To be inserted by utility)	Issued By	(To be inserted by CPUC)
Advice Letter <u>2412</u>	<u>Greg A. Milleman</u>	Date Filed <u>06/14/2021</u>
Decision	<u>Vice President</u>	Effective <u>07/14/2021</u>
		Resolution _____

Rule No. 14.1

**NON-ESSENTIAL, WASTEFUL USES OF POTABLE WATER**

(C)

**D) ENFORCEMENT (continued)**

(L)

**1. FIRST VIOLATION (continued)**

- b) If the customer does not currently receive service through a metered connection, install a water meter on the customer’s service line, charge the customer for water use pursuant to Cal Water’s metered service tariffs and rules, and install a real-time water measurement device on the customer’s service line and provide the customer with access to information from the device. The cost of the device, including installation and ongoing operating costs, may be billed to the customer, and nonpayment may result in discontinuance of service.

(N)

(N)

**2. SECOND VIOLATION**

If Cal Water verifies that the customer has used potable water for non-essential, wasteful uses after having been notified of the first violation, Cal Water shall provide the customer with a second written notice of violation and is authorized to install a flow-restricting device on the customer’s service line. Cal Water shall not be held liable for any injuries, damages, and/or consequences arising from the installation of a flow-restricting device.

**3. NOTICES OF VIOLATION:**

- a) Unless otherwise specified, written notices of violation provided to customers pursuant to this Rule shall document the verified violation and alert the customer to the fact that future violations of the restricted uses of potable water may result in a real-time water measurement device being installed on the customer’s service line at the customers expense, the installation of a flow-restricting device on the customer’s service line, or the discontinuation of the customer’s service.
- b) If Cal Water elects to install a flow-restricting device on a customer’s service line, the written notice shall document the steps the customer must take in order for the flow-restricting device to be removed, and shall explain that after the flow-restricting device is removed, it may be reinstalled, without further notice, if the customer is again verified by Cal Water to be using potable water for non-essential, wasteful uses.

(T)

(T)

(T)

(T)

(T)

(T)

(T)

**4. FLOW RESTRICTING DEVICE CONDITIONS**

The installation of a flow-restricting device on a customer’s service line is subject to the following conditions:

(L)

(Continued)

(To be inserted by utility)	Issued By	(To be inserted by CPUC)
Advice Letter <u>2412</u>	<u>Greg A. Milleman</u>	Date Filed <u>06/14/2021</u>
Decision	<u>Vice President</u>	Effective <u>07/14/2021</u>
		Resolution _____

Rule No. 14.1

**NON-ESSENTIAL, WASTEFUL USES OF POTABLE WATER**

(C)

**D) ENFORCEMENT (continued)**

(L)

**4. FLOW RESTRICTING DEVICE CONDITIONS (continued)**

- a) The device shall be capable of providing the premise with a minimum flow rate of 0.5 gallons per minute. (C)
- b) The device may only be removed by Cal Water, and only after a minimum three-day period has elapsed. (C)
- c) Any tampering with the device may result in the discontinuation of the customer's water service and the customer being charged for any damage to Cal Water's equipment or facilities and any required service visits.
- d) After the removal of the device, if Cal Water's personnel verify that the customer is using potable water for non-essential, wasteful uses, Cal Water may install another flow-restricting device without prior notice. This device shall remain in place until water supply conditions warrant its removal. If, despite the installation of the device, Cal Water's personnel verifies that the customer is using potable water for non-essential, wasteful uses, then Cal Water may discontinue the customer's water service, as provided in its Rule No. 11. (T)

**5. FLOW RESTRICTING DEVICE REMOVAL CHARGES**

The charge to customers for removal of a flow-restricting device installed pursuant to this Rule is \$100 during normal business hours, and \$150 for the device to be removed outside of normal business hours.

**E) WASTEFUL USES OF WATER**

Except where necessary to address an immediate health or safety need or to comply with a term or condition in a permit issued by a state or federal agency, customers are prohibited, at all times, from using potable water for the following actions, as each is declared a non-essential, wasteful use of water:

- a) Outdoor Irrigation Restrictions (C)
  - (i) Irrigating ornamental landscape with potable water is prohibited during the hours between 8:00 a.m. and 6:00 p.m.
  - (ii) The foregoing irrigation restriction does not apply to:
    - (1) Landscape irrigation zones that exclusively use drip irrigation systems and/or micro spray irrigation systems;

(L) (C)

(Continued)

(To be inserted by utility)	Issued By	(To be inserted by CPUC)
Advice Letter <u>2412</u>	<u>Greg A. Milleman</u>	Date Filed <u>06/14/2021</u>
Decision	<u>Vice President</u>	Effective <u>07/14/2021</u>
		Resolution _____

Rule No. 14.1

**NON-ESSENTIAL, WASTEFUL USES OF POTABLE WATER**

(C)

**E) WASTEFUL USES OF WATER (continued)**

(L)

a) Outdoor Irrigation Restrictions (continued)

(ii) The foregoing irrigation restriction does not apply to: (continued)

...

(2) Irrigating ornamental landscapes with the use of a hand-held bucket or similar container, with a continuously monitored hose which is fitted with an automatic shut-off nozzle or device attached to it that causes it to cease dispensing water immediately when not in use or monitored, or for the express purpose of adjusting or repairing an irrigation system.

(C)

b) Obligation to Fix Leaks, Breaks, or Malfunctions: All leaks, breaks, or other malfunctions in the customer's plumbing fixtures and/or irrigation system must be repaired within five (5) business days of written notification by Cal Water, unless other arrangements are made with Cal Water.

c) Prohibited Uses of Water: Customers are prohibited from using potable water for the following actions:

(i) The application of potable water to landscapes in a manner that causes runoff such that water flows onto adjacent property, non-irrigated areas, private and public walkways, roadways, parking lots, or structures;

(ii) The use of a hose that dispenses potable water to wash vehicles, including cars, trucks, buses, boats, aircraft, and trailers, whether motorized or not, except where the hose is fitted with a shut-off nozzle or device attached to it that causes it to cease dispensing water immediately when not in use;

(iii) The application of potable water to driveways and sidewalks;

(iv) The use of potable water in a water feature, except where the water is part of a recirculating system;

(v) The application of potable water to outdoor landscapes during and within forty-eight (48) hours after measurable rainfall (see Definitions);

(vi) Irrigation outside of newly constructed homes and buildings with potable water in a manner inconsistent with regulations or other requirements established by the California Building Standards Commission, the Department of Housing and Community Development, or other state agency.

(vii) The serving or drinking water other than upon request in eating and drinking establishments, including but not limited to restaurants, hotels, cafes, cafeterias, bars, or other public places where food or drink are served and/or purchased;

(L) (C)

(Continued)

(To be inserted by utility)  
Advice Letter 2412  
Decision

Issued By  
Greg A. Milleman  
Vice President

(To be inserted by CPUC)  
Date Filed 06/14/2021  
Effective 07/14/2021  
Resolution \_\_\_\_\_

Rule No. 14.1

**NON-ESSENTIAL, WASTEFUL USES OF POTABLE WATER**

(C)

**E) WASTEFUL USES OF WATER (continued)**

(L)

- d) Operators of hotels and motels shall provide guests with the option of choosing not to have towels and linens laundered daily. The hotel or motel shall prominently display notice of this option in each guest room using clear and easily understood language.
- e) Other duly adopted restrictions on the use of potable water as prescribed from time to time by the Commission or other authorized government agencies are incorporated herein by reference.

(C)

(C)

(D)

(T)

(T)

**F) ADOPTION OF SCHEDULE NO. 14.1 - STAGED MANDATORY REDUCTIONS AND DROUGHT SURCHARGES**

**1. Addition of Schedule No. 14.1**

If, in the opinion of Cal Water, more stringent water conservation measures are required due to supply conditions or government directive, Cal Water may request the addition of Schedule No. 14.1 – Staged Mandatory Reductions and Drought Surcharges, via a Tier 2 advice letter.

(T)

- a) Cal Water may not activate Schedule No. 14.1 until it has been authorized to do so by the California Public Utilities Commission, as delegated to its Division of Water and Audits.
- b) A Schedule No. 14.1 that has been authorized by the California Public Utilities Commission shall remain dormant until triggered by specific conditions detailed in the Schedule No. 14.1 tariff and Cal Water has requested and received authorization for activating a stage by the California Public Utilities Commission.
- c) Notice of the Tier 2 advice letter and associated public participation hearing, if required, shall be provided to customers through a bill insert or a direct mailing, as set forth in Subsection 5 (Public Notice) below.
- d) Cal Water shall comply with all requirements of Sections 350-358 of the California Water Code.
- e) The Tier 2 advice letter requesting the addition of a Schedule No. 14.1 shall include, but not be limited to:
  - (i) A proposed Schedule No. 14.1 tariff, which shall include but not be limited to:
    - (1) Applicability;
    - (2) Territory applicable to;

(L)

(Continued)

(To be inserted by utility)	Issued By	(To be inserted by CPUC)
Advice Letter <u>2412</u>	<u>Greg A. Milleman</u>	Date Filed <u>06/14/2021</u>
Decision	<u>Vice President</u>	Effective <u>07/14/2021</u>
		Resolution _____

Rule No. 14.1

**NON-ESSENTIAL, WASTEFUL USES OF POTABLE WATER**

(C)

**F) ADOPTION OF SCHEDULE NO. 14.1 - STAGED MANDATORY REDUCTIONS AND DROUGHT SURCHARGES (continued)**

(L)

**1. Addition of Schedule No. 14.1 (continued)**

e) The Tier 2 advice letter requesting the addition of a Schedule No. 14.1 shall include, but not be limited to: (continued)

(i) A proposed Schedule No. 14.1 tariff, which shall include but not be limited to: (continued)

...

(3) A detailed description of each stage (the number of stages requested for a ratemaking area may vary depending on the specifics of the water shortage event);

(T)

(T)

(4) A detailed description of the trigger(s) that activates each stage;

(T)

(5) A detailed description of each water use restriction for each stage of water budgets;

(6) Water use violation levels, written warning levels, associated penalties, if applicable, and exception procedures;

(T)

(7) Conditions for the installation of a flow-restricting device;

(T)

(8) Charges for the removal of a flow-restricting device; and

(T)

(9) Special conditions.

(ii) Justification for, and documentation and calculations in support of the water budgets.

**2. Conditions for Activating Schedule No. 14.1**

Cal Water may file a Tier 1 advice letter to request activation of a particular stage of Schedule No. 14.1 tariff if:

a) Cal Water, the California Public Utilities Commission, wholesale water supplier, or other government agency declares an emergency requiring mandatory water budgets, mandatory water rationing, or mandatory water allocations; or

b) A government agency declares a state of emergency in response to severe drought conditions, earthquake or other catastrophic event that severely reduces Cal Water's water supply; or

c) Water supplies are projected to be insufficient to meet normal customer demand by Cal Water; or

(C)

d) A water supply shortage or threatened shortage exists; or

e) Cal Water is unable to achieve water conservation targets set by itself or a governing agency; or

(L)(C)

(Continued)

(To be inserted by utility)

Issued By

(To be inserted by CPUC)

Advice Letter 2412

Greg A. Milleman

Date Filed 06/14/2021

Decision

Vice President

Effective 07/14/2021

Resolution \_\_\_\_\_

Rule No. 14.1

**NON-ESSENTIAL, WASTEFUL USES OF POTABLE WATER**

(C)

**F) ADOPTION OF SCHEDULE NO. 14.1 - STAGED MANDATORY REDUCTIONS AND DROUGHT SURCHARGES (continued)**

(L)

**2. Conditions for Activating Schedule No. 14.1 (continued)**

...

- f) Water conservation targets set by itself or a governing agency are insufficient; or
- g) Cal Water chooses to subsequently activate a different stage of the Schedule No. 14.1 tariff.

(C)

**3. Activating Schedule No. 14.1**

The Tier 1 advice letter requesting activation of a stage of the Schedule No. 14.1 tariff shall:

- a) Include, but not be limited to, a justification for activating the particular stage of Staged Mandatory Reductions and Drought Surcharges, as well as the period during which the particular stage will be in effect.
- b) Be accompanied by the customer notification measures detailed in sub-section 5 (Public Notice) below.

(C)

**4. De-Activating Schedule No. 14.1**

When Schedule No. 14.1 is activated and Cal Water determines that water supplies are again sufficient to meet normal demands, and mandatory water use reductions are no longer necessary, Cal Water shall seek the approval of the California Public Utilities Commission, via a Tier 1 advice letter, to de-activate the particular stage of mandatory water use reductions that had been authorized.

**5. Public Notice**

- a) When Cal Water requests the addition of Schedule No. 14.1 via a Tier 2 advice letter, it shall provide notice of the Tier 2 advice letter and associated public hearing to customers through bill inserts or direct mailing, and it shall comply with all requirements of Sections 350-358 of the California Water Code (CWC), including but not limited to the following:
  - (i) In order to be in compliance with both General Order 96-B and CWC, notice shall be provided via both newspaper and bill insert or direct mailing;
  - (ii) One notice shall be provided for each advice letter filed that includes both notice of the filing of the Tier 2 advice letter as well as the details of the public hearing (date, time, place, etc.);

(T)

(T)

(T)

(T)

(L)

(Continued)

(To be inserted by utility)	Issued By	(To be inserted by CPUC)
Advice Letter <u>2412</u>	<u>Greg A. Milleman</u>	Date Filed <u>06/14/2021</u>
Decision	<u>Vice President</u>	Effective <u>07/14/2021</u>
		Resolution _____

Rule No. 14.1

**NON-ESSENTIAL, WASTEFUL USES OF POTABLE WATER**

(C)

**F) ADOPTION OF SCHEDULE NO. 14.1 - STAGED MANDATORY REDUCTIONS AND DROUGHT SURCHARGES (continued)**

(L)

**5. Public Notice (continued)**

a) When Cal Water requests the addition of Schedule No. 14.1 via a Tier 2 advice letter, it shall provide notice of the Tier 2 advice letter and associated public hearing to customers through bill inserts or direct mailing, and it shall comply with all requirements of Sections 350-358 of the California Water Code (CWC), including but not limited to the following: (continued)

...

(iii) The public meeting shall be held after the Tier 2 advice letter is filed, and before the Commission authorizes the addition of Schedule No. 14.1 to the tariff, except in cases of emergency water shortages approved by the Commission;

(C)

(iv) Cal Water shall consult with Division of Water and Audits staff prior to filing advice letter, in order to determine details of the public meeting.

b) In the event that Schedule No. 14.1 is triggered, and Cal Water requests activation through the filing of a Tier 1 advice letter, Cal Water shall notify its customers and provide each customer with a summary of Schedule No. 14.1 by means of bill insert or direct mailing. Notification shall take place prior to imposing any penalties associated with this plan. If activation of Schedule No. 14.1 occurs one year or more since the public hearing associated with adding Schedule No. 14.1 to its tariffs, then Cal Water shall conduct a public hearing pursuant to California Water Code Section 351 prior to activating a stage of the tariff.

(T)

(T)

c) During the period that a stage of Schedule No. 14.1 is activated, Cal Water shall provide customers with updates in at least every other bill regarding its water supply status and the results of customers' conservation efforts.

(L)

(To be inserted by utility)

Issued By

(To be inserted by CPUC)

Advice Letter 2412

Greg A. Milleman

Date Filed 06/14/2021

Decision

Vice President

Effective 07/14/2021

Resolution \_\_\_\_\_

## Appendix H: Conservation Master Plan

# CONSERVATION MASTER PLAN 2026 – 2030



April 2026

Dixon District

California Water Service

Prepared by M.Cubed



## Executive Summary

---

This Conservation Master Plan presents California Water Service’s (Cal Water’s) strategy for managing water demand in the Dixon District over the 2026–2030 planning period. The plan describes historical conservation performance, emerging regulatory and resource drivers, the District’s conservation program framework, and the funding needed to support expanded conservation efforts.

### *Historical Progress*

The Dixon District has achieved substantial and sustained reductions in water use over the past two decades. Per capita water use has declined significantly, enabling the District to comply with the Water Conservation Act of 2009 (SB X7-7) and consistently exceed the California Public Utilities Commission (CPUC) conservation goals for Class A water utilities. These reductions reflect the combined effects of universal metering, conservation-oriented pricing, customer conservation programs, and state and federal plumbing and appliance efficiency standards.

### *Need for Expanded Conservation*

The conservation landscape facing the District is evolving. The State’s *Making Conservation a California Way of Life* (MCCWL) regulations establish increasingly stringent efficiency standards and reporting requirements beginning in 2027. At the same time, the Sustainable Groundwater Management Act (SGMA) requires groundwater basins serving the District to achieve long-term sustainability, reinforcing the need to reduce demand. These regulatory drivers are compounded by rising water supply costs, which make conservation an increasingly cost-effective resource.

Under baseline conditions reflecting currently authorized programs and anticipated passive efficiency gains, regulated water use in the District is projected to remain at or below Urban Water Use Objective (UWUO) requirements throughout the planning period. In contrast, baseline real water loss projections exceed the applicable state water loss standard beginning in 2028 and continue to do so throughout the forecast period. These results indicate that, absent additional water loss control measures, the District would not comply with the state’s real water loss performance standard, even in years when total regulated water use remains within its UWUO. Accordingly, enhanced leak detection, pressure management, infrastructure renewal, and related water loss control activities will be necessary to achieve compliance with the separate water loss performance requirement.

### *Conservation Program Strategy*

Cal Water’s conservation strategy integrates multiple demand-management tools within a centrally administered program framework designed to maximize consistency, cost-effectiveness, and regulatory compliance. Key elements include:

## Dixon District Conservation Master Plan: 2026-2030

- Residential and non-residential conservation programs
- Increased emphasis on outdoor landscape efficiency and high-water-use customers
- Universal metering and conservation-oriented rate design
- Proactive water loss management
- Water waste prevention under CPUC Rule 14.1
- Ongoing program tracking, empirical savings evaluations, and regulatory reporting

Together, these components position conservation as a long-term resource strategy that supports compliance with state efficiency standards, groundwater sustainability objectives, and cost-effective service delivery.

### *Budget and Implementation*

Because the Dixon District is projected to comply with its Urban Water Use Objective under currently authorized conservation levels and does not face significant SGMA-driven demand reduction requirements at this time, Cal Water has proposed a reduction in the District's conservation budget in the 2024 General Rate Case. The requested budget maintains funding for core program implementation while achieving efficiencies in public information and administrative support functions. While the District is not projected to comply with the state's real water loss performance standard under baseline conditions, water loss control measures are primarily funded through capital improvement and system replacement programs rather than the conservation budget. Accordingly, the proposed conservation funding level reflects the District's compliance outlook and program needs during the 2026–2030 planning period.

### *Conclusion*

Conservation is a core resource management function rather than a supplementary program. Continued investment in conservation will help the Dixon District meet evolving state requirements, reduce pressure on groundwater supplies, support water supply reliability, and manage the cost of service for customers. This plan establishes the framework for achieving these objectives during the 2026–2030 period and provides the foundation for future program adjustments as regulatory requirements and water use conditions continue to evolve.

## Table of Contents

Executive Summary.....	i
List of Acronyms.....	v
1 Introduction.....	1
1.1 Master Plan Scope and Objectives .....	1
1.2 Relationship to GRC and UWMP .....	2
1.3 Relationship to Water Shortage Contingency Plan.....	2
1.4 Plan Organization.....	3
2 District Overview.....	4
3 Need for Expanded Conservation.....	8
3.1 New State Regulations for Urban Water Use .....	8
3.1.1 UWUO Compliance Requirements .....	8
3.1.2 Mixed-Use Meter Requirements .....	11
3.1.3 CII Performance Measures.....	12
3.1.4 Overall Compliance Timeline and Enforcement Provisions.....	13
3.1.5 Non-Functional Turf Watering Ban.....	15
3.2 Addressing Groundwater Overdraft.....	15
3.3 Managing Cost of Service .....	18
3.4 Summary of Conservation Drivers .....	18
4 Progress Towards Conservation Goals and Targets .....	19
4.1 Compliance with Water Conservation Act of 2009 .....	19
4.2 Compliance with CPUC Conservation Goals .....	20
4.3 UWUO & Water Loss Compliance Assessment.....	21
4.4 Summary of Progress Toward Goals and Targets.....	25

Dixon District Conservation Master Plan: 2026-2030

5 Water Conservation Program Strategy..... 26

5.1 Program Administration ..... 26

5.2 Water Waste Prevention ..... 27

5.3 Metering and Conservation Pricing..... 28

5.4 Water Loss Management..... 29

5.5 Customer Conservation Programs..... 30

5.5.1 Current Customer Conservation Programs ..... 30

5.5.2 Future Customer Conservation Programs..... 31

5.5.3 CII BMPS..... 35

5.6 Program Monitoring and Reporting..... 37

5.7 Water Conservation Program Staffing..... 38

5.8 Summary of Water Conservation Program Strategy ..... 40

6 Current and Requested Conservation Budget ..... 42

6.1 Conservation Program Budget Components..... 42

6.2 Conservation Program Budget Adjustments..... 42

6.3 Conservation Program Budget Comparison..... 43

7 Conclusion ..... 46

## List of Acronyms

---

<b>AB</b>	Assembly Bill
<b>AF</b>	Acre-feet (one AF equals 325,851 gallons)
<b>AMI</b>	Advanced metering infrastructure
<b>AMR</b>	Automatic meter reading
<b>AWE</b>	Alliance for Water Efficiency
<b>BCR</b>	Benefit Cost Ratio
<b>BMP</b>	Best Management Practice
<b>CalWEP</b>	California Water Efficiency Partnership
<b>CII</b>	Commercial, industrial, and institutional
<b>CPUC</b>	California Public Utilities Commission
<b>CUWCC</b>	California Urban Water Conservation Council
<b>EO</b>	Executive Order
<b>GPCD</b>	Gallons per capita per day
<b>GPF</b>	Gallons per flush
<b>GPM</b>	Gallons per minute
<b>GRC</b>	General Rate Case
<b>HET</b>	High efficiency toilet
<b>HEU</b>	High efficiency urinal
<b>HEW</b>	High efficiency clothes washer
<b>IOU</b>	Investor-owned utility
<b>MaP</b>	Maximum performance toilet testing program
<b>MCCWL</b>	Making Conservation a California Way of Life
<b>MGD</b>	Million gallons per day
<b>MOU</b>	Memorandum of Understanding Regarding Urban Water Conservation in California
<b>SB</b>	Senate Bill
<b>SB X7-7</b>	Senate Bill X7-7 Water Conservation Act of 2009
<b>ULFT</b>	Ultra low flow toilet
<b>UWMP</b>	Urban Water Management Plan
<b>WF</b>	Water Factor
<b>WSCP</b>	Water Shortage Contingency Plan

# 1 Introduction

---

## 1.1 Master Plan Scope and Objectives

Cal Water is committed to helping its customers use water efficiently and has developed a broad portfolio of water conservation programs to support this objective. To ensure that these programs represent an appropriate and cost-effective mix, Cal Water routinely conducts comprehensive conservation program analysis and planning. This planning is undertaken on a five-year cycle in coordination with the Urban Water Management Plan (UWMP). The results of this planning effort for the Dixon District are summarized in this report, which covers the period from 2026 through 2030.

New State regulations, rising water supply costs, and increasing competition for limited water supplies are driving the need for expanded conservation programs. Although Cal Water and its customers have made substantial progress in improving water-use efficiency and managing demand over the past two decades, additional conservation will be required going forward.

The recently adopted *Making Conservation a California Way of Life* (MCCWL) regulations establish a new set of conservation requirements and performance targets for urban water suppliers. In addition, the Sustainable Groundwater Management Act (SGMA) requires groundwater basins to be brought into long-term sustainability, with increased conservation expected to play a central role. At the same time, rising water supply costs in many parts of the State are making conservation an increasingly cost-effective means of narrowing the gap between water supply and demand.

Together, these regulatory, hydrologic, and economic factors underscore the need to expand conservation programming in the Dixon District.

The primary purposes of this Conservation Master Plan are to:

- Serve as a high-level guidance document to inform annual conservation activities, including program implementation levels, staffing requirements, and budget needs, for both internal planning and stakeholder coordination.
- Summarize the portfolio of conservation measures that Cal Water plans to implement, including estimated water savings, program costs, and anticipated effects on water demand.
- Describe the evaluation process and criteria used to assess and select conservation measures.

## Dixon District Conservation Master Plan: 2026-2030

- Provide an update to the 2016–2020 Conservation Master Plan as part of Cal Water’s five-year review cycle, including an assessment of program performance and identification of any needed adjustments.
- Ensure that Cal Water districts are positioned to comply with the State’s *Making Conservation a California Way of Life* (MCCWL) regulations.

### 1.2 Relationship to GRC and UWMP

Cal Water’s operations are regulated by the California Public Utilities Commission (CPUC), which approves district-level budgets and rates through a triennial General Rate Case (GRC) proceeding. Conservation programs and associated expenditures are reviewed and authorized as part of each GRC.

The most recent completed GRC was initiated in 2021 and covered the three-year period from 2023 through 2025 (the 2021 GRC). Conservation programs and budgets reflected in this plan are those authorized under the 2021 GRC.

A subsequent GRC covering the period from 2026 through 2028 was initiated in 2024 (the 2024 GRC). In that proceeding, Cal Water has requested authorization for increased conservation program expenditures in the Dixon District to support compliance with state conservation and groundwater regulations. At the time this plan was prepared, a final decision in the 2024 GRC had not yet been issued. As a result, it remains uncertain whether the requested level of conservation program funding needed to support compliance with state conservation requirements will be approved.

This plan updates the Conservation Master Plan completed by Cal Water in 2021, which covered the 2021–2025 planning period. It serves as the primary source of information on the historical and planned implementation of conservation programs reported in the Dixon District’s 2025 Urban Water Management Plan (UWMP). A copy of this Conservation Master Plan is included as an appendix to the UWMP.

### 1.3 Relationship to Water Shortage Contingency Plan

The Water Conservation Master Plan is distinct from Cal Water’s Water Shortage Contingency Plan (WSCP), which is also included as part of each district’s UWMP. The primary purpose of the WSCP is to provide a framework for responding to water shortage emergencies, such as those caused by drought or other events that temporarily disrupt water supplies.

In contrast, the purpose of the Water Conservation Master Plan is to establish a long-term framework for education, assistance, and incentive programs designed to help customers use water efficiently on an ongoing basis. Regardless of drought conditions, water in California is an increasingly scarce resource, and investments in

water use efficiency have consistently been shown to be a cost-effective means of ensuring reliable water supplies over the long term.

While conservation programs become especially important during periods of water shortage, their primary objective is to support Cal Water's ability to reliably meet customer water needs well into the future.

## 1.4 Plan Organization

This Conservation Master Plan is organized to describe the context for conservation in the Dixon District, assess regulatory and resource drivers, outline the District's conservation strategy, and present the funding and implementation framework for the 2026–2030 planning period.

- **Section 2** describes the Dixon District service area, including population, customer characteristics, and historical water use trends.
- **Section 3** explains the need for expanded conservation, including new state efficiency requirements, groundwater sustainability considerations under SGMA, and the role of conservation in managing long-term cost of service.
- **Section 4** summarizes the District's performance relative to past and emerging conservation goals and regulatory targets, including SB X7-7, CPUC conservation goals, and Urban Water Use Objective (UWUO) requirements.
- **Section 5** presents the District's water conservation program strategy, including program administration, water waste prevention, metering and conservation pricing, water loss management, customer conservation programs, staffing, and program monitoring and reporting.
- **Section 6** describes the current and requested conservation budget, including budget components, proposed adjustments, and comparisons of authorized and requested funding levels.
- **Section 7** provides conclusions regarding the District's conservation progress, future needs, and the role of conservation as a long-term resource management strategy.

Together, these sections provide a comprehensive framework for understanding how conservation supports regulatory compliance, groundwater sustainability, water supply reliability, and cost-effective water service in the Dixon District.

## 2 District Overview


### District Quick Facts:

- Communities Served: Parts of the City of Dixon
- Population served in 2025: 9,394
- Residential Customers: 94% of total services and 89% of total use
- Sources of Supply: 100% local groundwater
- Average Annual Water Deliveries Last Five Years: 1,300 AF
- Average Per Capita Water Use Last Five Years: 122 GPCD

The Dixon District was formed in 1927 with the purchase of the water system from Pacific Gas and Electric Company. The District is located south of Interstate 80 in northern Solano County, approximately 20 miles southwest of Sacramento and 65 miles northeast of San Francisco. Water served by the District comes from local groundwater. The District operates nine groundwater wells, two storage tanks, and 32 miles of pipeline. On average, the District delivers 1.2 million gallons of water per day to 3,100 service connections. A map

of the service area boundaries is shown in Figure 1.

**Figure 1. Dixon District Service Area Boundaries**



## Dixon District Conservation Master Plan: 2026-2030


Service area population has remained largely unchanged over the past decade. The District provides water service to residential, commercial, industrial, and governmental customers. Residential customers account for approximately 94 percent of service connections and 89 percent of total water use within the District. The distribution of service connections and water sales by customer category is shown in Figures 2 and 3.

On a per capita basis, water use in the District has declined steadily since the mid-2000s. Between 2000 and 2025, water use per person decreased by 26 percent (Figure 4), falling from 159 gallons per capita per day (GPCD) to 118 GPCD. Over this period, total demand also decreased by 26 percent—from 1,669 AF in 2000 to 1,238 AF today.

Several factors have contributed to this long-term reduction in use. Tiered residential pricing was adopted in 2009, strengthening incentives for efficient household water use. Additionally, beginning in 2012, Cal Water tripled conservation program expenditures, expanding customer access to tools and resources that support water-use efficiency. Lastly, state and federal efficiency standards have significantly reduced water use from toilets, showers, clothes washers, and other plumbing fixtures.

Collectively, these actions have resulted in a sustained reduction in water use across the service area.

**Figure 2. Share of Services in 2025 by Customer Category**



**Figure 3. Share of Water Sales by Customer Category: 2021-2025**





Figure 4. Total and Per Capita Water Use: 2000 - 2025



### 3 Need for Expanded Conservation

While the Dixon District has achieved substantial reductions in per capita water use over the past two decades, evolving regulatory requirements, groundwater sustainability challenges, and rising water supply costs are increasing the need for additional conservation. Expanded conservation efforts will play a central role in meeting new state efficiency standards, supporting long-term groundwater reliability, and managing the cost of service for customers. The following sections describe these drivers in greater detail and explain how they shape the District’s conservation planning priorities.

#### 3.1 New State Regulations for Urban Water Use

In 2018, the California State Legislature enacted Senate Bill 606 and Assembly Bill 1668 to enhance the state's resilience against droughts and climate change. These laws – collectively referred to as the *Making Conservation a California Way of Life* legislation -- set stringent water efficiency standards that retail water suppliers must meet within an accelerated timeline. Starting in 2027, these suppliers are mandated to keep their water consumption within the limits of an Urban Water Use Objective (UWUO). The UWUO encompasses the aggregate efficient use of indoor and outdoor residential water uses, commercial landscape irrigation, and distribution system water loss. Furthermore, the regulations stipulate that water suppliers implement comprehensive commercial performance measures and substantially increase their reporting to the state on their progress in meeting these new requirements.

##### 3.1.1 UWUO Compliance Requirements

An urban retail water supplier’s UWUO represents the cumulative volumes of water shown in Figure 5.

Figure 5. Components of UWUO Standards



### *Residential Indoor Standard*

The Residential Indoor Standard sets the maximum allowable indoor water use, measured in gallons per capita per day (GPCD). Initially, Assembly Bill 1668 established a statewide standard of 55 GPCD until January 1, 2025, then reducing to 52.5 GPCD until January 1, 2030, when it drops further to 50 GPCD. However, adjustments were made with the enactment of Senate Bill 1157 in 2022, which now sets the indoor standard at 55 GPCD in 2024, decreasing to 47 GPCD in 2025, and further to 42 GPCD by 2030.

It has been estimated that indoor residential use in California currently averages about 50 GPCD.<sup>1</sup> Thus, meeting the 2030 standard implies a 16 percent reduction from current indoor usage levels.

### *Residential Outdoor Standard*

The outdoor standard is tailored to the efficient water use required for residential landscaping within each district's climate. It involves an aggregate water budget calculated as follows:

$$\text{Outdoor Residential Budget} = \text{LAM} \times \text{LEF} \times (\text{ETo} - \text{Peff}) \times 0.62$$

In this equation:

- **LAM** is the measured residential landscape area in square feet.
- **ETo** represents the reference evapotranspiration, measured in inches per year.<sup>2</sup>
- **Peff** is the effective precipitation, also in inches per year.<sup>3</sup>
- **LEF** (Landscape Efficiency Factor) is a regulatory factor that dictates the overall water budget.

The LEF poses significant compliance challenges due to its stringent reduction targets. Initially set at 0.80, the LEF will decrease to 0.63 starting July 1, 2035, and further to 0.55 by July 1, 2040.

For new residential landscapes, the standard is immediately more stringent, set at a LEF of 0.55 from the outset. This means that all new residential landscaping must meet this lower efficiency factor regardless of the current LEF enforced for existing landscapes. This regulation ensures that new developments contribute to water conservation efforts from their inception.

---

<sup>1</sup> See [Results of the Indoor Residential Water Use Study](#) prepared by the California Department of Water Resources.

<sup>2</sup> The amount of water needed to maintain cool season turf grass in a healthy condition.

<sup>3</sup> The portion of annual rainfall available for plant water requirements thereby reducing the amount needing to come from irrigation.

## Dixon District Conservation Master Plan: 2026-2030

The introduction of progressively lower LEF values for existing landscapes, combined with the standard for new developments, presents a considerable challenge. Maintaining the health of turf grass will be particularly difficult when the LEF drops below 0.8. Many communities may need to significantly reduce or even eliminate turf grass, a change that will transform the visual and functional aspects of residential outdoor spaces.

### *CII Dedicated Irrigation Meter Standard*

The water budget for CII Dedicated Irrigation Meters (DIMs) is calculated similarly to residential landscaping but adheres to a stricter standard. Starting July 1, 2040, the required efficiency factor for these meters will be set at 0.45, making the maintenance of landscapes with significant amounts of turf nearly unattainable. It is the responsibility of each retail water agency to accurately measure and map the landscape area for their dedicated irrigation accounts. These measurements are then incorporated into a landscape water use equation to establish a supplier-specific CII landscape budget.

For retail water suppliers, including Cal Water, that do not currently have a CII DIM customer classification, the regulations impose additional requirements. These suppliers are mandated to identify all CII Mixed Use Meters (MUMs) within their service areas that serve landscapes of half an acre or more of irrigated area. They must either install DIMs for these landscapes or implement at least two equivalent in-lieu technologies designed to measure and enhance landscape water-use efficiency at these sites. This aspect of the legislation ensures that all significant landscape areas, regardless of their current meter classification, are brought under stringent water use monitoring and management. The actions Cal Water will be required to take to satisfy these requirements are described in a subsequent section of this plan.

### *Water Loss Standard*

The Water Loss Standard, established by Senate Bill 555, sets rigorous criteria for managing "real" water loss, which includes actual physical leakage from a water supplier's distribution system. The standard specifies the maximum allowable water loss per connection per day for each urban water retailer's service area. This is determined using system-specific validated baseline water loss audit data.

Every year, water suppliers must conduct a detailed audit of their distribution systems to pinpoint where and how water losses occur—whether through leaks, meter inaccuracies, unauthorized consumption, or other inefficiencies. The primary objective is to accurately gauge the extent of water loss and to develop effective strategies to reduce it, thereby enhancing the overall efficiency of the water supply system and conserving water resources.

It is crucial to note that compliance with the Water Loss Standard is mandatory for all suppliers, regardless of their total water use relative to their UWUO. Even if a supplier's aggregate water usage falls below their designated UWUO, they must still


## Dixon District Conservation Master Plan: 2026-2030

meet their specific water loss standards. This separate and independent compliance requirement underscores the importance of including water loss monitoring, management, and reporting tasks in the plan.

### WUO Compliance Timeline

Compliance with these standards will require rigorous documentation and adherence to evolving guidelines, underscoring the escalating complexities water suppliers face under the UWUO compliance framework. Figure 6 outlines the compliance timelines for these regulatory components.

Figure 6. Compliance Timeline for Meeting WUO Standards



### 3.1.2 Mixed-Use Meter Requirements

As discussed above, the regulations mandate that each retail water agency must identify all CII MUM accounts with landscaped areas of half an acre or more by June 30, 2027. These sites must either be converted to dedicated irrigation meters by 2039 or be equipped with at least two approved in-lieu water management technologies. By June 30, 2040, suppliers are required to achieve and maintain a 95% conversion rate to dedicated irrigation meters or equivalent interventions annually.

## Dixon District Conservation Master Plan: 2026-2030

For water suppliers opting to implement in-lieu water management technologies on CII large landscapes, they have until June 30, 2029, to identify all sites that will require treatment. Acceptable in-lieu water management technologies include:

1. Water budget-based management programs without a specific rate structure.
2. Water budget-based rate structures.
3. Installation of technologies that support detailed monitoring and analysis of outdoor water use, such as Advanced Metering Infrastructure.
4. Use of remote sensing or similar technologies to monitor and analyze outdoor water usage.
5. Other technologies that assist in water use analysis or enhance outdoor water use efficiency, pending Board approval.

Additionally, the proposed regulations require water suppliers managing large landscapes without Dedicated Irrigation Meters to implement the following water management practices:

1. Regular communications with users about water efficiency.
2. Maintenance of irrigation systems to ensure optimal performance.
3. Adherence to efficient irrigation scheduling practices to minimize waste.

These requirements are designed to ensure more precise water use monitoring and management, helping these sites to meet conservation goals and comply with regulatory standards.

### 3.1.3 CII Performance Measures

For CII properties, the state has not set efficiency standards per se but has mandated specific performance measures due to the high variability and insufficient data on water use across commercial properties. The proposed measures aim to identify high water users and promote efficiency within this sector.

These new requirements entail substantial utility staff efforts to analyze the water usage of CII customers. One such task requires categorizing all CII accounts into 19 Energy Star Portfolio Manager property types, in addition to three specialized water-centric business categories: water recreation, vehicle washes, and laundries.

Additionally, suppliers are required to identify all buildings within their service area that are 50,000 square feet or larger by June 30, 2024, or when the regulations take effect—whichever is later. The regulations require water suppliers to provide an aggregate water use report to each of these properties upon request from the building owner or their representative.

Water suppliers are also tasked with identifying their Top Water Users in CII and choosing from three tracks of Best Management Practices (BMP) compliance to

## Dixon District Conservation Master Plan: 2026-2030

address the highest water users. Full implementation for all tracks must be finalized by June 30, 2039. Each track is detailed as follows:

- **Track 1:** By June 30, 2025, identify both the top 2.5% and top 20% of all CII water users. Implement a conservation program that includes at least two BMPs from each of five BMP categories for the top 2.5% (10 BMPs in total), and one BMP from the same categories for the top 20% (5 BMPs in total).
- **Track 2:** By June 30, 2027, identify the top 2.5% and top 20% of water users within each of the 22 CII classification categories. Implement a conservation program that includes at least two BMPs from each of five BMP categories for the top 2.5% users, and one BMP from the same categories for the top 20% in each category.
- **Track 3:** By June 30, 2029, identify existing CII connections deemed inefficient based on Key Business Activity Indicators (KBAI) developed for each of the 22 CII categories. Implement a conservation program that includes at least one BMP from each of the five BMP categories.


### *CII Performance Measures and UWUO Compliance*

Despite the comprehensive nature of these measures, it is important to note that none of the savings achieved through these efforts will count towards a water agency's compliance with their UWUO. Although these measures are a legally mandated and significant undertaking, they do not directly contribute to UWUO compliance, presenting a challenging scenario for suppliers who must fulfill these obligations without them counting towards their UWUO compliance requirements.

### 3.1.4 Overall Compliance Timeline and Enforcement Provisions

Figure 7 outlines the critical reporting dates and compliance milestones associated with the *Making Conservation a California Way of Life* regulatory framework. This schedule details the progressive tightening of standards from 2025 to 2040. Starting on January 1, 2027, water suppliers are required to demonstrate compliance with the UWUO on an annual basis.

Figure 7. Making Conservation a California Way of Life Regulatory Framework Timeline



Beginning in 2027, under the new regulations, retail water suppliers are mandated to maintain their actual water use at or below the levels specified by their UWUO. After November 1, 2027, the State Water Board is empowered to enforce civil penalties for non-compliance. These penalties can reach up to \$1,000 per day in non-drought years and escalate to \$10,000 per day during drought conditions. In addition to monetary

## Dixon District Conservation Master Plan: 2026-2030

finances, the State Water Board may issue informational orders demanding specific data and information needed for assessing compliance, as well as conservation orders that mandate actions to be taken by the water supplier to enhance water resource conservation.

Although the State Water Board has indicated a possible delay in enforcement to allow water suppliers adequate time to adhere to these standards, it is important to acknowledge that the 2018 legislation codifies these deadlines. Consequently, water suppliers remain at risk of third-party lawsuits grounded on claims of waste and unreasonable use if they do not achieve UWUO compliance by the stipulated dates.

### 3.1.5 Non-Functional Turf Watering Ban

Alongside the *Making Conservation a California Way of Life* framework, a separate regulation now exists that restricts the use of potable water for watering "non-functional" turf. Drawing inspiration from a similar initiative in Nevada, the California Legislature enacted Assembly Bill 1572 in October 2023. This law prohibits the irrigation of non-functional turf on CII properties using potable water. Although property owners retain autonomy to determine what qualifies as "functional" versus "non-functional" turf, water suppliers are tasked with updating their ordinances and communicating the prohibitions to customers. Additionally, suppliers may choose to provide technical or turf replacement program support to customers facing turf removal, necessitating further allocation of staff and budgetary resources.

## 3.2 Addressing Groundwater Overdraft

Decades of groundwater overdraft in California's Central Valley—where groundwater pumping routinely exceeded natural recharge—has led to significant declines in groundwater levels and widespread land subsidence. In some areas, subsidence has damaged canals, roads, and other infrastructure and permanently reduced aquifer storage capacity. These conditions highlighted the long-term consequences of unmanaged groundwater use and were a key factor leading to enactment of the Sustainable Groundwater Management Act (SGMA) in 2014, which established a statewide framework for achieving sustainable groundwater management.

SGMA provides a comprehensive framework for sustainable, local groundwater management. It mandates that regions reliant on groundwater cease overdraft activities and achieve balanced levels of pumping and recharge. Key components of SGMA include:

- Defining "sustainable groundwater management."
- Mandating Groundwater Sustainability Plans for California's most critically impacted groundwater basins.

## Dixon District Conservation Master Plan: 2026-2030


- Setting a timeline for the adoption of these plans.
- Empowering local agencies with the authority to manage basins sustainably.
- Outlining specific requirements for Groundwater Sustainability Plans.
- Limiting the state's role in groundwater management.

Under SGMA, Groundwater Sustainability Agencies (GSAs) were required to be established in the state's high- and medium-priority basins and sub-basins by June 30, 2017. Following this initial milestone, over 260 GSAs were formed across more than 140 basins. Basins that were newly designated as high or medium priority in 2019 had two years from the reprioritization date to either establish a GSA or submit an alternative plan. The Water Code mandates that a GSA must manage its basin under a Groundwater Sustainability Plan (GSP) within five years of reprioritization. The planning deadline for California's first round of GSPs was January 31, 2020, for basins in critical conditions of overdraft, and January 31, 2022, for all other high- and medium-priority basins.

GSPs developed under SGMA generally incorporate enhanced conservation as part of a broader portfolio of actions to eliminate long-term groundwater overdraft. While many plans include supply-side projects such as recharge, recycled water, and surface water imports, most also recognize that achieving basin sustainability will require reductions in groundwater demand. As a result, GSPs commonly include expanded urban and agricultural water-use efficiency programs, irrigation and landscape efficiency improvements, and voluntary conservation measures, alongside potential demand-management tools such as pumping allocations, land repurposing, and crop or irrigation practice changes where needed. Although the emphasis and level of detail vary by basin, the overall planning framework reflects a growing recognition that conservation and demand reduction are essential components of long-term SGMA compliance, particularly in critically overdrafted Central Valley basins.

As illustrated in Figure 8, the Dixon District operates within a medium-priority groundwater basin. Although the potential for mandated reductions in groundwater pumping or other demand management requirements is not as high in medium-priority basins as it is in high-priority and critically overdrafted basins, SGMA nonetheless introduces an additional layer of regulatory oversight, potentially necessitating further reductions in water demand beyond those established by the *Making Conservation a California Way of Life* framework.

Figure 8. Location of Cal Water Districts in Critical, High, and Medium Priority Basins



### 3.3 Managing Cost of Service

In addition to meeting regulatory and groundwater sustainability requirements, expanded conservation plays an important role in managing the long-term cost of water service. Many of Cal Water’s conservation programs are able to generate verified water savings at a cost in the range of approximately \$500 to \$1,000 per acre-foot (AF), placing conservation among the lower-cost water resource options available to the District. By comparison, purchased surface water supplies often cost more than \$1,000 per AF, and the development of new supply sources—such as recycled water, groundwater remediation, desalination, or new surface storage—can exceed \$2,000 per AF when capital, treatment, conveyance, and operating costs are considered.

Because conservation can reduce the volume and timing of higher-cost supply acquisitions, it helps moderate upward pressure on rates while also improving supply reliability. In many situations, enhanced conservation represents one of the lowest-cost sources of incremental water supply available to the District and plays an important role in managing future cost-of-service impacts for customers, even as additional supply investments may still be required over the long term.

### 3.4 Summary of Conservation Drivers

Taken together, regulatory, hydrologic, and economic factors create a strong and continuing need for conservation in the Dixon District. The State’s *Making Conservation a California Way of Life* (MCCWL) regulations establish increasingly stringent water use efficiency standards and reporting requirements that will require additional reductions in residential, landscape, and system water use over time. At the same time, the Sustainable Groundwater Management Act (SGMA) requires groundwater basins serving the District to achieve long-term sustainability, increasing the likelihood of demand management actions and reinforcing the importance of reducing reliance on groundwater supplies.

In parallel with these regulatory and resource constraints, the cost of developing or acquiring additional water supplies continues to rise. Compared with purchased water and new supply development, conservation often represents the least-cost resource available to meet incremental demand and maintain system reliability. Expanded conservation therefore serves multiple objectives: supporting compliance with State regulations, contributing to groundwater sustainability, and helping manage long-term cost-of-service impacts for customers. For these reasons, conservation will remain a central component of the District’s resource management strategy over the 2026–2030 planning period and beyond.

## 4 Progress Towards Conservation Goals and Targets

---

This section summarizes the Dixon District’s progress toward key state and regulatory conservation requirements and assesses the District’s outlook for compliance with new state conservation requirements. It reviews performance relative to the Water Conservation Act of 2009 (SB X7-7) and the California Public Utilities Commission (CPUC) conservation goals, both of which reflect historical reductions in per capita water use. It then evaluates future compliance with the State’s Urban Water Use Objective (UWUO) framework under the *Making Conservation a California Way of Life* regulations, which establish increasingly stringent efficiency requirements beginning in 2027.

Together, these measures provide a bridge between past conservation achievements and the additional reductions that will be required in the coming decades. The analysis highlights that while the District has met or exceeded prior conservation targets, further conservation beyond currently authorized levels will likely be necessary to maintain compliance with post-2030 state efficiency standards.


### 4.1 Compliance with Water Conservation Act of 2009

The Water Conservation Act of 2009 (SB X7-7) required urban retail water suppliers to achieve a 20 percent reduction in per capita water use by 2020. To comply, each supplier was required to establish a 2020 per capita water use target based on historical water use. The statute also allowed suppliers to meet the requirement through participation in a Regional Alliance with other urban retail water suppliers.

The Dixon District formed a Regional Alliance with other Cal Water districts located within the Sacramento River Hydrologic Region. Under SB X7-7, compliance is achieved if either the District’s individual per capita water use or the Regional Alliance’s aggregate per capita water use remains below the applicable target.

As shown in Figure 9, the District has maintained compliance with the Water Conservation Act of 2009. In 2025, both the District’s and the Regional Alliance’s per capita water use remained well below their respective targets, reflecting on-going improvements in water-use efficiency by the District and its customers.


Figure 9. 2020 Target and Actual Per Capita Water Use



## 4.2 Compliance with CPUC Conservation Goals

In 2008, the CPUC established a water conservation goal of 1 to 2 percent per annum for Class A water utilities, including California Water Service Company. As shown in Figure 10, the Dixon District has consistently exceeded this goal. Since adoption of the CPUC's conservation goal, District per capita water use has declined by approximately 33 percent.

**Figure 10. District Per Capita Water Use Relative to CPUC Conservation Goals**



### 4.3 UWUO & Water Loss Compliance Assessment

As described in Section 3, the UWUO establishes an aggregate water-water budget calculated from: (1) a residential indoor water use standard; (2) a residential outdoor water budget; (3) a CII landscape outdoor water use budget for landscapes served by dedicated irrigation meters; (4) a water loss budget; (5) allowable variances; and (6) a potable reuse bonus. Beginning in 2027, the District must annually assess whether the sum of its regulated water uses—residential indoor and outdoor use, dedicated irrigation meter use, and distribution system water loss—is at or below its UWUO. Additionally, starting in 2028, the District must demonstrate that real and apparent distribution system water loss rates are less than their corresponding standards.<sup>4</sup> As noted in Section 3, compliance with the water loss standards is required even if the District’s total regulated water use is below its UWUO.

The state standards underlying the residential indoor, residential outdoor, and CII outdoor components of the UWUO will become increasingly stringent over time. As a result, compliance is expected to require continued reductions in water use beyond those achieved under the SB X7-7 framework.

<sup>4</sup> Real losses refer to physical loss of water through leaks, spills, and seeps, while apparent losses refer to unaccounted for water due to meter inaccuracies, administrative or record keeping errors, or theft.

## Dixon District Conservation Master Plan: 2026-2030

Cal Water has evaluated how projected regulated water use in the Dixon District compares to anticipated UWUO requirements over the UWMP 2025-2050 planning horizon. The assessment is predicated on levels of conservation that are currently authorized by the CPUC, together with anticipated passive conservation savings. These passive savings include continued turnover of plumbing fixtures and appliances subject to state and federal efficiency standards and customer behavioral responses to conservation-oriented rate structures.


Under this baseline demand scenario, regulated water use in the Dixon District is projected to remain below or near the applicable UWUO requirements throughout most of the forecast period, as shown in Table 1 and Figure 11. While modest exceedances are projected in certain years, these differences are relatively small and indicate that only limited additional conservation may be needed to maintain compliance under the UWUO framework.

In contrast, baseline real water loss projections exceed the applicable state water loss standard beginning in 2028 and continue to do so throughout the forecast period. As shown in Table 1 and Figure 11, projected real water loss ranges from approximately 296 to 330 acre-feet per year, while the corresponding standard ranges from approximately 160 to 179 acre-feet per year. The projected exceedance grows from roughly 136 acre-feet in 2030 to more than 150 acre-feet by 2050. These results indicate that, absent additional water loss control measures, the District would not comply with the state's real water loss performance standard, even in years when total regulated water use remains within its UWUO. Accordingly, enhanced leak detection, pressure management, infrastructure renewal, and related water loss control activities will be necessary to achieve compliance with the separate water loss performance requirement.

**Table 1. Dixon District Projected Regulated Demands vs UWUO**

Regulated Water Use					
Year	Service Area Population (a)	Water Demand Subject to UWUO Compliance (b)	UWUO Projections	Over (+)/Under (-) UWUO	
		(AF)	(AF)	(AF)	(GPCD)
2025	9,394	1,099	1,404	-305	-29
2030	9,668	1,099	1,195	-97	-9
2035	9,950	1,094	1,111	-17	-2
2040	10,239	1,100	1,087	+13	+1
2045	10,538	1,113	1,119	-6	-0
2050	10,844	1,127	1,151	-24	-2
Distribution System Real Water Loss					
Year	Service Area Population (a)	Baseline Real Water Loss Projections	Real Water Loss Standard Projections	Over (+)/Under (-) Standard	
		(AF)	(AF)	(AF)	(GPCD)
2025	9,394	288	288	0	0
2030	9,668	296	164	+132	+12
2035	9,950	304	169	+135	+12
2040	10,239	312	173	+139	+12
2045	10,538	321	178	+143	+12
2050	10,844	330	183	+147	+12
NOTES:					
(a) From 2025 UWMP Table 3-1.					
(b) Water demand subject to UWUO compliance includes single family, multi-family, dedicated irrigation meter, and water loss sectors (excluding unbilled authorized consumption) and is detailed in 20205 UWMP Table 4-2.					

Figure 11. Dixon District Projected Regulated Demands & Real Water Loss



## 4.4 Summary of Progress Toward Goals and Targets

The Dixon District has demonstrated strong performance relative to historical conservation requirements. Per capita water use has declined substantially over the past two decades, enabling the District to maintain compliance with the Water Conservation Act of 2009 and to consistently exceed CPUC conservation goals for Class A water utilities. These results reflect the combined effects of conservation programming, metering, conservation-oriented pricing, and state and federal plumbing and appliance efficiency standards.

Looking forward, the District's baseline demand projections—reflecting currently authorized conservation and anticipated passive efficiency gains—indicate that regulated water use is expected to remain below or near UWUO requirements throughout the forecast period. In contrast, baseline real water loss projections exceed the applicable state water loss standard beginning in 2028 and continue to do so throughout the forecast period. These results indicate that, absent additional water loss control measures, the District would not comply with the state's real water loss performance standard, even in years when total regulated water use remains within its UWUO.

In summary, the District has successfully met past conservation targets and is positioned to comply with near-term UWUO requirements. However, sustained progress toward long-term state efficiency standards will depend on continued program refinement and expansion of conservation efforts in the coming planning cycles.

## 5 Water Conservation Program Strategy

---

This section describes the strategy Cal Water uses to manage water demand in the Dixon District and to support compliance with state conservation, groundwater sustainability, and cost-of-service objectives. Rather than relying on any single measure, the District’s approach combines regulatory tools, pricing signals, system efficiency improvements, and customer-focused conservation programs to achieve sustained reductions in water use.

The strategy is implemented within a centrally administered program framework that promotes consistency, cost-effectiveness, and regulatory compliance across Cal Water’s service areas. Within this structure, the District applies a coordinated set of actions that include water waste prevention and enforcement, universal metering and conservation-oriented pricing, water loss management, residential and non-residential conservation programs, and expanded efforts to transform outdoor landscape water use in response to emerging state efficiency standards. The subsections that follow describe how these elements work together to form an integrated long-term demand management strategy.

### 5.1 Program Administration

Cal Water administers its conservation programs on a centralized basis across its service districts. This structure reflects both operational and regulatory considerations. Because Cal Water operates as a single regulated utility, conservation program budgets, designs, and performance are reviewed and authorized through statewide CPUC General Rate Case proceedings. Centralized administration helps ensure that programs are implemented consistently with CPUC authorizations and reporting requirements while allowing Cal Water to maintain standardized tracking, evaluation, and compliance processes.

Central administration also creates important efficiencies. By offering a core set of programs across multiple districts, Cal Water can leverage economies of scale in program design, marketing, rebate fulfillment, data management, and vendor contracting. These scale advantages reduce per-unit program costs and improve overall cost-effectiveness. Consistent program offerings also simplify customer communications and expectations, as customers across districts have access to a similar suite of rebates, services, and educational resources.

While program administration is centralized, implementation is informed by local conditions. Marketing emphasis, customer targeting, and outreach strategies are adjusted to reflect district-specific conservation drivers, such as groundwater sustainability requirements, UWUO compliance needs, and customer water use characteristics. This structure allows Cal Water to balance systemwide efficiency with responsiveness to the Dixon District’s particular conservation needs.

## 5.2 Water Waste Prevention

Cal Water's authority to enforce water waste prevention measures and water use restrictions is established and overseen by the CPUC through Rule 14.1 or Schedule 14.1. In addition, local governments within Cal Water districts may adopt ordinances regulating water use. Cal Water coordinates its water waste prevention efforts with applicable local jurisdictions. For the Dixon District, this coordination includes the City of Dixon and Yolo County.

CPUC Rule 14.1 defines the District's Water Shortage Contingency Plan, including, but not limited to, permanent prohibitions on water waste and restrictions on water use. Prohibited water waste practices include, but are not limited to, the following:

- Use of potable water through a broken or defective plumbing fixture or irrigation system after Cal Water has provided written notice to repair the condition and the customer has failed to complete repairs within seven business days of receipt of the notice.
- Application of potable water to landscapes in a manner that results in runoff onto adjacent property, non-irrigated areas, sidewalks, roadways, parking lots, or structures.
- Use of a hose to wash vehicles—including cars, trucks, buses, boats, aircraft, and trailers—unless the hose is equipped with a shut-off nozzle or similar device that immediately stops water flow when not in use.

During water shortage conditions, Schedule 14.1 also authorizes Cal Water to implement additional water use restrictions, which may include the following:

- Limitations on outdoor irrigation, including restrictions on time of day and frequency of watering.
- Requirements to repair leaks, breaks, or malfunctions following written notification by Cal Water.
- Application of potable water to driveways, sidewalks, and other hardscapes.
- Use of potable water in water features unless the feature operates as a recirculating system.
- Application of potable water to outdoor landscapes during and within 48 hours following measurable rainfall.
- Serving drinking water in eating or drinking establishments unless requested by the customer.

## Dixon District Conservation Master Plan: 2026-2030

- Irrigation of ornamental landscaping on public street medians.
- Irrigation of landscapes at newly constructed homes or buildings using potable water in a manner inconsistent with requirements established by the California Building Standards Commission or the Department of Housing and Community Development.
- Requirements for hotels and motels to provide guests with the option to decline daily laundering of towels and linens, with clear and prominent notice provided in each guest room.
- Limitations on filling ornamental lakes or ponds.
- Use of potable water for street cleaning, except for initial wash-down associated with construction activities.
- Use of potable water for construction-related purposes, such as dust control or backfill consolidation, unless no alternative water source or method is available.

These measures are a component of the District’s overall demand management strategy and support compliance with state water conservation regulations.

### 5.3 Metering and Conservation Pricing

Metering provides the measurement needed to track usage, identify leaks and high-use patterns, and manage demand effectively—because water use cannot be managed if it is not measured—while volumetric and tiered pricing structures create clear financial incentives for customers to use water efficiently.

#### *Metered Service*

All services in the District are metered and routinely calibrated and tested for accuracy. Metering water use provides improved customer awareness of water use, stronger price signals under volumetric billing, and the identification and repair of leaks. Metered households typically use 10 to 30 percent less water than similar unmetered households.<sup>5</sup>

#### *Advanced Metering Infrastructure*

Cal Water is also piloting automatic meter reading (AMR) and advanced metering infrastructure (AMI). If deployed more broadly in the future, AMI would enhance the District’s ability to detect leaks and other system issues and to notify customers of potential problems. AMI would also allow the provision of more timely and detailed

---

<sup>5</sup> Tanverakul, S. A., & Lee, J. (2015). *Impacts of Metering on Residential Water Use in California*. Journal of the American Water Works Association, 107(2).

## Dixon District Conservation Master Plan: 2026-2030

water use information, supporting customer engagement as well as enabling customers to more closely monitor their own water usage and take appropriate actions to improve their water use efficiency.

### *Conservation Pricing*

The District uses a four-tier increasing block rate structure for residential water use and a single-tier uniform rate for non-residential customers. Under the residential rate design, the unit price of water increases as usage rises, providing progressively stronger financial incentives for customers to use water efficiently and to limit discretionary outdoor use. The District also offers rate assistance to lower-income households through its Customer Assistance Program (CAP). All District water rates are reviewed and authorized by the CPUC through the General Rate Case process conducted every three years.

## 5.4 Water Loss Management

The District conducts annual distribution system water loss audits using the American Water Works Association (AWWA) Free Water Audit Software and reports the results to the California Department of Water Resources.<sup>6</sup>

To guide ongoing water loss management, Cal Water has developed a Water Loss Control Compliance Plan and a Water Loss Control Policy. These documents provide a framework for:

- Meeting current and future CPUC and state water loss standards and regulatory requirements;
- Improving audit data quality and validation scores; and
- Identifying and implementing cost-effective water loss control actions.

Cal Water has also conducted a comprehensive assessment comparing each district's current and projected distribution system water loss to applicable water loss standards. The results indicate that, absent additional water loss control measures, the District would not comply with the state's real water loss performance standard, even in years when total regulated water use remains within its UWUO. Accordingly, enhanced leak detection, pressure management, infrastructure renewal, and related water loss control activities will be necessary to achieve compliance with the separate water loss performance requirement.

---

<sup>6</sup> Completed water audits may be accessed at: <https://wuedata.water.ca.gov/>

## 5.5 Customer Conservation Programs

Cal Water has a long-standing water-use efficiency program designed to reduce water use across residential and non-residential customer classes. The program includes landscape conversion incentives, irrigation equipment rebates, indoor device rebates, and customer education resources. Core programs available to residential customers are summarized below. Additional programs are offered to non-residential customers, and program offerings may be adjusted over time based on district-specific needs and program performance.

### 5.5.1 Current Customer Conservation Programs

Cal Water currently offers residential customers a range of water-use efficiency rebates, support services, and educational resources, including the following:

#### *Turf Replacement*

- Turf replacement rebates of up to \$3 per square foot for removal of turf and conversion to California-friendly, low-water-use landscaping with efficient irrigation.

#### *Irrigation Equipment Rebates*

- Smart Landscape Tune-Up: A free, site-specific irrigation assessment that includes approved repairs to existing irrigation systems and installation of high-efficiency sprinkler nozzles and smart irrigation controllers, as appropriate.
- Smart irrigation controllers: Rebates of \$125 per controller for weather- and soil-based irrigation controllers that adjust watering schedules based on site conditions.
- High-efficiency sprinkler nozzles: Rebates of \$5 per nozzle for replacing conventional spray nozzles with high-efficiency nozzles that apply water more uniformly.

#### *Indoor Device Rebates*

- High-efficiency clothes washers: Rebates of \$150 per washer for eligible models that use substantially less water than standard washers.
- MaP Premium high-efficiency toilets: Rebates of \$50 per toilet for models using 1.1 gallons per flush or less.

## Dixon District Conservation Master Plan: 2026-2030

- Conservation kits: Free kits containing water-saving plumbing devices, such as high-efficiency showerheads, faucet aerators, hose nozzles, leak detection tablets, and educational materials.

### *Online Resources*

- Cal Water maintains a suite of online water-use efficiency resources to help customers understand and adopt water-saving practices.

### *School Education*

- Cal Water's school education program includes the Aqua Adventures, A Splash of Creativity, H2Oath, and Water Smart Grant programs. Cal Water's Teacher Toolkit provides teachers with practical guidance and teaching rubrics for helping students learn about resource sustainability and the importance of using water wisely.

In addition to these core offerings, Cal Water may implement non-core programs in select districts to address specific local needs or emerging opportunities. For example, in recent years Cal Water implemented a direct-install bathroom retrofit program targeting lower-income households and multifamily properties in several of its districts.

Cal Water's customer conservation programs are implemented through a combination of in-house staff and contracted service providers. Cal Water conducts ongoing outreach and customer engagement to promote awareness and participation. In addition, customer service representatives are trained to assist customers with high water use or billing concerns by directing them to appropriate conservation programs and educational resources.

## 5.5.2 Future Customer Conservation Programs

Cal Water understands that its conservation programming must be adapted to the new MCCWL regulatory requirements. For instance, meeting the rigorous outdoor water use standards will require transitioning substantial amounts of turf area to more water efficient landscaping. Therefore, outdoor conservation measures, including turf replacement incentives and support services, will need to be further prioritized to drive future water savings. While targeted indoor efficiency measures have also been retained to maximize water savings, the focus remains heavily on outdoor improvements.

### *Achieving Landscape Transformation*

Achieving the required level of water savings in the Dixon District requires a rapid market transformation towards landscape efficiency. Typically, market transformations can span decades as they require shifting both consumer behaviors and supply chain dynamics, even with incentives. Early adopters have already made

necessary adjustments, but many property owners have not yet embraced this change. Landscape transformation represents a significant departure from traditional practices, often perceived as complex and undesirable by many. Overcoming this resistance and encouraging participation will be challenging.

A crucial aspect is convincing customers that embracing landscape efficiency enhances, rather than detracts from, the value of their property. The traditional view equates lush, green lawns with success and economic status. Therefore, changing this deep-seated perception to appreciate the aesthetics and benefits of water-sustainable landscaping is essential.

Given the urgency to transform landscapes without the luxury of time, Cal Water faces several challenges that require:

- Robust customer education.
- High levels of customer motivation.
- Accessibility to landscape design and plant knowledge.
- Considerable labor investment.
- Significant financial resources.

To increase customer engagement, Cal Water's programs must offer compelling incentives, clear communication about the required processes, and substantial support to guide customers through these changes. Table 2 outlines the key barriers to successful deployment of landscape transformation programs.

Many water users currently do not prioritize landscape water efficiency, lacking both understanding of its urgency and motivation to implement drastic changes.

Cal Water's strategy is to significantly enhance education about the need for outdoor water use reduction and how to achieve it. Fortunately, studies indicate a growing customer interest in aesthetically pleasing, water-efficient landscaping. Many property owners consider turf removal but require assistance to proceed. Time and cost are significant barriers.

To effectively encourage this shift, Cal Water must not only convince customers of the necessity of these changes but also provide them with extensive support—from design assistance to continuous engagement and resources. Additionally, incentives must be compelling enough to convince customers of the value of investing in these changes.

Success will depend on expanding education, services, and incentives to accelerate market transformation. To support this enhanced program structure, Cal Water must accordingly increase its staff, marketing efforts, operational support, and budget to meet these elevated service demands.

**Table 2. Barriers and Customer Requirements of Landscape Transformation Programs**

Landscape Transformation Barriers	Customer Requirements
<ul style="list-style-type: none"> <li>• Customers lack motivation to reduce their water use.</li> <li>• Most customers are unaware of, or overwhelmed by, landscape efficiency programs.</li> <li>• Landscape efficiency solutions must be “customized” for each property.</li> <li>• Water suppliers do not currently have a deep understanding of their customers.</li> <li>• Agencies do not possess the resources to uniquely target and engage their customers.</li> </ul>	<ul style="list-style-type: none"> <li>• Customers desire to have a beautiful landscape.</li> <li>• Each customer has a different vision of what comprises landscape beauty.</li> <li>• Most customers have considered converting their lawn, but they need help to accomplish this.</li> <li>• Customers confirmed that design support is the most important need.</li> <li>• Incentives are necessary to pull the trigger on converting their lawn.</li> <li>• There are a number of misperceptions that disconnect the customer from their actual water usage. They believe most water is used indoors; that they already have efficient equipment; and saving money is the main driver.</li> </ul>

*Beyond Landscape Transformation*

In addition to turf replacement, Cal Water has identified a suite of customer conservation programs with demonstrated water-saving potential and meaningful market impact. Together, these measures represent a comprehensive portfolio that—subject to adequate staffing and funding—is intended to support achievement of the water use reduction levels required under the MCCWL regulations. The measures summarized in Table 3 are representative of Cal Water’s current conservation approach. As program performance is evaluated and technologies evolve, Cal Water may refine this portfolio by modifying, replacing, or adding measures to ensure continued program effectiveness.

**Table 3. Representative Conservation Measures with Significant Savings Potential**

<b>Conservation Measure</b>	<b>Remaining Potential</b>	<b>Reasoning for Selecting</b>
<b>Home Water Budgets</b>	All single-family homes	<ul style="list-style-type: none"> <li>• Identifies customers with inefficient usage, thus allowing better targeting of programs and assistance.</li> <li>• Provides a foundational step in educating customers with powerful and personal information that identifies site-specific efficiency opportunities.</li> <li>• As an educational tool alone, shown to reduce water use.</li> </ul>
<b>Outdoor Efficiency</b>		
<b>Turf Replacement</b>	All properties with remaining turf	<ul style="list-style-type: none"> <li>• Required measure for meeting landscape and irrigation standards.</li> <li>• Huge remaining opportunity.</li> <li>• Long lifespan measure.</li> </ul>
<b>Sprinkler Tune-up</b>	All properties with remaining turf	<ul style="list-style-type: none"> <li>• Nearly all irrigation systems need repair.</li> <li>• Repairs are necessary before efficiency upgrades are made otherwise new products will not work as designed.</li> <li>• High customer demand.</li> </ul>
<b>Smart Controllers</b>	All properties with irrigation	<ul style="list-style-type: none"> <li>• High customer receptivity due to technical aspect of device.</li> <li>• Reduces overwatering by providing the appropriate amount of water based on the local weather.</li> </ul>
<b>Pressure Regulating Spray Heads</b>	All properties with popup spray heads	<ul style="list-style-type: none"> <li>• Millions of non-pressure regulating spray heads.</li> <li>• Reduces water use due to high water pressure and low head drainage.</li> </ul>
<b>High Efficiency Sprinkler Nozzles</b>	All properties with popup spray heads	<ul style="list-style-type: none"> <li>• Millions of high flow nozzles are available for retrofit.</li> <li>• Solution for customers electing to keep turf.</li> <li>• Reduces runoff.</li> <li>• High cost effectiveness.</li> <li>• Generally easy retrofit.</li> </ul>
<b>Indoor Efficiency</b>		

Conservation Measure	Remaining Potential	Reasoning for Selecting
<b>Premium Efficiency Toilets</b>	Nearly 50% of existing fixtures are 1.6 GPF or above	<ul style="list-style-type: none"> <li>Reliable 25-year life of water savings.</li> <li>Easy retrofit.</li> </ul>
<b>High Efficiency Clothes Washers</b>	All single-family homes and multi-family in-unit washers	<ul style="list-style-type: none"> <li>Customers prefer high efficiency models.</li> <li>Easy to administer.</li> <li>Washers have 10–12-year life</li> </ul>

### 5.5.3 CII BMPS

The MCCWL regulations require that the District implement CII BMPs for non-residential customers with very high usage.

The regulations specify that the District must implement at least one BMP from each of the following categories for customers with usage above the 80th percentile, while it must implement at least two BMPs from these categories for customers with usage above the 97.5th percentile.

#### *Outreach, Technical Assistance, and Education BMPs*

1. Direct contacts via site visits or phone calls
2. Informative or educational bill inserts
3. Conducting workshop or developing training videos
4. Webpage portals to access information, tools, and rebates
5. Cost-effectiveness analysis tools
6. Commercials or advertisements
7. Grass roots marketing
8. Community based social marketing
9. Other CII-best management practices derived from additional innovation and technology advancement that can be taken by suppliers, subject to Water Board approval

#### *Incentives BMPs*

1. Rebates and cost-sharing for replacing inefficient fixtures, equipment, irrigation systems or landscapes with water efficient ones
2. Certification or branding programs that recognize customers as water efficient
3. Incentives for technologies that enable customers to identify, measure, and analyze indoor and outdoor water use

## Dixon District Conservation Master Plan: 2026-2030

4. Other CII-best management practices derived from additional innovation and technology advancement that can be taken by suppliers, subject to Board approval

### *Landscape BMPs*

1. Landscape and irrigation management practices to promote improved water use efficiency
2. Irrigation system inspections, audits, or surveys
3. Training or guidance on irrigation scheduling and maintenance
4. New development landscape inspection, workshops, and training
5. Programs to remove turf and replace it with climate-ready vegetation
6. Programs to decrease urban heat and reduce turf water use by planting trees
7. Programs to install green infrastructure such as swales or rain gardens that offset irrigation needs
8. Other CII-best management practices derived from additional innovation and technology advancement that can be used by suppliers, subject to Water Board approval

### *Collaboration and Coordination BMPs*

1. Coordination with “green” building certification or recognition programs to promote water use efficiency
2. Coordination with land use authorities to check new landscapes design and implementation
3. Collaboration with non-governmental organizations on outreach and education
4. Collaboration with municipal arborists and tree planting organizations to expand and maintain urban forests
5. Collaboration with stormwater agencies to install green infrastructure such as swales or rain gardens to also offset irrigation needs
6. Other CII-best management practices derived from additional innovation and technology advancement that can be taken by suppliers, subject to Water Board approval

### *Operational BMPs*

1. Infrastructure changes (for example, smart meter replacement programs)
2. Billing or data collection procedures (for example, data tracking, analysis, and reporting improvements)
3. Other operational best management practices to facilitate CII best management practices program implementation and evaluation
4. Other CII best management practices derived from additional innovation and technology advancement that can be taken by suppliers, subject to Water Board approval

Table 4 shows the key tasks and milestones related to these new CII BMP requirements.

**Table 4. Tasks and Milestones for Regulatorily Prescribed CII BMPs**

<b>Task</b>	<b>Frequency</b>	<b>Timing</b>
Identify the top 2.5% and the top 20% of CII water users	One time and on-going	June 30, 2025
Identify the top 2.5% of CII water users and top 20% of connections in each water use classification	One time and on-going	June 30, 2029
Identify existing CII connections that appear to be inefficient according to key business activity indicators	One time and on-going	June 30, 2029
Implement at least 2 programs from each BMP category for top 2.5% of CII water users	Annually	June 30, 2039
Implement at least 1 program from each BMP category for top 20% of accounts in each water use classification	Annually	June 30, 2039
Conduct marketing and outreach to targeted commercial customers	Annually	Continuous
Administer Commercial Rebate and Support Programs	Annually	Continuous

## 5.6 Program Monitoring and Reporting

Ongoing monitoring, evaluation, and reporting are central components of Cal Water’s conservation program strategy. These activities ensure that programs are performing as intended, that water savings estimates are supported by empirical evidence, and that the District meets CPUC and state regulatory requirements. Together, these efforts provide accountability, support continuous program improvement, and inform future program design and funding decisions.

### *Program Tracking*

Cal Water uses the Alliance for Water Efficiency (AWE) Water Conservation Tracking Tool to systematically track program participation, expenditures, and estimated

## Dixon District Conservation Master Plan: 2026-2030

water savings across conservation programs. This system allows Cal Water to track implementation activity, evaluate program cost-effectiveness, identify participation trends, and assess progress toward water savings targets. The tracking data also support demand forecasting, program planning, and regulatory reporting.

### *Savings Evaluations*

In addition to routine tracking, Cal Water conducts periodic savings evaluations to assess the actual water use impacts of its conservation programs. These evaluations typically use statistical and econometric methods to compare water use patterns before and after program participation, often relative to control groups. Recent and ongoing evaluations include:

- Toilet, showerhead, faucet, and complete bathroom retrofit water savings evaluations
- Lawn-to-Garden Program turf replacement water savings evaluation
- Smart Landscape Tuneup Program water savings evaluation
- Flume Rebate Program water savings evaluation

### *CPUC and State Reporting*

Cal Water fulfills multiple conservation-related reporting requirements at both the CPUC and state levels. These include:

- **CPUC reporting:** Annual reports detailing conservation program activities, expenditures, and estimated water savings by district. These reports support regulatory oversight and future budget authorizations.
- **State reporting:**
  - Annual distribution system water loss audits and reporting to the California Department of Water Resources
  - Annual Urban Water Use Objective (UWUO) compliance assessments
  - Annual Commercial, Industrial, and Institutional (CII) performance measure compliance reporting

These monitoring and reporting functions require substantial data management, analytical support, and regulatory coordination, and are a key driver of the administration and research budget described in Section 6.

## 5.7 Water Conservation Program Staffing

Cal Water's Conservation Department is currently staffed by nine full-time equivalent (FTE) positions. A prior staffing evaluation by Cal Water indicated that the industry standard staffing ratio is 12 FTEs per million people served. At present, Cal Water has only 9 FTEs serving a customer base of 2 million people, or roughly one-third the

standard level. This evaluation, conducted before the *Making Conservation a California Way of Life* regulations were introduced, already demonstrated a stark understaffing issue. The additional responsibilities introduced by the new regulations will undoubtedly intensify this challenge.

In light of mandated UWUO reductions, SGMA-related impacts, and the extensive reporting and performance requirements associated with the MCCWL regulations, Cal Water has identified a need to expand its conservation program staffing.

While the use of consultants could provide short-term support, the ongoing and long-term nature of the regulatory requirements makes exclusive reliance on temporary staffing impractical. In particular, the data analysis, program tracking, and reporting obligations associated with the MCCWL framework require sustained institutional knowledge and continuity that are best supported through permanent staff.

Cal Water's staffing strategy therefore emphasizes strengthening internal capacity to manage conservation programs, lead outreach and customer engagement efforts, support customers, oversee ongoing CII activities, and fulfill reporting and compliance obligations. Consultants are expected to continue to play a targeted role by providing short-term, specialized expertise as needed, allowing flexibility while maintaining a strong in-house program foundation.

Consistent with this strategy, Cal Water has proposed in its 2024 GRC an increase in Conservation Department staffing from nine to fifteen positions. The six requested positions and their primary responsibilities are summarized in Table 5. At the time this plan was prepared, a final decision in the 2024 GRC had not yet been issued. As a result, it remains uncertain whether the CPUC will authorize the requested staffing increases necessary to support compliance with state conservation requirements.

**Table 5. Proposed New Conservation Staff Positions**

New Position	Responsibilities
Conservation Manager	<ul style="list-style-type: none"> <li>• Program development/implementation/management</li> <li>• Budgeting</li> <li>• Staff oversight</li> </ul>
Regional Conservation Coordinator (2 positions)	<ul style="list-style-type: none"> <li>• Regional program implementation</li> <li>• District coordination</li> <li>• Customer engagement</li> </ul>
Water Resource Sustainability Analyst	<ul style="list-style-type: none"> <li>• Program tracking/analysis</li> <li>• Compliance assessment/reporting</li> <li>• Data management</li> </ul>
Water Resource Sustainability Assistant	<ul style="list-style-type: none"> <li>• Data entry</li> <li>• Analysis support</li> <li>• Compliance reporting support</li> </ul>
Conservation Assistant	<ul style="list-style-type: none"> <li>• Program application/rebate processing</li> <li>• Customer assistance</li> <li>• Data entry/processing</li> </ul>

## 5.8 Summary of Water Conservation Program Strategy

Cal Water’s conservation strategy for the Dixon District integrates regulatory tools, pricing signals, system efficiency measures, customer-focused programs, and rigorous monitoring and reporting to achieve sustained reductions in water demand. This multi-layered approach reflects the need to meet evolving state conservation standards, support groundwater sustainability, and manage long-term cost-of-service impacts while maintaining reliable service.

Centralized program administration provides consistency, economies of scale, and strong cost-effectiveness, while district-level implementation focuses outreach and resources where they are most needed. Foundational elements of the strategy include water waste prevention and enforcement, universal metering and conservation-oriented rate design, and proactive water loss management. These structural measures create the conditions for efficient water use and system performance.

Building on this foundation, customer conservation programs deliver direct savings through rebates, technical assistance, education, and market transformation initiatives. In response to *Making Conservation a California Way of Life* requirements, increasing emphasis is being placed on outdoor landscape efficiency and support for high-water-use residential and commercial customers. Ongoing program tracking, empirical savings evaluations, and CPUC and state reporting ensure that program performance is documented, savings assumptions remain evidence-based, and the District can demonstrate compliance with UWUO, CII, and water loss standards.

## Dixon District Conservation Master Plan: 2026-2030

Together, these elements position conservation as a long-term resource management strategy that supports regulatory compliance, groundwater sustainability, water supply reliability, and cost-effective water supply planning for the District.

## 6 Current and Requested Conservation Budget

---

Because the Dixon District is projected to comply with its Urban Water Use Objective under currently authorized conservation levels and does not face significant SGMA-driven demand reduction requirements, Cal Water has proposed a reduction in the District's conservation budget in the 2024 General Rate Case. The requested budget maintains funding for core program implementation while achieving efficiencies in public information and administrative support functions.

Although the District is not projected to comply with the state's real water loss performance standard under baseline conditions, water loss control measures are primarily funded through capital improvement and system replacement programs rather than the conservation budget. Accordingly, the proposed conservation funding level reflects the District's compliance outlook and program needs during the 2026-2030 planning period.

### 6.1 Conservation Program Budget Components

The District's conservation budget consists of four primary components: (1) program implementation, (2) public information, (3) school education, and (4) administration and research. The program implementation budget is the largest component and covers the costs of delivering conservation programs, excluding marketing and internal staffing costs. The public information budget supports program marketing as well as broader conservation outreach and customer communications. The school education budget funds school-based conservation education programs offered within the District. The administration and research budget covers the District's allocated share of conservation staffing costs, along with expenditures for external consultants performing research, program evaluation, and water savings verification.

### 6.2 Conservation Program Budget Adjustments

In its 2024 GRC, Cal Water proposed three key adjustments to the currently authorized conservation program budget to address evolving regulatory and operational needs:

#### 1. UWUO Compliance Budget Adjustment:

To support compliance with UWUO requirements, Cal Water conducted a detailed cost analysis using a representative portfolio of conservation measures. This analysis identified the measures and activity levels needed to achieve projected savings, estimated associated annual and cumulative water savings, and calculated the corresponding costs required to meet UWUO targets.

#### 2. Adjustments for SGMA-Impacted and High-Cost Districts:

Additional adjustments were proposed for districts affected by SGMA and for those facing high incremental water supply costs. These adjustments allocate additional conservation resources to address groundwater sustainability requirements and to pursue conservation as a cost-effective alternative to higher-cost supply development.

### 3. Adjustments to Mitigate Potential Implementation Feasibility and Cost-of-Service Concerns:

Because the first two adjustments resulted in substantial budget increases in some districts, a moderating adjustment was applied to limit potential cost-of-service impacts. This constraint effectively capped proposed program budget increases at no more than five times a district's currently authorized conservation budget, balancing regulatory compliance needs with affordability and implementation feasibility.

## 6.3 Conservation Program Budget Comparison

Figures 12 and 13 compare the Dixon District's currently authorized conservation budget with the budget requested in the 2024 General Rate Case (GRC). Overall, the proposed annual conservation budget decreases from \$40,729 to \$33,695, representing an approximately 20 percent reduction in total conservation funding.

This budget proposal reflects the District's projected compliance position and the primary funding mechanisms for addressing its principal compliance risks. First, the District is projected to remain in compliance with its UWUO under currently authorized conservation levels and anticipated passive savings; therefore, a budget increase to close an UWUO gap is not required. Second, the District operates in a medium-priority groundwater basin, and SGMA compliance is not expected to be a major driver of incremental conservation needs during this planning period. Third, although the District is not projected to comply with the State's real water loss standard under baseline conditions, the actions required to reduce real water loss—such as leak detection, pressure management, pipeline replacement, and other system improvements—are primarily implemented and funded through the District's capital programs and system replacement budgets, rather than through the conservation program budget. Accordingly, the requested conservation budget focuses on maintaining core customer programs while achieving efficiencies in support functions.

The program implementation budget is unchanged at \$19,314. Because other budget components decline, the share of the total conservation budget allocated to direct customer programs increases from 47 percent to 57 percent, reflecting a strategic decision to preserve on-the-ground program delivery even as total funding declines.

The public information budget decreases from \$7,943 to \$3,863, reducing its share of total funding from 20 percent to 11 percent. This reduction reflects lower planned expenditures for program marketing and outreach, consistent with maintaining baseline participation levels rather than expanding program activity.


## Dixon District Conservation Master Plan: 2026-2030

Similarly, the administration and research budget decreases from \$11,371 to \$7,389, with its share declining from 28 percent to 22 percent. This change reflects reduced administrative support and related program overhead under the requested budget level.


The school education budget increases modestly from \$2,101 to \$3,129, increasing its share from 5 percent to 9 percent. While small in absolute terms, this adjustment supports continued school-based education and community engagement activities.

Taken together, the requested budget represents a targeted recalibration rather than a program expansion: core program delivery is maintained, expenditures for marketing and administration are reduced, and the District's major compliance risk related to real water loss is expected to be addressed primarily through capital-funded system improvements rather than conservation program funding.

**Figure 12. Dixon District Conservation Budget: Current Authorized and Requested**



**Figure 13. Dixon District Conservation Budget Shares**



## 7 Conclusion

---

The Dixon District has achieved substantial and sustained reductions in water use over the past two decades, driven by universal metering, conservation-oriented pricing, expanded customer programs, and state and federal efficiency standards. As documented in this plan, these efforts have enabled the District to meet or exceed historical conservation requirements, including compliance with the Water Conservation Act of 2009 and CPUC conservation goals, while maintaining reliable service to a growing population.

Looking ahead, the conservation landscape facing the District is fundamentally different from that of the past. The *Making Conservation a California Way of Life* regulations establish increasingly stringent efficiency standards and reporting requirements. At the same time, the Sustainable Groundwater Management Act (SGMA) introduces long-term constraints on groundwater supplies. These regulatory drivers are reinforced by rising water supply costs, which make conservation an increasingly cost-effective component of the District's resource strategy.

The analysis presented in this plan indicates that, under currently authorized funding levels and anticipated passive savings, regulated water use is expected to remain below UWUO requirements. In contrast, baseline real water loss projections exceed the applicable state water loss standard beginning in 2028 and continue to do so throughout the forecast period. Addressing this gap will require enhanced leak detection, pressure management, infrastructure renewal, and related water loss control activities.

To respond to these challenges, Cal Water's conservation strategy for the Dixon District integrates regulatory tools, pricing signals, system efficiency measures, and customer-focused programs within a centrally administered framework designed to maximize consistency and cost-effectiveness. Expanded monitoring, evaluation, and reporting capabilities will ensure that program performance is documented, savings assumptions remain evidence-based, and support the scale of implementation, customer outreach, and regulatory compliance now required.

In summary, conservation is a core long-term resource strategy for the Dixon District. Continued investment in conservation will help the District meet evolving state efficiency standards, reduce pressure on groundwater supplies, support water supply reliability, and manage the cost of service for customers. This Conservation Master Plan provides the framework for achieving these objectives over the 2026–2030 planning period and establishes a foundation for future updates as regulatory requirements, water use patterns, and program performance evolve.

## **Appendix I: Resolution to Adopt**



## CALIFORNIA WATER SERVICE

1720 North First Street  
San Jose, CA 95112-4598 Tel: (408) 367-8200

June 26, 2026

Mr. Ryan Bailey, Manager  
Water Use Efficiency Branch  
California Department of Water Resources  
P.O. Box 942836  
Sacramento, CA 94236-0001

**Re: Adoption of the 2025 Urban Water Management Plan and  
Water Shortage Contingency Plan  
California Water Service – Dixon District**

Mr. Bailey:

This letter serves as notice that California Water Service (Cal Water) has formally adopted this 2025 Urban Water Management Plan (UWMP) and Water Shortage Contingency Plan (WSCP) for our Dixon District.

The attached resolution from Cal Water's Board of Directors on September 28, 2005 delegated authority for this approval to, among others, any Vice President. I have approved the attached UWMP and WSCP, which were developed by staff under my supervision in accordance with the Urban Water Management Planning Act contained in the California Water Code, Division 6, Part 2.6.

If you have any questions regarding this UWMP or WSCP, please contact Jake Lam at the above mailing address, by telephone at (408) 367-8257, or by email at [jlam@calwater.com](mailto:jlam@calwater.com).

Sincerely,

A handwritten signature in black ink, appearing to read "K. G. Jenkins".

Kenneth G. Jenkins  
Vice President, Water Resources Planning and Sustainability

Attachments – Resolution

cc: Scott Wagner – Director of Water Resources  
Ben Voight – Local Manager, Dixon District





## CALIFORNIA WATER SERVICE

1720 North First Street  
San Jose, CA 95112-4598 Tel: (408) 367-8200

### CALIFORNIA WATER SERVICE COMPANY

RESOLVED, that this Board of Directors delegates its authority to approve Urban Water Management Plans as required under the Urban Water Management Planning Act contained in California Water Code 6, Part 2.6 to the President and Chief Executive Officer, any Vice President, the Corporate Secretary and any Assistant Secretary of California Water Service Company.

--oOo--

I, DAN L. STOCKTON, Corporate Secretary of California Water Service Company, a California corporation, do hereby certify that the foregoing is a full, true and correct copy of certain resolution adopted by the Board of Directors of said corporation at a regular meeting of said Board duly called and held September 28, 2005, at which a quorum was present, that all Directors present voted in favor of said resolution, and that said resolution has never been annulled or revoked but is still in full force and effect.

IN WITNESS WHEREOF, I have hereunto signed my name this 7th day of September, 2005.

A handwritten signature in blue ink that reads "Dan L. Stockton". The signature is written in a cursive style and is positioned above a horizontal line.

Dan L. Stockton  
Corporate Secretary

