

CALIFORNIA WATER SERVICE
REPORT ON WATER QUALITY RELATIVE TO PUBLIC HEALTH GOALS
IN THE SALINAS WATER SYSTEM
MAY 28, 2025

Background

Provisions of the California Health and Safety Code (Section 116470 [b]) specify that water systems serving more than 10,000 connections shall prepare a special report by July 1, 2025, if their water exceeds any Public Health Goals (PHGs) after each compliance period. PHGs are non-enforceable goals established by the Cal-EPA's Office of Environmental Health Hazard Assessment (OEHHA). The statute also requires that water suppliers use the Maximum Contaminant Level Goals (MCLGs) adopted by USEPA for constituents for which OEHHA has not adopted a PHG.

There are a few constituents that are routinely detected in water systems, at levels usually well below the drinking water standards, for which no PHG or MCLG has yet been adopted (e.g., Total Trihalomethanes). These constituents will be addressed in a future required report after a PHG has been adopted.

In accordance with the Health and Safety Code (reference 1), if a constituent was detected in the water system's supply during 2022, 2023, or 2024 at a level exceeding an applicable PHG or MCLG, it will be identified in this report. Additional information includes the numerical public health risk associated with the Maximum Contaminant Level (MCL), plus the PHG or MCLG; the category or type of risk to health that could be associated with each constituent; the best available treatment technology that could be used to reduce the constituent level; and an estimate of the cost to install that treatment if it is appropriate and feasible.

What are Public Health Goals?

PHGs are set by OEHHA, which is part of Cal-EPA, and are based solely on public health risk considerations. None of the practical risk-management factors that are considered in the rulemaking process by the USEPA or the California State Water Resources Control Board's Division of Drinking Water (DDW) in setting drinking water standards, otherwise known as Maximum Contaminant Levels (MCLs). These factors include analytical detection capability, treatment technology available, benefits, and costs. PHGs and MCLGs are not mandatory and therefore compliance is not legally required by any public water system.

Water Quality Data Considered

All water quality data collected by our system between 2022 through 2024 to determine compliance with drinking water standards, specifically from sources that were not treated to remove certain constituents, are included in this report. This information is also available in our annual Consumer Confidence Reports which can be accessed online at: <https://www.calwater.com/water-quality-reports/>.

Guidelines Followed

The Association of California Water Agencies (ACWA) formed a workgroup that prepared guidelines for water utilities to use in preparing these required reports and ACWA guidelines were followed in preparation of this report.

Best Available Treatment Technology and Cost Estimates

Both the USEPA and DDW adopt the best available technologies (BATs), which are the best-known methods of reducing contaminant levels to the MCL. Costs can be estimated for such technologies; however, since many PHGs and all MCLGs are set much lower than the MCL, it is not feasible to determine what treatment is needed to further reduce a constituent to an established goal. Many established goals are set below analytical detection limits, which means that the level has been lowered to zero. In some cases, installing treatment to further reduce very low levels of one constituent may have adverse effects on other aspects of water quality. Additionally, since there is little data readily available to estimate the cost of treatment to achieve some of the goal levels, use of this “BAT” may still not achieve the PHG or MCLG and the costs may be significantly higher to do so.

Costs estimates for treatment were taken from Tables 1 – 3 in the *Suggested Guidelines for Preparation of Required Reports on Public Health Goals to satisfy requirements of California Health and Safety Code Section 116470(b)*, prepared by Association of California Water Agencies (ACWA), April 2025.

Constituents Detected That Exceed a PHG or MCLG

The following is a discussion of constituents that were detected in one or more of our drinking water sources at levels above the PHG, or alternatively above the MCLG. As previously stated, the numerical value for PHGs and MCLGs are often set below detectable levels. Therefore, the Detection Limit for Purposes of Reporting (DLR) is provided for each constituent. DLR is the lowest quantity of a substance that can be distinguished within a stated confidence limit, generally one percent. Constituents reported in this section were detected above the method DLR and PHG, and in sources that supplied the system during 2022, 2023 and 2024.

ARSENIC (As)

The PHG for arsenic is 0.004 ppb, and the MCL is 10 ppb. The DLR is 2.0 ppb. Arsenic is detected above the DLR and PHG without treatment in 17 active wells.

The category of health risk for arsenic is carcinogenicity. The numerical cancer health risk at the PHG is 1×10^{-6} , which means one excess case of cancer per one million. The numerical health risk at the MCL is 2.5×10^{-3} which means two and a half excess cases of cancer per thousand people.

BATs for treatment/removal of arsenic are activated alumina, coagulation filtration, ion exchange, lime softening, and reverse osmosis. All these technologies generate waste that is sometimes classified as hazardous waste. The costs below do not reflect the cost of disposing of hazardous waste.

The estimated cost to install and operate a treatment system that would reliably reduce arsenic concentrations to the PHG would be approximately \$2.59/1,000 gallons treated. This would result in an assumed increased cost for each service connection of \$394.74 per year.

COPPER (Cu)

The PHG for copper is 0.3 ppm, and while there is no MCL, there is an Action Level (AL) of 1.3 ppm. Compliance with this drinking water standard is based on the 90th percentile value of all samples collected from household taps in the distribution system.

The category of health risk for copper is gastrointestinal irritation. There is no numerical health risk established for copper at the PHG or the AL. Since copper is non-carcinogenic, the cancer risk or health risk could not be calculated by OEHHA for this chemical.

While copper was not detected above the PHG in the source water, of 50 samples analyzed, zero exceeded the action level, and the 90th percentile was 0.47 ppm. The Salinas water system is in compliance with the federal and state Lead and Copper Rule and is, therefore, deemed to have “optimized corrosion control.”

HEXAVALENT CHROMIUM (CrVI)

The PHG for hexavalent chromium (CrVI) is 0.02 ppb and the California MCL is 10 ppb. The DLR is 0.1 ppb. CrVI is detected above the DLR and PHG without treatment in 25 active wells.

The category of health risk for chromium is carcinogenicity. The numerical health risk at the PHG is 1×10^{-6} , which means one excess case of cancer per one million people. The numerical health risk at the MCL is 5×10^{-4} , which means five excess cases of cancer per ten thousand people.

The BATs for treatment/removal of chromium are coagulation/filtration, ion exchange, lime softening, and reverse osmosis. The estimated cost to install and operate a treatment system that will reliably reduce the CrVI concentration to the PHG is approximately \$2.19/1,000 gallons treated. This would result in an assumed increased cost for each service connection of \$490.95 per year.

NICKEL (Ni)

The PHG for nickel is 12 ppb, and the MCL is 100 ppb. The DLR is 10 ppb. Nickel is detected without treatment in 4 active wells.

The category of health risk for nickel is developmental toxicity (causes increased neonatal deaths). There are no established PHG and MCL cancer health risks.

The BATs for treatment/removal of nickel are ion exchange, lime softening, and reverse osmosis. The estimated cost to install and operate a treatment system that will reliably reduce the nickel concentration to the PHG is approximately \$2.46/1,000 gallons treated. This would result in an assumed increased cost for each service connection of \$88.22 per year.

RADIUM 226 AND 228

The PHG for radium 226 is 0.05 pCi/L (picocuries per liter), and 0.019 pCi/L for radium 228. The MCL for the combined radium 226 and 228 is 5 pCi/L. The DLR for either radium 226 or 228 is 1 pCi/L. Radium 226 is detected without treatment in 1 active well and radium 228 is detected without treatment in zero active wells.

The category of health risk associated with radium is carcinogenicity. The numerical health risk at the PHG is 1×10^{-6} , which means one cancer case per one million people. The numerical health risk for radium 226 at the MCL is 1×10^{-4} , which means one excess case of cancer per ten thousand people. The numerical health risk for radium 228 at the MCL is 3×10^{-4} , which means three excess cases of cancer per ten thousand people.

The BAT for the treatment/removal of radium to concentrations below the MCL is reverse osmosis. The estimated cost to install and operate a treatment system that will reliably reduce the radium concentration is approximately \$5.31/1000 gallons treated. This would result in an assumed increased cost for each service connection of \$47.61 per year.

SELENIUM (Se)

The PHG for selenium is 30 ppb and the MCL is 50 ppb. The DLR is 5 ppb. Selenium is detected without treatment in 1 active well.

The category of health risk for selenium is integumentary toxicity which causes hair loss and nail damage. There are no established PHG and MCL cancer health risks for selenium.

BATs for treatment/removal of selenium are ion exchange, lime softening, and reverse osmosis. The estimated cost to install and operate a treatment system that will reliably reduce selenium concentration to the PHG is approximately \$2.46/1,000 gallons treated. This would result in an assumed increased cost for each service connection of \$22.05 per year.

TETRACHLOROETHYLENE (PCE)

The PHG for PCE is 0.06 ppb and the MCL is 5 ppb. The DLR is 0.5 ppb. PCE is detected above the DLR and PHG without treatment in 4 active wells.

The category of health risk of PCE is carcinogenicity. The numerical health risk for PCE at the PHG is 1×10^{-6} , which means one excess case of cancer per one million people. The numerical risk at the MCL is 8×10^{-5} , which means eight excess cases of cancer per 100,000 people.

BATs for the treatment/removal of PCE are granular-activated carbon (GAC) and air stripping. The estimated cost to install and operate a GAC treatment system that would reliably reduce the PCE level to zero would be approximately \$1.96/1,000 gallons treated. This would result in an assumed increased cost for each service connection of \$70.29 per year.

URANIUM AND GROSS ALPHA PARTICLE ACTIVITY

The PHG for uranium is 0.43 pCi/L (picocuries per liter) and the MCL is 20 pCi/L. The DLR is 1 pCi/L. Uranium is detected without treatment in 21 active wells.

There is no California PHG for gross alpha particle activity; however, the MCLG level is set at 0 pCi/L and the MCL is 15 pCi/L. The DLR is 3 pCi/L. Gross alpha particle activity is detected without treatment in 8 active wells.

The category of health risk associated with uranium and gross alpha particle activity is carcinogenicity. The numerical health risk for uranium at the PHG is 1×10^{-6} , which means one excess case of cancer per one million people. The numerical health risk for uranium at the MCL is 5×10^{-5} , which means five excess cases of cancer per 100,000 people.

The BAT for the treatment/removal of uranium and gross alpha is reverse osmosis. The estimated cost to install and operate a reverse osmosis treatment system that would reliably reduce the uranium and gross alpha particle activity concentration is approximately \$5.31/1,000 gallons treated. This would result in an assumed increased cost for each service connection of \$999.72 per year.

RECOMMENDATIONS FOR FURTHER ACTION

The drinking water quality of the Salinas water system meets all State and Federal drinking water standards set to protect public health. Cal Water will continue to assure the protection of public health by researching and examining emerging treatment technologies on an ongoing basis while taking into account health protection benefits and cost.

REFERENCES:

- No.1 Excerpt from California Health & Safety Code: Section 116470 (b)
- No.2 Table of Regulated Constituents with MCLs, PHGs, or MCLGs
- No.3 Salinas Water System's 2022, 2023, 2024 Consumer Confidence Report
- No.4 Health Risk Information for Public Health Goal Exceedance Reports prepared by the Office of Environmental Health Hazard Assessment, California Environmental Protection Agency, February 2025
- No. 5 Suggested Guidelines for Preparation of Required Reports on Public Health Goals to satisfy requirements of California Health and Safety Code Section 116470(b), prepared by Association of California Water Agencies (ACWA), April 2025